

Subtype ECO100

545() FC 100100	
Certificate Holder	Energie
Address	
ZIP	4570-311
City	Laúndos - Póvoa de Varzim
Country	PT
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	ECO100
Registration number	011-1W0349
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R134a
Mass of Refrigerant	1.3 kg
Certification Date	30.09.2020
Testing basis	HP KEYMARK certification scheme rules rev. 7



Model Eco100

Model name	Eco100
Application	n/a
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Cooling mode application (optional)	n/a
Any additional heat sources	Outdoor Air
General data	
Power supply	1x230V 50Hz
Off-peak product	No

Heat Pump for Domestic Hot Water (DHW)