

Subtype DAIKIN ALTHERMA 3 M 16kW

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA 3 M 16kW
Registration number	011-1W0426
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	3.8 kg
Certification Date	27.10.2020
Testing basis	HP KEYMARK certification scheme rules rev. 7

Model EBLA16D(3)V3

Model name	EBLA16D(3)V3
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.00 kW	15.63 kW
El input	3.53 kW	5.68 kW
COP	4.53	2.75

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.58 kW	
Cooling capacity	14.01	
EER	3.06	

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	185 %	132 %
Prated	12.00 kW	12.00 kW
SCOP	4.69	3.37
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.20 kW	9.40 kW

COP Tj = -7°C	2.87	1.95
Cdh Tj = -7 °C		1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.33	3.27
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.70 kW	4.40 kW
COP Tj = +7°C	6.83	4.93
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.50 kW	5.30 kW
COP Tj = 12°C	8.82	6.60
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.76 kW	10.10 kW
COP Tj = Tbiv	2.48	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.76 kW	7.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.67
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	4.10 kW
Annual energy consumption Qhe	5281 kWh	7359 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	246 %	172 %
Prated	12.00 kW	12.10 kW
SCOP	6.23	4.38
Tbiv	2 °C	3 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.90 kW	9.80 kW
COP Tj = +2°C	3.30	2.17
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.10 kW	7.60 kW
COP Tj = +7°C	5.64	3.83
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.20 kW	5.00 kW
COP Tj = 12°C	7.73	5.69

Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.90 kW	11.00 kW
COP Tj = Tbiv	3.30	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.30	2.17
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	2.27 kW
Annual energy consumption Qhe	2573 kWh	3690 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	14.00 kW	
SEER	5.59	
Pdc Tj = 35°C	14.00 kW	
EER Tj = 35°C	3.06	
Pdc Tj = 30°C	10.80 kW	
EER Tj = 30°C	4.41	
Cdc Tj = 30 °C	1.0	
Pdc Tj = 25°C	6.90 kW	
EER Tj = 25°C	6.56	
Cdc Tj = 25 °C	1.0	
Pdc Tj = 20°C	5.90 kW	
EER Tj = 20°C	8.51	
Cdc Tj = 20 °C	1.0	
Poff	23 W	
PTO	23 W	
PSB	23 W	
PCK	0 W	
Annual energy consumption Qce	1500 kWh	

Model EBLA16D(3)W1		
Model name	EBLA16D(3)W1	
Application	Heating (medium temp)	
Units	Outdoor	
Climate zone (for heating)	Warmer Climate	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C	
Any additional heat sources	n/a	
General data		
Power supply	3x400V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.63 kW
El input	3.53 kW	5.68 kW
COP	4.53	2.75
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	4.58 kW	
Cooling capacity	14.01	
EER	3.06	
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	185 %	132 %
Prated	12.00 kW	12.00 kW
SCOP	4.69	3.37
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.20 kW	9.40 kW

COP Tj = -7°C	2.87	1.95
Cdh Tj = -7 °C		1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.33	3.27
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.70 kW	4.40 kW
COP Tj = +7°C	6.83	4.93
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.50 kW	5.30 kW
COP Tj = 12°C	8.82	6.60
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.76 kW	10.10 kW
COP Tj = Tbiv	2.48	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.76 kW	7.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.67
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	4.10 kW
Annual energy consumption Qhe	5281 kWh	7359 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	246 %	172 %
Prated	12.00 kW	12.10 kW
SCOP	6.23	4.38
Tbiv	2 °C	3 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.90 kW	9.80 kW
COP Tj = +2°C	3.30	2.17
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.10 kW	7.60 kW
COP Tj = +7°C	5.64	3.83
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.20 kW	5.00 kW
COP Tj = 12°C	7.73	5.69

Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.90 kW	11.00 kW
COP Tj = Tbiv	3.30	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.30	2.17
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	2.27 kW
Annual energy consumption Qhe	2573 kWh	3690 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	14.00 kW	
SEER	5.59	
Pdc Tj = 35°C	14.00 kW	
EER Tj = 35°C	3.06	
Pdc Tj = 30°C	10.80 kW	
EER Tj = 30°C	4.41	
Cdc Tj = 30 °C	1.0	
Pdc Tj = 25°C	6.90 kW	
EER Tj = 25°C	6.56	
Cdc Tj = 25 °C	1.0	
Pdc Tj = 20°C	5.90 kW	
EER Tj = 20°C	8.51	
Cdc Tj = 20 °C	1.0	
Poff	23 W	
PTO	23 W	
PSB	23 W	
PCK	0 W	
Annual energy consumption Qce	1500 kWh	

Model EDLA16D(3)V3		
Model name	EDLA16D(3)V3	
Application	Heating (medium temp)	
Units	Outdoor	
Climate zone (for heating)	Warmer Climate	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	1x230V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.63 kW
El input	3.53 kW	5.68 kW
COP	4.53	2.75
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	4.58 kW	
Cooling capacity	14.01	
EER	3.06	
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	182 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.62	3.33
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.20 kW	9.40 kW
COP Tj = -7°C	2.87	1.95

Cdh Tj = -7 °C		1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.33	3.27
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.70 kW	4.40 kW
COP Tj = +7°C	6.83	4.93
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.50 kW	5.30 kW
COP Tj = 12°C	8.82	6.60
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.76 kW	10.10 kW
COP Tj = Tbiv	2.48	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.76 kW	7.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.67
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	4.10 kW
Annual energy consumption Qhe	5366 kWh	7444 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	237 %	168 %
Prated	12.00 kW	12.10 kW
SCOP	5.99	4.26
Tbiv	2 °C	3 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.90 kW	9.80 kW
COP Tj = +2°C	3.30	2.17
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.10 kW	7.60 kW
COP Tj = +7°C	5.64	3.83
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.20 kW	5.00 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.00	1.00

Pdh Tj = Tbiv	11.90 kW	11.00 kW
COP Tj = Tbiv	3.30	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.30	2.17
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	2.27 kW
Annual energy consumption Qhe	2675 kWh	3792 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	14.00 kW	
SEER	5.59	
Pdc Tj = 35°C	14.00 kW	
EER Tj = 35°C	3.06	
Pdc Tj = 30°C	10.80 kW	
EER Tj = 30°C	4.41	
Cdc Tj = 30 °C	1.0	
Pdc Tj = 25°C	6.90 kW	
EER Tj = 25°C	6.56	
Cdc Tj = 25 °C	1.0	
Pdc Tj = 20°C	5.90 kW	
EER Tj = 20°C	8.51	
Cdc Tj = 20 °C	1.0	
Poff	23 W	
PTO	23 W	
PSB	23 W	
PCK	0 W	
Annual energy consumption Qce	1500 kWh	

Model EDLA16D(3)W1		
Model name	EDLA16D(3)W1	
Application	Heating (medium temp)	
Units	Outdoor	
Climate zone (for heating)	Warmer Climate	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	3x400V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.63 kW
El input	3.53 kW	5.68 kW
COP	4.53	2.75
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	4.58 kW	
Cooling capacity	14.01	
EER	3.06	
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	182 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.62	3.33
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.20 kW	9.40 kW
COP Tj = -7°C	2.87	1.95

Cdh Tj = -7 °C		1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.33	3.27
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.70 kW	4.40 kW
COP Tj = +7°C	6.83	4.93
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.50 kW	5.30 kW
COP Tj = 12°C	8.82	6.60
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.76 kW	10.10 kW
COP Tj = Tbiv	2.48	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.76 kW	7.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.67
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	4.10 kW
Annual energy consumption Qhe	5366 kWh	7444 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	237 %	168 %
Prated	12.00 kW	12.10 kW
SCOP	5.99	4.26
Tbiv	2 °C	3 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.90 kW	9.80 kW
COP Tj = +2°C	3.30	2.17
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.10 kW	7.60 kW
COP Tj = +7°C	5.64	3.83
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	5.20 kW	5.00 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.00	1.00

Pdh Tj = Tbiv	11.90 kW	11.00 kW
COP Tj = Tbiv	3.30	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.30	2.17
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	2.27 kW
Annual energy consumption Qhe	2675 kWh	3792 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	14.00 kW	
SEER	5.59	
Pdc Tj = 35°C	14.00 kW	
EER Tj = 35°C	3.06	
Pdc Tj = 30°C	10.80 kW	
EER Tj = 30°C	4.41	
Cdc Tj = 30 °C	1.0	
Pdc Tj = 25°C	6.90 kW	
EER Tj = 25°C	6.56	
Cdc Tj = 25 °C	1.0	
Pdc Tj = 20°C	5.90 kW	
EER Tj = 20°C	8.51	
Cdc Tj = 20 °C	1.0	
Poff	23 W	
PTO	23 W	
PSB	23 W	
PCK	0 W	
Annual energy consumption Qce	1500 kWh	