

Subtype Thermastage Compact Combi TCC13-16/ TOC13RIYF

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	Thermastage Compact Combi TCC13-16/ TOC13RIYF
Registration number	012-C700092
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.5 kg
Certification Date	22.12.2020
Testing basis	HP Keymark Scheme 2017

Model Compact Combi TCC13-16/ TOC13RIYF

Model name	Compact Combi TCC13-16/ TOC13RIYF
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.80 kW	9.29 kW
El input	2.51 kW	3.52 kW
COP	4.30	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	154 %	112 %
Prated	11.30 kW	9.30 kW
SCOP	3.92	2.87
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.70	1.90
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.70
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	5.90 kW

COP Tj = +7°C	5.50	3.90
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	7.10	5.20
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.00 kW	8.20 kW
COP Tj = Tbiv	2.70	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.90 kW	8.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	44 W	32 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.20 kW
Annual energy consumption Qhe	5930 kWh	6669 kWh