

Subtype 11. Yutaki S 10.0HP (tri)

Certificate Holder	Johnson Controls-Hitachi AirConditioning Spain
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella
ZIP	08233
City	Vacarisses, Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	11. Yutaki S 10.0HP (tri)
Registration number	041-K002-11
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	5 kg

Model RAS-10WHNPE RWM-10.0NE - Heating Only

Model name	RAS-10WHNPE RWM-10.0NE - Heating Only
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	24.00 kW	24.00 kW
El input	5.59 kW	9.06 kW
COP	4.29	2.65

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	74 dB(A)	74 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	141 %	116 %
Prated	20.00 kW	18.00 kW
SCOP	3.60	2.98
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	17.40 kW	15.60 kW
COP Tj = -7°C	2.30	1.65
Pdh Tj = +2°C	10.77 kW	9.50 kW
COP Tj = +2°C	3.60	3.10
Pdh Tj = +7°C	8.70 kW	8.30 kW
COP Tj = +7°C	5.10	4.35
Pdh Tj = 12°C	8.70 kW	8.50 kW
COP Tj = 12°C	4.90	4.60

Pdh Tj = Tbiv	17.40 kW	15.60 kW
COP Tj = Tbiv	2.10	1.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	18.00 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	36 W	36 W
PTO	0 W	0 W
PSB	36 W	36 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	3.60 kW
Annual energy consumption Qhe	11410 kWh	12210 kWh

Model RAS-10WHNPE RWM-10.0NE - with cooling kit

Model name	RAS-10WHNPE RWM-10.0NE - with cooling kit
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	24.00 kW	24.00 kW
El input	5.59 kW	9.06 kW
COP	4.29	2.65

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	74 dB(A)	74 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	142 %	118 %
Prated	20.00 kW	18.00 kW
SCOP	3.60	2.98
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	17.40 kW	15.60 kW
COP Tj = -7°C	2.30	1.65
Pdh Tj = +2°C	10.77 kW	9.50 kW
COP Tj = +2°C	3.60	3.10
Pdh Tj = +7°C	8.70 kW	8.30 kW
COP Tj = +7°C	5.10	4.35
Pdh Tj = 12°C	8.70 kW	8.50 kW
COP Tj = 12°C	4.90	4.60

Pdh Tj = Tbiv	17.40 kW	15.60 kW
COP Tj = Tbiv	2.10	1.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	18.00 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	36 W	36 W
PTO	0 W	0 W
PSB	36 W	36 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	3.60 kW
Annual energy consumption Qhe	11278 kWh	12078 kWh