

Subtype 21. Yutaki M 6.0HP (mono)

Certificate Holder	Johnson Controls-Hitachi AirConditioning Spain
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella
ZIP	08233
City	Vacarisses, Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	21. Yutaki M 6.0HP (mono)
Registration number	041-K002-21
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	3.1 kg

Model RASM-6VNE - Heating Only

Model name	RASM-6VNE - Heating Only
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.00 kW	16.00 kW
El input	3.50 kW	6.40 kW
COP	4.57	2.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	153 %	125 %
Prated	16.00 kW	14.00 kW
SCOP	3.90	3.20
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.80 kW	11.20 kW
COP Tj = -7°C	2.40	1.60
Pdh Tj = +2°C	8.40 kW	6.82 kW
COP Tj = +2°C	3.90	3.35
Pdh Tj = +7°C	5.40 kW	4.38 kW
COP Tj = +7°C	5.00	4.35
Pdh Tj = 12°C	3.50 kW	3.60 kW
COP Tj = 12°C	6.00	5.50
Pdh Tj = Tbiv	13.80 kW	11.20 kW

COP $T_j = T_{biv}$	2.40	1.60
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	14.10 kW	11.70 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.55
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	13 W	13 W
PTO	0 W	0 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.30 kW
Annual energy consumption Q _{he}	8287 kWh	8170 kWh

Model RASM-6VNE - with cooling kit

Model name	RASM-6VNE - with cooling kit
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.00 kW	16.00 kW
El input	3.50 kW	6.40 kW
COP	4.57	2.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	153 %	126 %
Prated	16.00 kW	14.00 kW
SCOP	3.90	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.80 kW	11.20 kW
COP Tj = -7°C	2.40	1.60
Pdh Tj = +2°C	8.40 kW	6.82 kW
COP Tj = +2°C	3.90	3.35
Pdh Tj = +7°C	5.40 kW	4.38 kW
COP Tj = +7°C	5.00	4.35
Pdh Tj = 12°C	3.50 kW	3.60 kW
COP Tj = 12°C	6.00	5.50
Pdh Tj = Tbiv	13.80 kW	11.20 kW

COP $T_j = T_{biv}$	2.40	1.60
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	14.10 kW	11.70 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.55
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	13 W	13 W
PTO	0 W	0 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.30 kW
Annual energy consumption Q _{he}	8239 kWh	8122 kWh