

Subtype DAITSU SPLIT URBAN 22 30

Certificate Holder	Eurofred S.A.
Address	Marqués de Sentmenat, 97
ZIP	08029
City	Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	DAITSU SPLIT URBAN 22 30
Registration number	041-K010-09
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.1 kg
Certification Date	08.03.2021
Testing basis	Heat Pump Keymark Scheme Rules Rev 09

Model SPLIT URBAN AOWD 22

Model name	SPLIT URBAN AOWD 22
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.11.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	123 %
COP	2.92
Heating up time	1:47 h:min
Standby power input	36.1 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	226 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	94 %
COP	2.25
Heating up time	1:58 h:min
Standby power input	38.2 W
Reference hot water temperature	53.0 °C
Mixed water at 40°C	226 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	143 %
COP	3.40
Heating up time	1:33 h:min
Standby power input	30.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	226 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	7.98 kW
El input	1.61 kW	2.60 kW
COP	4.97	3.06

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	129 %
Prated	7.00 kW	7.00 kW
SCOP	4.60	3.30
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	6.30 kW
COP Tj = -7°C	2.94	2.24
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.90 kW	4.10 kW
COP Tj = +2°C	4.39	3.18
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	3.00 kW	4.30 kW
COP Tj = +7°C	6.29	4.26
Cdh Tj = +7 °C	0.950	0.970
Pdh Tj = 12°C	3.60 kW	5.00 kW
COP Tj = 12°C	8.43	5.93
Cdh Tj = +12 °C	0.940	0.970
Pdh Tj = Tbiv	6.20 kW	6.30 kW
COP Tj = Tbiv	2.94	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.90 kW	6.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.69	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W

PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	0.70 kW
Annual energy consumption Qhe	3149 kWh	4371 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	146 %	112 %
Prated	7.00 kW	7.00 kW
SCOP	3.72	2.87
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.50 kW	4.60 kW
COP Tj = -7°C	3.26	2.64
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.26	3.24
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	4.30 kW	4.20 kW
COP Tj = +7°C	6.04	4.76
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	4.90 kW	4.70 kW
COP Tj = 12°C	7.26	5.86
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	5.80 kW	5.90 kW
COP Tj = Tbiv	2.63	1.77
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.50 kW	2.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.52	1.26
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.50 kW	4.10 kW
Annual energy consumption Qhe	4628 kWh	5982 kWh

Pdh Tj = -15°C (if TOL	5.80	5.90
COP Tj = -15°C (if TOL	2.63	1.77
Cdh Tj = -15 °C	0.990	0.990

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	217 %	159 %
Prated	8.00 kW	8.00 kW
SCOP	5.50	4.05
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.20 kW	8.10 kW
COP Tj = +2°C	3.58	2.52
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.40 kW	5.30 kW
COP Tj = +7°C	4.84	3.38
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	5.10 kW	5.20 kW
COP Tj = 12°C	7.08	5.42
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	8.20 kW	8.10 kW
COP Tj = Tbiv	3.58	2.52
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.20 kW	8.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.58	2.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1947 kWh	2645 kWh

Model SPLIT URBAN AOWD 30

Model name	SPLIT URBAN AOWD 30
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.11.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	123 %
COP	2.92
Heating up time	1:47 h:min
Standby power input	36.1 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	226 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	94 %
COP	2.25
Heating up time	1:58 h:min
Standby power input	38.2 W
Reference hot water temperature	53.0 °C
Mixed water at 40°C	226 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	143 %
COP	3.40
Heating up time	1:33 h:min
Standby power input	30.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	226 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.00 kW	9.47 kW
El input	2.10 kW	3.12 kW
COP	4.76	3.04

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	127 %
Prated	9.00 kW	8.00 kW
SCOP	4.60	3.25
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.70 kW	6.90 kW
COP Tj = -7°C	2.87	2.12
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	4.80 kW	4.20 kW
COP Tj = +2°C	4.34	3.09
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	3.10 kW	4.30 kW
COP Tj = +7°C	6.58	4.34
Cdh Tj = +7 °C	0.950	0.970
Pdh Tj = 12°C	3.70 kW	4.90 kW
COP Tj = 12°C	8.37	5.91
Cdh Tj = +12 °C	0.940	0.970
Pdh Tj = Tbiv	7.70 kW	6.90 kW
COP Tj = Tbiv	2.87	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.10 kW	6.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.75
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W

PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	1.20 kW
Annual energy consumption Qhe	4038 kWh	5091 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	149 %	110 %
Prated	8.00 kW	8.00 kW
SCOP	3.80	2.82
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.20 kW	5.30 kW
COP Tj = -7°C	3.25	2.42
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	3.20 kW	3.10 kW
COP Tj = +2°C	4.31	3.23
Cdh Tj = +2 °C	0.970	0.970
Pdh Tj = +7°C	4.30 kW	4.20 kW
COP Tj = +7°C	6.11	4.78
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	4.90 kW	4.80 kW
COP Tj = 12°C	7.30	5.91
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.40 kW	6.70 kW
COP Tj = Tbiv	2.69	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	3.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.22
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	4.70 kW
Annual energy consumption Qhe	5201 kWh	6985 kWh

Pdh Tj = -15°C (if TOL	6.40	6.70
COP Tj = -15°C (if TOL	2.69	1.83
Cdh Tj = -15 °C	0.990	0.990

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	217 %	161 %
Prated	9.00 kW	9.00 kW
SCOP	5.50	4.10
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.80 kW	9.00 kW
COP Tj = +2°C	3.15	2.48
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.80 kW	5.90 kW
COP Tj = +7°C	4.86	3.56
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	5.10 kW	5.20 kW
COP Tj = 12°C	7.18	5.30
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	8.80 kW	9.00 kW
COP Tj = Tbiv	3.15	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.80 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.48
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2183 kWh	2927 kWh