

## Subtype PACIFIC H-TECH 60 Mono Taille 11

|                     |                                                             |
|---------------------|-------------------------------------------------------------|
| Certificate Holder  | Groupe Atlantic                                             |
| Address             | 44 boulevard des Etats-Unis                                 |
| ZIP                 | 85000                                                       |
| City                | La Roche Sur Yon                                            |
| Country             | FR                                                          |
| Certification Body  | RISE CERT                                                   |
| Subtype title       | PACIFIC H-TECH 60 Mono Taille 11                            |
| Registration number | 012-C700176                                                 |
| Heat Pump Type      | Outdoor Air/Water                                           |
| Refrigerant         | R410A                                                       |
| Mass of Refrigerant | 2.5 kg                                                      |
| Certification Date  | 22.03.2023                                                  |
| Testing basis       | EN 14511:2013, EN 16147:2011, EN 14825:2013, EN 12102:2013. |

## Model PACIFIC H-TECH 60 Mono Taille 11

|                                     |                                  |
|-------------------------------------|----------------------------------|
| Model name                          | PACIFIC H-TECH 60 Mono Taille 11 |
| Application                         | Heating (medium temp)            |
| Units                               | Indoor, Outdoor                  |
| Climate zone (for heating)          | n/a                              |
| Cooling mode application (optional) | n/a                              |
| Any additional heat sources         | n/a                              |

## General data

|                  |             |
|------------------|-------------|
| Power supply     | 1x230V 50Hz |
| Off-peak product | n/a         |

## Outdoor Air/Water

## EN 14511-4 | Heating

|                                            |        |
|--------------------------------------------|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure              | passed |
| Defrost test                               | passed |
| Starting and operating test                | passed |

## EN 14511-2 | Heating

|             | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 10.80 kW        | 7.59 kW            |
| El input    | 2.54 kW         | 3.07 kW            |
| COP         | 4.25            | 2.47               |

## EN 12102-1 | Average Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 46 dB(A)        | 46 dB(A)           |
| Sound power level outdoor | 69 dB(A)        | 69 dB(A)           |

## EN 14825 | Average Climate

|                | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| $\eta_s$       | 151 %           | 112 %              |
| Prated         | 11.30 kW        | 9.30 kW            |
| SCOP           | 3.85            | 2.87               |
| Tbiv           | -7 °C           | -7 °C              |
| TOL            | -10 °C          | -10 °C             |
| Pdh Tj = -7°C  | 10.00 kW        | 8.20 kW            |
| COP Tj = -7°C  | 2.60            | 1.90               |
| Cdh Tj = -7 °C | 0.900           | 0.900              |
| Pdh Tj = +2°C  | 6.10 kW         | 5.00 kW            |
| COP Tj = +2°C  | 3.70            | 2.80               |
| Cdh Tj = +2 °C | 0.900           | 0.900              |
| Pdh Tj = +7°C  | 6.20 kW         | 5.90 kW            |

|                                                     |             |             |
|-----------------------------------------------------|-------------|-------------|
| COP Tj = +7°C                                       | 5.30        | 3.80        |
| Cdh Tj = +7 °C                                      | 0.900       | 0.900       |
| Pdh Tj = 12°C                                       | 7.40 kW     | 7.00 kW     |
| COP Tj = 12°C                                       | 6.90        | 4.80        |
| Cdh Tj = +12 °C                                     | 0.900       | 0.900       |
| Pdh Tj = Tbiv                                       | 10.00 kW    | 8.20 kW     |
| COP Tj = Tbiv                                       | 2.60        | 1.90        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 10.00 kW    | 8.00 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.20        | 1.70        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900       | 0.900       |
| WTOL                                                | 60 °C       | 60 °C       |
| Poff                                                | 8 W         | 8 W         |
| PTO                                                 | 45 W        | 22 W        |
| PSB                                                 | 12 W        | 12 W        |
| PCK                                                 | 0 W         | 0 W         |
| Supplementary Heater: Type of energy input          | Electricity | Electricity |
| Supplementary Heater: PSUP                          | 1.30 kW     | 1.30 kW     |
| Annual energy consumption Qhe                       | 6062 kWh    | 6623 kWh    |

## Model PACIFIC H-TECH 60 + Mono Taille 11

|                                     |                                    |
|-------------------------------------|------------------------------------|
| Model name                          | PACIFIC H-TECH 60 + Mono Taille 11 |
| Application                         | Heating + DHW + low temp           |
| Units                               | Indoor, Outdoor                    |
| Climate zone (for heating)          | n/a                                |
| Cooling mode application (optional) | n/a                                |
| Any additional heat sources         | n/a                                |

### General data

|                  |     |
|------------------|-----|
| Power supply     | n/a |
| Off-peak product | n/a |

### Outdoor Air/Water

#### EN 16147 | Average Climate

|                                 |            |
|---------------------------------|------------|
| Declared load profile           | L          |
| Efficiency $\eta_{DHW}$         | 88 %       |
| COP                             | 2.25       |
| Heating up time                 | 0:46 h:min |
| Standby power input             | 40.0 W     |
| Reference hot water temperature | 54.0 °C    |
| Mixed water at 40°C             | 250 l      |

#### EN 14511-4 | Heating

|                                            |        |
|--------------------------------------------|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure              | passed |
| Defrost test                               | passed |
| Starting and operating test                | passed |

#### EN 14511-2 | Heating

|             | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 10.80 kW        | 7.59 kW            |
| El input    | 2.54 kW         | 3.07 kW            |
| COP         | 4.25            | 2.47               |

#### EN 12102-1 | Average Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 46 dB(A)        | 46 dB(A)           |
| Sound power level outdoor | 69 dB(A)        | 69 dB(A)           |

#### EN 14825 | Average Climate

|          | Low temperature | Medium temperature |
|----------|-----------------|--------------------|
| $\eta_s$ | 151 %           | 112 %              |
| Prated   | 11.30 kW        | 9.30 kW            |
| SCOP     | 3.85            | 2.87               |

|                                                     |             |             |
|-----------------------------------------------------|-------------|-------------|
| Tbiv                                                | -7 °C       | -7 °C       |
| TOL                                                 | -10 °C      | -10 °C      |
| Pdh Tj = -7°C                                       | 10.00 kW    | 8.20 kW     |
| COP Tj = -7°C                                       | 2.60        | 1.90        |
| Cdh Tj = -7 °C                                      | 0.900       | 0.900       |
| Pdh Tj = +2°C                                       | 6.10 kW     | 5.00 kW     |
| COP Tj = +2°C                                       | 3.70        | 2.80        |
| Cdh Tj = +2 °C                                      | 0.900       | 0.900       |
| Pdh Tj = +7°C                                       | 6.20 kW     | 5.90 kW     |
| COP Tj = +7°C                                       | 5.30        | 3.80        |
| Cdh Tj = +7 °C                                      | 0.900       | 0.900       |
| Pdh Tj = 12°C                                       | 7.40 kW     | 7.00 kW     |
| COP Tj = 12°C                                       | 6.90        | 4.80        |
| Cdh Tj = +12 °C                                     | 0.900       | 0.900       |
| Pdh Tj = Tbiv                                       | 10.00 kW    | 8.20 kW     |
| COP Tj = Tbiv                                       | 2.60        | 1.90        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 10.00 kW    | 8.00 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.20        | 1.70        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900       | 0.900       |
| WTOL                                                | 60 °C       | 60 °C       |
| Poff                                                | 8 W         | 8 W         |
| PTO                                                 | 45 W        | 22 W        |
| PSB                                                 | 12 W        | 12 W        |
| PCK                                                 | 0 W         | 0 W         |
| Supplementary Heater: Type of energy input          | Electricity | Electricity |
| Supplementary Heater: PSUP                          | 1.30 kW     | 1.30 kW     |
| Annual energy consumption Qhe                       | 6062 kWh    | 6623 kWh    |