

Subtype Split Heat Pump 8 10 kW	
Certificate Holder	Zhejiang Zhongguang Electrical Co., Ltd.
Address	No. 96 Yunjing Road Shuige Industry Area, Lishui
ZIP	323000
City	Zhejiang
Country	CN
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Split Heat Pump 8 10 kW
Registration number	011-1W0642
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.45 kg
Certification Date	16.06.2023
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 11 (as of 2022-09)



Model Outdoor unit AHbS8VR3H/O and indo	oor unit AHbS10VR3H/IP		
Model name	Outdoor unit AHbS8VR3H/O and indoor unit AHbS10VR3H/IP		
Application	Heating (medium temp)		
Units	Indoor, Outdoor		
Climate zone (for heating)	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		
Any additional heat sources	n/a		
General data			
Power supply	1x230V 50Hz		
Off-peak product	n/a		
Outdoor Air/Water			
EN 14511-4 Heating			
Shutting off the heat transfer medium flow	passed		
Complete power supply failure	passed		
Defrost test	passed		
Starting and operating test	passed		
EN 12102-1 Average Climate			
	Low temperature	Medium temperature	
Sound power level indoor	42 dB(A)	42 dB(A)	
Sound power level outdoor	59 dB(A)	59 dB(A)	
EN 14825 Average Climate			
	Low temperature	Medium temperature	
ης	194 %	142 %	
Prated	8.22 kW	8.20 kW	
SCOP	4.92	3.61	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7° C	7.24 kW	7.22 kW	
$COP Tj = -7^{\circ}C$	2.93	2.12	
Cdh Tj = -7 °C	1.000	1.000	
$Pdh Tj = +2^{\circ}C$	4.81 kW	4.42 kW	
$COP Tj = +2^{\circ}C$	4.61	3.49	
Cdh Tj = +2 °C	1.000	1.000	
Pdh Tj = $+7^{\circ}$ C	3.16 kW	3.08 kW	
$COP Tj = +7^{\circ}C$	6.81	4.75	
Cdh Tj = +7 °C	0.990	0.990	
Pdh Tj = 12°C	3.13 kW	3.25 kW	
COP Tj = 12°C	10.98	7.61	
Cdh Tj = +12 °C	0.990	0.990	



Pdh Tj = Tbiv	7.24 kW	7.22 kW
COP Tj = Tbiv	2.93	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.79 kW	6.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.72	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	4 W	4 W
PSB	15 W	15 W
PCK	27 W	27 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.43 kW	1.29 kW
Annual energy consumption Qhe	3440 kWh	4668 kWh



Model Outdoor unit AHbS10VR3H/O and inc	loor unit AHbS10VR3H/IP		
Model name	Outdoor unit AHbS10VR3H/O and indoor unit AHbS10VR3H/IP		
Application	Heating (medium temp)		
Units	Indoor, Outdoor		
Climate zone (for heating)	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		
Any additional heat sources	n/a		
General data			
Power supply	1x230V 50Hz		
Off-peak product	n/a		
Outdoor Air/Water			
EN 14511-4 Heating			
Shutting off the heat transfer medium flow	passed		
Complete power supply failure	passed		
Defrost test	passed		
Starting and operating test	passed		
EN 12102-1 Average Climate			
	Low temperature	Medium temperature	
Sound power level indoor	42 dB(A)	42 dB(A)	
Sound power level outdoor	60 dB(A)	60 dB(A)	
EN 14825 Average Climate			
	Low temperature	Medium temperature	
ης	194 %	141 %	
Prated	8.90 kW	8.20 kW	
SCOP	4.92	3.61	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7 °C	7.89 kW	7.22 kW	
$COP Tj = -7^{\circ}C$	2.92	2.12	
Cdh Tj = -7 °C	1.000	1.000	
$Pdh Tj = +2^{\circ}C$	4.81 kW	4.42 kW	
$COP Tj = +2^{\circ}C$	4.61	3.49	
Cdh Tj = +2 °C	1.000	1.000	
Pdh Tj = $+7^{\circ}$ C	3.16 kW	3.09 kW	
$COP Tj = +7^{\circ}C$	6.82	4.75	
Cdh Tj = +7 °C	0.990	0.990	
Pdh Tj = 12°C	3.13 kW	3.25 kW	
$COP Tj = 12^{\circ}C$	11.00	7.60	
Cdh Tj = +12 °C	0.990	0.990	



Pdh Tj = Tbiv	7.89 kW	7.22 kW
COP Tj = Tbiv	2.92	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.51 kW	6.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.67	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	4 W	4 W
PSB	15 W	15 W
PCK	27 W	27 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.39 kW	1.29 kW
Annual energy consumption Qhe	3744 kWh	4671 kWh