

Subtype Alféa Extensa +16

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	Alféa Extensa +16
Registration number	012-012
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.5 kg

Model Alféa Extensa +16

Model name	Alféa Extensa +16
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.06 kW	10.03 kW
El input	4.37 kW	4.01 kW
COP	3.68	2.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	149 %	113 %
Prated	13.00 kW	11.00 kW
SCOP	3.77	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	1.90
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.60	2.80
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	3.90
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.90	5.10

Pdh Tj = Tbiv	11.10 kW	10.00 kW
COP Tj = Tbiv	2.50	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	9.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	8 W	8 W
PTO	72 W	25 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.10 kW
Annual energy consumption Qhe	6824 kWh	8041 kWh

Model Alféa Extensa A.I. 16

Model name	Alféa Extensa A.I. 16
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.06 kW	10.03 kW
El input	4.37 kW	4.01 kW
COP	3.68	2.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	149 %	113 %
Prated	13.00 kW	11.00 kW
SCOP	3.77	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	1.90
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.60	2.80
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	3.90
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.90	5.10

Pdh Tj = Tbiv	11.10 kW	10.00 kW
COP Tj = Tbiv	2.50	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	9.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	8 W	8 W
PTO	72 W	25 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.10 kW
Annual energy consumption Qhe	6824 kWh	8041 kWh