

Subtype Mono Series 12 14 16kW

Certificate Holder	Wamsler Bioenergy GmbH
Address	Adalperostrasse 86
ZIP	85737
City	Ismaning
Country	DE
Certification Body	BRE Global Limited
Subtype title	Mono Series 12 14 16kW
Registration number	041-K075-06
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.8 kg
Certification Date	16.11.2023
Testing basis	Heat Pump Keymark Scheme Rules Rev 12

Model HPM3P12KWEWA

Model name	HPM3P12KWEWA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.2 kW	12 kW
El input	2.49 kW	4 kW
COP	4.9	3

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	200.2 %	141.6 %
Prated	12.3 kW	12.5 kW
SCOP	5.08	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.85 kW	11.06 kW
COP Tj = -7°C	3.11	2.15
Cdh Tj = -7 °C	0.9	0.9
Pdh Tj = +2°C	6.79 kW	6.91 kW
COP Tj = +2°C	4.86	3.59
Cdh Tj = +2 °C	0.9	0.9
Pdh Tj = +7°C	4.79 kW	4.64 kW

COP Tj = +7°C	6.98	5.07
Cdh Tj = +7 °C	0.9	0.9
Pdh Tj = 12°C	3.73 kW	2.15 kW
COP Tj = 12°C	9.02	4.52
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	10.85 kW	11.06 kW
COP Tj = Tbiv	3.11	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.3 kW	10.97 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.8	1.98
WTOL	65 °C	65 °C
Poff	6 W	6 W
PTO	18 W	18 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	1.53 kW
Annual energy consumption Qhe	5003 kWh	7148 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	168.8 %	126 %
Prated	12.5 kW	11.3 kW
SCOP	4.3	3.23
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.08 kW	7.09 kW
COP Tj = -7°C	3.64	2.75
Cdh Tj = -7 °C	0.9	0.9
Pdh Tj = +2°C	4.93 kW	4.44 kW
COP Tj = +2°C	5.34	3.88
Cdh Tj = +2 °C	0.9	0.9
Pdh Tj = +7°C	3.17 kW	3 kW
COP Tj = +7°C	5.28	4.88
Cdh Tj = +7 °C	0.9	0.9
Pdh Tj = 12°C	3.69 kW	3.6 kW
COP Tj = 12°C	9.34	6.61
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	10.17 kW	9.21 kW
COP Tj = Tbiv	2.66	1.92

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.72 kW	7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.08	1.38
WTOL	65 °C	65 °C
Poff	6 W	6 W
PTO	18 W	18 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.78 kW	4.3 kW
Annual energy consumption Qhe	7153 kWh	8628 kWh
Pdh Tj = -15°C (if TOL	10.17	9.21
COP Tj = -15°C (if TOL	2.66	1.92
Cdh Tj = -15 °C	0.9	0.9

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	262.5 %	179 %
Prated	12.1 kW	12 kW
SCOP	6.64	4.55
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.1 kW	12 kW
COP Tj = +2°C	3.53	2.39
Cdh Tj = +2 °C	0.9	0.9
Pdh Tj = +7°C	7.78 kW	7.73 kW
COP Tj = +7°C	5.82	3.86
Cdh Tj = +7 °C	0.9	0.9
Pdh Tj = 12°C	3.64 kW	3.59 kW
COP Tj = 12°C	8.31	5.88
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.78 kW	7.73 kW
COP Tj = Tbiv	5.82	3.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.1 kW	12 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.53	2.39
WTOL	65 °C	65 °C
Poff	6 W	6 W
PTO	18 W	18 W
PSB	6 W	6 W

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Q _{he}	2435 kWh	3523 kWh

Model HPM3P16KWEWA

Model name	HPM3P16KWEWA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.00 kW	16.00 kW
El input	3.56 kW	5.61 kW
COP	4.50	2.85

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	190.5 %	140.7 %
Prated	15.20 kW	14.70 kW
SCOP	4.84	3.59
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.49 kW	13.03 kW
COP Tj = -7°C	2.87	2.16
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.59 kW	8.50 kW
COP Tj = +2°C	4.53	3.55
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.55 kW	5.27 kW

COP Tj = +7°C	7.01	5.05
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.73 kW	2.15 kW
COP Tj = 12°C	9.02	4.52
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	13.49 kW	13.03 kW
COP Tj = Tbiv	2.87	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.05 kW	12.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.94
WTOL	65.00 °C	65.00 °C
Poff	6.00 W	6.00 W
PTO	18.00 W	18.00 W
PSB	6.00 W	6.00 W
PCK	0.00 W	0.00 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.15 kW	2.63 kW
Annual energy consumption Qhe	6509 kWh	8460 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	170.9 %	124.3 %
Prated	15.10 kW	13.50 kW
SCOP	4.35	3.18
Tbiv	-15.00 °C	-15.00 °C
TOL	-22.00 °C	-22.00 °C
Pdh Tj = -7°C	9.26 kW	8.43 kW
COP Tj = -7°C	3.59	2.77
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.76 kW	5.20 kW
COP Tj = +2°C	5.35	3.74
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.76 kW	3.53 kW
COP Tj = +7°C	7.04	5.19
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.72 kW	3.61 kW
COP Tj = 12°C	8.78	6.61
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.30 kW	11.03 kW
COP Tj = Tbiv	2.58	1.85

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.43 kW	7.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.00	1.30
WTOL	65.00 °C	65.00 °C
Poff	6.00 W	6.00 W
PTO	18.00 W	18.00 W
PSB	6.00 W	6.00 W
PCK	0.00 W	0.00 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.67 kW	5.98 kW
Annual energy consumption Qhe	8546 kWh	10473 kWh
Pdh Tj = -15°C (if TOL	12.30	11.03
COP Tj = -15°C (if TOL	2.58	1.85
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	255.5 %	184 %
Prated	14.20 kW	14.50 kW
SCOP	6.46	4.68
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	14.20 kW	13.62 kW
COP Tj = +2°C	3.22	2.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	9.15 kW	9.35 kW
COP Tj = +7°C	5.41	3.94
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.24 kW	4.26 kW
COP Tj = 12°C	8.56	6.37
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.15 kW	9.35 kW
COP Tj = Tbiv	5.41	3.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.20 kW	13.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.22	2.35
WTOL	65.00 °C	65.00 °C
Poff	6.00 W	13.00 W
PTO	18.00 W	20.00 W
PSB	6.00 W	13.00 W

PCK	0.00 W	0.00 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.91 kW
Annual energy consumption Qhe	2935 kWh	4153 kWh