

Subtype ThermaX R290 12/15KW

Certificate Holder	GD Shenling Thermal Tech Co., Ltd
Address	No.29 Shunye East Rd.
ZIP	528325
City	Foshan
Country	CN
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	ThermaX R290 12/15KW
Registration number	011-1W0744
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.4 kg
Certification Date	29.11.2023
Testing basis	European KEYMARK Scheme for Heat Pumps Version 12 (2023-03)

Model HPM-V120W/R3

Model name	HPM-V120W/R3
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.00 kW
COP	4.75	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	193 %	148 %
Prated	12.20 kW	12.10 kW
SCOP	4.90	3.77
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.07 kW	10.73 kW
COP Tj = -7°C	2.90	2.20
Cdh Tj = -7 °C	0.995	0.996
Pdh Tj = +2°C	6.52 kW	6.43 kW
COP Tj = +2°C	4.52	3.58
Cdh Tj = +2 °C	0.987	0.989
Pdh Tj = +7°C	4.26 kW	4.24 kW

COP Tj = +7°C	7.19	5.34
Cdh Tj = +7 °C	0.968	0.976
Pdh Tj = 12°C	2.78 kW	2.56 kW
COP Tj = 12°C	10.18	6.76
Cdh Tj = +12 °C	0.930	0.950
Pdh Tj = Tbiv	11.07 kW	10.73 kW
COP Tj = Tbiv	2.90	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.55 kW	10.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	2.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.995	0.996
WTOL	75 °C	75 °C
Poff	12 W	12 W
PTO	19 W	19 W
PSB	12 W	12 W
PCK	2 W	2 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.60 kW
Annual energy consumption Qhe	5141 kWh	6639 kWh

Model HPM-V150W/R3

Model name	HPM-V150W/R3
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	15.00 kW	15.00 kW
El input	3.33 kW	5.26 kW
COP	4.50	2.85

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	186 %	146 %
Prated	14.00 kW	14.00 kW
SCOP	4.73	3.73
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.53 kW	12.47 kW
COP Tj = -7°C	2.74	2.10
Cdh Tj = -7 °C	0.996	0.997
Pdh Tj = +2°C	7.58 kW	7.67 kW
COP Tj = +2°C	4.37	3.55
Cdh Tj = +2 °C	0.989	0.991
Pdh Tj = +7°C	4.83 kW	4.81 kW

COP Tj = +7°C	7.04	5.39
Cdh Tj = +7 °C	0.972	0.979
Pdh Tj = 12°C	2.78 kW	2.56 kW
COP Tj = 12°C	10.18	6.76
Cdh Tj = +12 °C	0.930	0.950
Pdh Tj = Tbiv	12.53 kW	12.47 kW
COP Tj = Tbiv	2.74	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.55 kW	12.12 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.995	0.997
WTOL	75 °C	75 °C
Poff	12 W	12 W
PTO	19 W	19 W
PSB	12 W	12 W
PCK	2 W	2 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.40 kW	1.90 kW
Annual energy consumption Qhe	6115 kWh	7763 kWh

Model HPM-V120W/SR3

Model name	HPM-V120W/SR3
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.00 kW
COP	4.75	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	192 %	148 %
Prated	12.20 kW	12.10 kW
SCOP	4.88	3.76
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.22 kW	11.18 kW
COP Tj = -7°C	2.79	2.21
Cdh Tj = -7 °C	0.997	0.997
Pdh Tj = +2°C	6.67 kW	6.45 kW
COP Tj = +2°C	4.57	3.58
Cdh Tj = +2 °C	0.991	0.993
Pdh Tj = +7°C	4.23 kW	4.18 kW

COP Tj = +7°C	7.10	5.17
Cdh Tj = +7 °C	0.978	0.984
Pdh Tj = 12°C	2.77 kW	2.71 kW
COP Tj = 12°C	10.01	7.54
Cdh Tj = +12 °C	0.953	0.964
Pdh Tj = Tbiv	11.22 kW	11.18 kW
COP Tj = Tbiv	2.79	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.57 kW	10.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.61	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.997	0.997
WTOL	75 °C	75 °C
Poff	12 W	12 W
PTO	13 W	13 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.90 kW
Annual energy consumption Qhe	5168 kWh	6642 kWh

Model HPM-V150W/SR3

Model name	HPM-V150W/SR3
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	15.00 kW	15.00 kW
El input	3.33 kW	5.26 kW
COP	4.50	2.85

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	187 %	145 %
Prated	14.00 kW	14.00 kW
SCOP	4.74	3.69
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.39 kW	12.85 kW
COP Tj = -7°C	2.68	2.10
Cdh Tj = -7 °C	0.997	0.998
Pdh Tj = +2°C	7.55 kW	7.54 kW
COP Tj = +2°C	4.45	3.49
Cdh Tj = +2 °C	0.992	0.994
Pdh Tj = +7°C	4.83 kW	4.78 kW

COP Tj = +7°C	6.93	5.25
Cdh Tj = +7 °C	0.981	0.986
Pdh Tj = 12°C	2.77 kW	2.71 kW
COP Tj = 12°C	10.01	7.54
Cdh Tj = +12 °C	0.953	0.964
Pdh Tj = Tbiv	12.39 kW	12.85 kW
COP Tj = Tbiv	2.68	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.54 kW	11.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.997	0.998
WTOL	75 °C	75 °C
Poff	12 W	12 W
PTO	13 W	13 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.50 kW	2.20 kW
Annual energy consumption Qhe	6097 kWh	7837 kWh