

Subtype Alféa Extensa M DUO XL 8

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	Alféa Extensa M DUO XL 8
Registration number	012-C700269
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.47 kg
Certification Date	05.04.2024
Testing basis	EN 14511:2022, EN 14825:2022, EN 16147:2017+A1:2022, EN 12102:2022

Model Alféa Extensa M DUO XL 8

Model name	Alféa Extensa M DUO XL 8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	128 %
COP	3.20
Heating up time	1:35 h:min
Standby power input	45.0 W
Reference hot water temperature	55.0 °C
Mixed water at 40°C	300 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.57 kW	2.62 kW
COP	5.08	3.05

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	139 %
Prated	9.00 kW	8.70 kW
SCOP	4.94	3.54

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.00 kW	7.70 kW
COP Tj = -7°C	3.19	2.26
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	4.80 kW	4.70 kW
COP Tj = +2°C	4.90	3.40
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	3.90 kW	3.70 kW
COP Tj = +7°C	6.54	4.83
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	4.50 kW	4.40 kW
COP Tj = 12°C	8.45	6.45
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	8.00 kW	7.70 kW
COP Tj = Tbiv	3.19	2.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.90 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.79	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	23 W	23 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	1.30 kW
Annual energy consumption Qhe	3764 kWh	5078 kWh