

Subtype THERMOR ALFEA EXTENSA A.I. 13 2024

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	THERMOR ALFEA EXTENSA A.I. 13 2024
Registration number	012-C700286
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.5 kg
Certification Date	16.04.2024
Testing basis	EN 14511:2022, EN 14825:2022, EN 12102:2022

Model THERMOR ALFEA EXTENSA AI 13 2024

Model name	THERMOR ALFEA EXTENSA AI 13 2024
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.80 kW	8.40 kW
El input	2.51 kW	3.31 kW
COP	4.30	2.54

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	157 %	118 %
Prated	11.00 kW	9.40 kW
SCOP	4.00	3.03
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	8.30 kW
COP Tj = -7°C	2.60	1.97
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	5.90 kW	5.10 kW
COP Tj = +2°C	3.78	2.95
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.10 kW	5.80 kW

COP Tj = +7°C	5.47	3.97
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.99	5.18
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.70 kW	8.30 kW
COP Tj = Tbiv	2.60	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.39	1.59
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	16 W	16 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.10 kW
Annual energy consumption Qhe	5675 kWh	6409 kWh