

Subtype DAIKIN ALTHERMA H HYBRID GAS 4KW

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA H HYBRID GAS 4KW
Registration number	011-1W0293
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	0.56 kg

Model EJHA04AV3 / EHY2KOMB28A

Model name	EJHA04AV3 / EHY2KOMB28A
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.83 kW	3.28 kW
El input	0.85 kW	1.29 kW
COP	4.49	2.56

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	163 %	128 %
Prated	5.20 kW	5.60 kW
SCOP	4.14	3.26
Tbiv	2 °C	2 °C
TOL	-5 °C	-3 °C
Pdh Tj = -7°C	0.01 kW	0.01 kW
COP Tj = -7°C	1.00	1.00
Pdh Tj = +2°C	2.80 kW	3.00 kW
COP Tj = +2°C	4.31	3.19
Pdh Tj = +7°C	3.40 kW	3.20 kW
COP Tj = +7°C	5.78	4.52
Pdh Tj = 12°C	3.90 kW	3.90 kW
COP Tj = 12°C	8.02	6.42

Pdh Tj = Tbiv	2.80 kW	3.00 kW
COP Tj = Tbiv	4.31	3.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.00 kW	2.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.49
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	33 °C	48 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.20 kW	5.60 kW
Annual energy consumption Qhe	2595 kWh	3524 kWh

Model EJHA04AV3 / EHY2KOMB32A

Model name	EJHA04AV3 / EHY2KOMB32A
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.83 kW	3.28 kW
El input	0.85 kW	1.29 kW
COP	4.49	2.56

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	163 %	128 %
Prated	5.20 kW	5.60 kW
SCOP	4.15	3.28
Tbiv	2 °C	2 °C
TOL	-5 °C	-3 °C
Pdh Tj = -7°C	0.01 kW	0.01 kW
COP Tj = -7°C	1.00	1.00
Pdh Tj = +2°C	2.80 kW	3.00 kW
COP Tj = +2°C	4.31	3.19
Pdh Tj = +7°C	3.40 kW	3.20 kW
COP Tj = +7°C	5.78	4.52
Pdh Tj = 12°C	3.90 kW	3.90 kW
COP Tj = 12°C	8.02	6.42

Pdh Tj = Tbiv	2.80 kW	3.00 kW
COP Tj = Tbiv	4.31	3.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.00 kW	2.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.49
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	33 °C	48 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.20 kW	5.60 kW
Annual energy consumption Qhe	2588 kWh	3511 kWh

Model EJHA04AV3 / NHY2KOMB28A

Model name	EJHA04AV3 / NHY2KOMB28A
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.83 kW	3.28 kW
El input	0.85 kW	1.29 kW
COP	4.49	2.56

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	163 %	128 %
Prated	5.20 kW	5.60 kW
SCOP	4.14	3.26
Tbiv	2 °C	2 °C
TOL	-5 °C	-3 °C
Pdh Tj = -7°C	0.01 kW	0.01 kW
COP Tj = -7°C	1.00	1.00
Pdh Tj = +2°C	2.80 kW	3.00 kW
COP Tj = +2°C	4.31	3.19
Pdh Tj = +7°C	3.40 kW	3.20 kW
COP Tj = +7°C	5.78	4.52
Pdh Tj = 12°C	3.90 kW	3.90 kW
COP Tj = 12°C	8.02	6.42

Pdh Tj = Tbiv	2.80 kW	3.00 kW
COP Tj = Tbiv	4.31	3.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.00 kW	2.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.49
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	33 °C	48 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.20 kW	5.60 kW
Annual energy consumption Qhe	2595 kWh	3524 kWh

Model EJHA04AV3 / NHY2KOMB32A

Model name	EJHA04AV3 / NHY2KOMB32A
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.83 kW	3.28 kW
El input	0.85 kW	1.29 kW
COP	4.49	2.56

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	163 %	128 %
Prated	5.20 kW	5.60 kW
SCOP	4.15	3.28
Tbiv	2 °C	2 °C
TOL	-5 °C	-3 °C
Pdh Tj = -7°C	0.01 kW	0.01 kW
COP Tj = -7°C	1.00	1.00
Pdh Tj = +2°C	2.80 kW	3.00 kW
COP Tj = +2°C	4.31	3.19
Pdh Tj = +7°C	3.40 kW	3.20 kW
COP Tj = +7°C	5.78	4.52
Pdh Tj = 12°C	3.90 kW	3.90 kW
COP Tj = 12°C	8.02	6.42

Pdh Tj = Tbiv	2.80 kW	3.00 kW
COP Tj = Tbiv	4.31	3.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.00 kW	2.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.49
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	33 °C	48 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.20 kW	5.60 kW
Annual energy consumption Qhe	2588 kWh	3511 kWh