

Subtype: OCHSNER SWK

Summary of	OCHSNER SWK	Reg. No.	012-C700000
Certificate Holder			
Name	OCHSNER Energie Technik GmbH		
Address	Krackowizerstraße 4	Zip	4020
City	Linz	Country	Austria
Certification Body	RISE CERT		
Subtype title	OCHSNER SWK		
Heat Pump Type	Brine/Water and Water/Water		
Refrigerant	R410A		
Mass of Refrigerant	0.95 kg		
Certification Date	11.12.2019		
Testing basis	EN14511:2018;EN14825:2016;EN12102:2017		

Model: OCHSNER SWK007P8d

Configure model

Model name	OCHSNER SWK007P8d
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Brine/Water Heat Pump

Heating

EN 14511-4

Starting and operating test	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2

	Low temperature	Medium temperature
El input	0.96 kW	1.74 kW
COP	4.65	2.90

Average Climate

This information was generated by the HP KEYMARK database on 27 Apr 2024

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	32 dB(A)	32 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	214 %	150 %
Prated	7.11 kW	6.39 kW
SCOP	5.56	3.96
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.29 kW	5.65 kW
COP Tj = -7°C	4.85	3.09
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	3.83 kW	3.44 kW
COP Tj = +2°C	5.70	4.03
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	2.46 kW	2.21 kW
COP Tj = +7°C	6.15	4.55
Cdh Tj = +7 °C	0.96	0.97
Pdh Tj = 12°C	2.16 kW	2.07 kW

This information was generated by the HP KEYMARK database on 27 Apr 2024

COP Tj = 12°C	6.01	4.54
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	7.11 kW	6.39 kW
COP Tj = Tbiv	4.43	2.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.11 kW	6.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.43	2.81
WTOL	65 °C	65 °C
Poff	12 W	10 W
PTO	15 W	13 W
PSB	15 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2597 kWh	3291 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	223 %	157 %
Prated	7.11 kW	6.39 kW
SCOP	5.77	4.12

This information was generated by the HP KEYMARK database on 27 Apr 2024

Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.30 kW	3.87 kW
COP Tj = -7°C	5.67	3.84
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	2.62 kW	2.35 kW
COP Tj = +2°C	6.21	4.51
Cdh Tj = +2 °C	0.97	0.98
Pdh Tj = +7°C	2.17 kW	2.07 kW
COP Tj = +7°C	6.09	4.65
Cdh Tj = +7 °C	0.96	0.97
Pdh Tj = 12°C	2.15 kW	2.09 kW
COP Tj = 12°C	5.84	4.54
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	7.11 kW	6.39 kW
COP Tj = Tbiv	4.43	2.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.11 kW	6.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.43	2.81
WTOL	65 °C	65 °C
Poff	12 W	10 W
PTO	15 W	13 W

This information was generated by the HP KEYMARK database on 27 Apr 2024

PSB	15 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	3008 kWh	3802 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	5.80	5.21
COP T _j = -15°C (if TOL<-20°C)	5.05	3.33
C _{dh} T _j = -15 °C	0.99	0.99

Water/Water Heat Pump

Heating

EN 14511-4	
Starting and operating test	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
El input	1.58 kW	2.35 kW
COP	5.96	3.63

Average Climate

This information was generated by the HP KEYMARK database on 27 Apr 2024

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	32 dB(A)	32 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	305 %	211 %
Prated	9.43 kW	8.51 kW
SCOP	7.82	5.47
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.34 kW	7.53 kW
COP Tj = -7°C	6.48	4.03
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	5.08 kW	4.58 kW
COP Tj = +2°C	7.93	5.47
Cdh Tj = +2 °C	0.99	1.00
Pdh Tj = +7°C	3.26 kW	2.95 kW
COP Tj = +7°C	8.76	6.55
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	2.91 kW	2.78 kW

This information was generated by the HP KEYMARK database on 27 Apr 2024

COP Tj = 12°C	8.65	6.84
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	9.43 kW	8.51 kW
COP Tj = Tbiv	5.96	3.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.43 kW	8.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.96	3.63
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	4 W	4 W
PSB	4 W	4 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2463 kWh	3186 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	317 %	219 %
Prated	9.43 kW	8.51 kW
SCOP	8.12	5.68

This information was generated by the HP KEYMARK database on 27 Apr 2024

Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.71 kW	5.15 kW
COP Tj = -7°C	7.77	5.12
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.47 kW	3.14 kW
COP Tj = +2°C	8.76	6.31
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	2.91 kW	2.78 kW
COP Tj = +7°C	8.76	6.85
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	2.89 kW	2.79 kW
COP Tj = 12°C	8.39	7.06
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	9.43 kW	8.51 kW
COP Tj = Tbiv	5.96	3.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.43 kW	8.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.96	3.63
WTOL	65 °C	65 °C
Poff	8 W	8 W
PTO	4 W	4 W

This information was generated by the HP KEYMARK database on 27 Apr 2024

PSB	4 W	4 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2847 kWh	3676 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	7.69	6.94
COP T _j = -15°C (if TOL<-20°C)	6.87	4.37
C _{dh} T _j = -15 °C	1.00	1.00