

Subtype ecoAIR 3-18 PRO

Certificate Holder	Ecoforest Geotermia S.L.
Address	Rúa das Pontes, 25
ZIP	36350
City	Nigrán (Pontevedra)
Country	ES
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	ecoAIR 3-18 PRO
Registration number	011-1W0442
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.37 kg
Certification Date	22.11.2021
Testing basis	Europäisches Zertifizierungsprogramm Wärmepumpen KEYMARK Version8 (Stand: 2020-09)

Model ecoAIR T 3-18 PRO

Model name	ecoAIR T 3-18 PRO
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	175 %	138 %
Prated	10.60 kW	10.50 kW
SCOP	4.46	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.44 kW	9.26 kW
COP Tj = -7°C	3.30	2.40
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	5.76 kW	5.63 kW
COP Tj = +2°C	3.97	3.13
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.56 kW	6.18 kW
COP Tj = +7°C	6.27	5.18
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.25 kW	6.14 kW
COP Tj = 12°C	7.00	6.65
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	10.55 kW	10.47 kW

COP Tj = Tbiv	3.14	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.55 kW	10.47 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.14	2.22
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4914 kWh	6144 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	145 %	124 %
Prated	10.00 kW	10.00 kW
SCOP	3.70	3.16
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	5.95 kW	6.04 kW
COP Tj = -7°C	3.73	3.16
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	4.47 kW	4.64 kW
COP Tj = +2°C	4.26	3.47
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	7.64 kW	6.48 kW
COP Tj = +7°C	6.50	5.65
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.80 kW	6.46 kW
COP Tj = 12°C	7.22	6.96
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	8.16 kW	8.15 kW
COP Tj = Tbiv	3.11	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.16 kW	8.15 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.11	2.40

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	10.00 kW	10.00 kW
Annual energy consumption Qhe	6661 kWh	7795 kWh
Pdh Tj = -15°C (if TOL		
COP Tj = -15°C (if TOL		
Cdh Tj = -15 °C		

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	236 %	188 %
Prated	11.70 kW	11.00 kW
SCOP	5.98	4.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.69 kW	10.96 kW
COP Tj = +2°C	3.04	2.19
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	8.22 kW	7.47 kW
COP Tj = +7°C	5.70	4.25
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.99 kW	7.27 kW
COP Tj = 12°C	7.27	6.27
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	11.69 kW	10.96 kW
COP Tj = Tbiv	3.04	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.69 kW	10.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	2.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W

PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2613 kWh	3079 kWh

Model ecoAIR 3-18 PRO

Model name	ecoAIR 3-18 PRO
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	175 %	138 %
Prated	10.60 kW	10.50 kW
SCOP	4.46	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.44 kW	9.26 kW
COP Tj = -7°C	3.30	2.40
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	5.76 kW	5.63 kW
COP Tj = +2°C	3.97	3.13
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.56 kW	6.18 kW
COP Tj = +7°C	6.27	5.18
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.25 kW	6.14 kW
COP Tj = 12°C	7.00	6.65
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	10.55 kW	10.47 kW

COP Tj = Tbiv	3.14	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.55 kW	10.47 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.14	2.22
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4914 kWh	6144 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	145 %	124 %
Prated	10.00 kW	10.00 kW
SCOP	3.70	3.16
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	5.95 kW	6.04 kW
COP Tj = -7°C	3.73	3.16
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	4.47 kW	4.64 kW
COP Tj = +2°C	4.26	3.47
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	7.64 kW	6.48 kW
COP Tj = +7°C	6.50	5.65
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.80 kW	6.46 kW
COP Tj = 12°C	7.22	6.96
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	8.16 kW	8.15 kW
COP Tj = Tbiv	3.11	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.16 kW	8.15 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.11	2.40

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	10.00 kW	10.00 kW
Annual energy consumption Qhe	6661 kWh	7795 kWh
Pdh Tj = -15°C (if TOL		
COP Tj = -15°C (if TOL		
Cdh Tj = -15 °C		

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	236 %	188 %
Prated	11.70 kW	11.00 kW
SCOP	5.98	4.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.69 kW	10.96 kW
COP Tj = +2°C	3.04	2.19
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	8.22 kW	7.47 kW
COP Tj = +7°C	5.70	4.25
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.99 kW	7.27 kW
COP Tj = 12°C	7.27	6.27
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	11.69 kW	10.96 kW
COP Tj = Tbiv	3.04	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.69 kW	10.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	2.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W

PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2613 kWh	3079 kWh