

## Subtype i-HPV5H 0250

Certificate Holder	Advantix S.p.A.
Address	Via San Giuseppe Lavoratore, 24
ZIP	37040
City	Arcole Verona
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	i-HPV5H 0250
Registration number	ICIM-PDC-000134
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	8.5 kg
Certification Date	25.02.2022
Testing basis	Heat Pump KEYMARK V9

## Model i-HPV5H 0250

Model name	i-HPV5H 0250
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	75 dB(A)	75 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	163 %	122 %
Prated	44.00 kW	44.00 kW
SCOP	4.16	3.11
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	39.30 kW	39.20 kW
COP Tj = -7°C	2.22	1.55
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	24.90 kW	23.80 kW
COP Tj = +2°C	4.25	3.06
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	24.70 kW	23.70 kW
COP Tj = +7°C	5.55	4.48
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	28.50 kW	27.70 kW
COP Tj = 12°C	7.22	7.10
Cdh Tj = +12 °C	1.000	1.000
Pdh Tj = Tbiv	39.30 kW	39.20 kW
COP Tj = Tbiv	2.22	1.55

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	34.00 kW	34.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.91	1.25
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	58 °C	58 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	76 W	76 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	10.00 kW	9.40 kW
Annual energy consumption Qhe	22063 kWh	29398 kWh