

This information was generated by the HP KEYMARK database on 3 Apr 2023

Summary of	Samsung EHS LNHT 12/14kW (200L)	Reg. No.	011-1W0552
Certificate Holder			
Name	Samsung Electronics Air Conditioner Europe B.V.		
Address	Evert van de Beekstraat 310	ZIP	1118 CX
City	Schiphol	Country	Netherlands
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Samsung EHS LNHT 12/14kW (200L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3.3 kg		
Certification Date	27.09.2022		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 10 (as of 2022-06)		

Model: AE120BXYDEG/EU & AE200RNWMEG/EU

Configure model	
Model name	AE120BXYDEG/EU & AE200RNWMEG/EU
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.35 kW	3.53 kW
COP	5.11	3.40

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 3 Apr 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	193 %	148 %
Prated	12.60 kW	12.60 kW
SCOP	4.90	3.78
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.15 kW	11.15 kW
COP Tj = -7°C	3.10	2.30
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.80 kW	6.80 kW
COP Tj = +2°C	4.70	3.70
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.70 kW	4.70 kW
COP Tj = +7°C	6.60	5.00
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 3 Apr 2023

Pdh Tj = 12°C	4.70 kW	4.70 kW
COP Tj = 12°C	8.60	6.30
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.15 kW	11.15 kW
COP Tj = Tbiv	3.10	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.30 kW	12.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	2.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.30 kW	0.30 kW
Annual energy consumption Qhe	5277 kWh	6862 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 3 Apr 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.60
Heating up time	0:54 h:min
Standby power input	65.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	206 l

Model: AE140BXYDEG/EU & AE200RNWMEG/EU

Configure model	
Model name	AE140BXYDEG/EU & AE200RNWMEG/EU
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.00 kW	14.00 kW
El input	2.77 kW	4.18 kW
COP	5.05	3.35

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 3 Apr 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	190 %	147 %
Prated	13.60 kW	13.60 kW
SCOP	4.83	3.75
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.03 kW	12.03 kW
COP Tj = -7°C	2.90	2.28
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	7.32 kW	7.30 kW
COP Tj = +2°C	4.65	3.65
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.80 kW	4.80 kW
COP Tj = +7°C	6.60	5.00
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 3 Apr 2023

Pdh Tj = 12°C	4.80 kW	4.80 kW
COP Tj = 12°C	8.60	6.28
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.03 kW	12.00 kW
COP Tj = Tbiv	2.90	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.30 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.30 kW	0.30 kW
Annual energy consumption Qhe	5796 kWh	7472 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 3 Apr 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.60
Heating up time	0:54 h:min
Standby power input	65.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	206 l