

## Subtype Hydrodan 10

Certificate Holder	Mitsubishi Electric Air Conditioning Systems Europe LTD
Address	Nettlehill Road, Houston Industrial Estate
ZIP	EH54 5EQ
City	Livingston
Country	GB
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
Subtype title	Hydrodan 10
Registration number	037-0101-22
Heat Pump Type	Water/Water
Refrigerant	R32
Mass of Refrigerant	0.9 kg
Certification Date	03.11.2022
Testing basis	HP Keymark scheme rules rev. no. 9

## Model EHWT17D-MHEDW

Model name	EHWT17D-MHEDW
Application	Heating + DHW + low temp
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	Water
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Water/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	171 %
COP	3.9
Heating up time	2:12 h:min
Standby power input	29 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l