

Subtype Platinum BC Mural iR32 4-6 & Platinum BC Integra iR32 4-6	
Certificate Holder	BAXI Climatización S.L.U
Address	López de Hoyos 35
ZIP	28002
City	Madrid
Country	ES
Certification Body	ECC Eurovent Certita Certification
Subtype title	Platinum BC Mural iR32 4-6 & Platinum BC Integra iR32 4-6
Registration number	24.03.023
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	25.03.2024
Testing basis	EN 14511: 2018 / EN 14825: 2018 / EN 16147: 2017 / EN 12102-1: 2017

**Model Platinum BC Integra 4 iR32**

Model name	Platinum BC Integra 4 iR32
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

**General data**

Power supply	1x230V 50Hz
Off-peak product	n/a

**Outdoor Air/Water****EN 16147 | Average Climate**

Declared load profile	L
Efficiency $\eta_{DHW}$	135 %
COP	3.25
Heating up time	1:30 h:min
Standby power input	27.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	249 l

**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

**EN 14511-2 | Heating**

	Low temperature	Medium temperature
Heat output	4.25 kW	4.40 kW
El input	0.82 kW	1.49 kW
COP	5.20	2.95

**EN 14511-2 | Cooling**

	+7°C/+12°C	+18°C/+23°C
El input	4.76 kW	4.64 kW
Cooling capacity	1.32	0.84
EER	3.60	5.50

**EN 12102-1 | Average Climate**

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)

Sound power level outdoor	52 dB(A)	52 dB(A)
EN 14825   Average Climate		
	Low temperature	Medium temperature
$\eta_s$	193 %	132 %
Prated	5.52 kW	4.40 kW
SCOP	4.90	3.38
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.88 kW	3.89 kW
COP Tj = -7°C	3.19	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.06 kW	2.38 kW
COP Tj = +2°C	4.78	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.94 kW	1.56 kW
COP Tj = +7°C	6.40	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.48 kW	1.32 kW
COP Tj = 12°C	8.05	5.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.88 kW	3.89 kW
COP Tj = Tbiv	3.19	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	3.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.11 kW	0.98 kW
Annual energy consumption Qhe	2326 kWh	2686 kWh
EN 14825   Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	4.76 kW	4.64 kW
SEER	4.44	8.25
Pdc Tj = 35°C	4.76 kW	4.64 kW
EER Tj = 35°C	3.60	5.50
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	3.44 kW	3.38 kW

EER Tj = 30°C	4.55	7.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	2.19 kW	2.09 kW
EER Tj = 25°C	5.12	8.95
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	0.95 kW	1.16 kW
EER Tj = 20°C	4.29	13.20
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W
PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	643 kWh	337 kWh

## Model Platinum BC Integra 6 iR32

Model name	Platinum BC Integra 6 iR32
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	135 %
COP	3.25
Heating up time	1:30 h:min
Standby power input	27.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	249 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.20 kW	6.00 kW
El input	1.24 kW	2.00 kW
COP	5.00	3.00

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	7.18 kW	6.70 kW
Cooling capacity	2.39	1.35
EER	3.01	4.95

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)

Sound power level outdoor	52 dB(A)	52 dB(A)
EN 14825   Average Climate		
	Low temperature	Medium temperature
$\eta_s$	195 %	138 %
Prated	6.82 kW	5.70 kW
SCOP	4.95	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.03 kW	5.05 kW
COP Tj = -7°C	3.09	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.88 kW	3.12 kW
COP Tj = +2°C	4.85	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.40 kW	2.09 kW
COP Tj = +7°C	6.63	4.54
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.39 kW	1.28 kW
COP Tj = 12°C	7.83	5.59
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.03 kW	5.05 kW
COP Tj = Tbiv	3.09	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.36 kW	4.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.18 kW
Annual energy consumption Qhe	2846 kWh	3341 kWh
EN 14825   Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.18 kW	6.70 kW
SEER	4.75	8.44
Pdc Tj = 35°C	7.18 kW	6.70 kW
EER Tj = 35°C	3.01	4.95
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	5.21 kW	4.93 kW

EER Tj = 30°C	4.47	7.22
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.42 kW	3.51 kW
EER Tj = 25°C	5.21	9.45
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	1.51 kW	1.43 kW
EER Tj = 20°C	5.68	12.89
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W
PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	907 kWh	477 kWh

**Model Platinum BC Mural 4 iR32**

Model name	Platinum BC Mural 4 iR32
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

**General data**

Power supply	1x230V 50Hz
Off-peak product	n/a

**Outdoor Air/Water****EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

**EN 14511-2 | Heating**

	Low temperature	Medium temperature
Heat output	4.25 kW	4.40 kW
El input	0.82 kW	1.49 kW
COP	5.20	2.95

**EN 14511-2 | Cooling**

	+7°C/+12°C	+18°C/+23°C
El input	4.76 kW	4.64 kW
Cooling capacity	1.32	0.84
EER	3.60	5.50

**EN 12102-1 | Average Climate**

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

**EN 14825 | Average Climate**

	Low temperature	Medium temperature
$\eta_s$	193 %	132 %
Prated	5.52 kW	4.40 kW
SCOP	4.90	3.38
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C



Pdh Tj = -7°C	4.88 kW	3.89 kW
COP Tj = -7°C	3.19	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.06 kW	2.38 kW
COP Tj = +2°C	4.78	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.94 kW	1.56 kW
COP Tj = +7°C	6.40	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.48 kW	1.32 kW
COP Tj = 12°C	8.05	5.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.88 kW	3.89 kW
COP Tj = Tbiv	3.19	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	3.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.11 kW	0.98 kW
Annual energy consumption Qhe	2326 kWh	2686 kWh

## EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	4.76 kW	4.64 kW
SEER	4.44	8.25
Pdc Tj = 35°C	4.76 kW	4.64 kW
EER Tj = 35°C	3.60	5.50
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	3.44 kW	3.38 kW
EER Tj = 30°C	4.55	7.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	2.19 kW	2.09 kW
EER Tj = 25°C	5.12	8.95
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	0.95 kW	1.16 kW
EER Tj = 20°C	4.29	13.20
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W

PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	643 kWh	337 kWh

## Model Platinum BC Mural 6 iR32

Model name	Platinum BC Mural 6 iR32
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.20 kW	6.00 kW
El input	1.24 kW	2.00 kW
COP	5.00	3.00

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	7.18 kW	6.70 kW
Cooling capacity	2.39	1.35
EER	3.01	4.95

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	195 %	138 %
Prated	6.82 kW	5.70 kW
SCOP	4.95	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	6.03 kW	5.05 kW
COP Tj = -7°C	3.09	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.88 kW	3.12 kW
COP Tj = +2°C	4.85	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.40 kW	2.09 kW
COP Tj = +7°C	6.63	4.54
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.39 kW	1.28 kW
COP Tj = 12°C	7.83	5.59
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.03 kW	5.05 kW
COP Tj = Tbiv	3.09	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.36 kW	4.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.18 kW
Annual energy consumption Qhe	2846 kWh	3341 kWh

## EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.18 kW	6.70 kW
SEER	4.75	8.44
Pdc Tj = 35°C	7.18 kW	6.70 kW
EER Tj = 35°C	3.01	4.95
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	5.21 kW	4.93 kW
EER Tj = 30°C	4.47	7.22
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.42 kW	3.51 kW
EER Tj = 25°C	5.21	9.45
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	1.51 kW	1.43 kW
EER Tj = 20°C	5.68	12.89
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W

PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	907 kWh	477 kWh