

Subtype CARRIER 30AWH004HP-C--C-

Certificate Holder	Riello S.p.A.
Address	Via Ing. Pilade Riello 7
ZIP	37045
City	Legnago (VR)
Country	IT
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	CARRIER 30AWH004HP-C--C-
Registration number	011-1W0621
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	0.39 kg
Certification Date	26.06.2023
Testing basis	HP KEYMARK Certification Scheme Rules Rev. 12

Model CARRIER 30AWH004HP-C--C-

Model name	CARRIER 30AWH004HP-C--C-
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	47 dB(A)	49 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	185 %	131 %
Prated	3.80 kW	3.46 kW
SCOP	4.70	3.34
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.36 kW	3.06 kW
COP Tj = -7°C	2.86	1.97
Cdh Tj = -7 °C		
Pdh Tj = +2°C	2.05 kW	1.86 kW
COP Tj = +2°C	4.46	3.15
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.62 kW	1.52 kW
COP Tj = +7°C	6.83	4.88
Cdh Tj = +7 °C	0.937	0.952
Pdh Tj = 12°C	1.91 kW	1.84 kW
COP Tj = 12°C	9.23	6.91
Cdh Tj = +12 °C	0.928	0.944
Pdh Tj = Tbiv	3.36 kW	3.06 kW
COP Tj = Tbiv	2.86	1.97

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.08 kW	2.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.55	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	75 °C	75 °C
Poff	10 W	10 W
PTO	15 W	15 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.72 kW	0.76 kW
Annual energy consumption Qhe	1666 kWh	2138 kWh