

Subtype Beretta AGILE T 11T WH

Certificate Holder	Riello S.p.A.
Address	Via Ing. Pilade Riello 7
ZIP	37045
City	Legnago (VR)
Country	IT
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Beretta AGILE T 11T WH
Registration number	011-1W0726
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.3 kg
Certification Date	24.10.2023
Testing basis	HP KEYMARK certification scheme rules V12

Model HP ODU AGILE 11T / HP IDU AGILE M3WM

Model name	HP ODU AGILE 11T / HP IDU AGILE M3WM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	138 %	138 %
Prated	10 kW	10 kW
SCOP	4.56	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.13 kW	9.04 kW
COP Tj = -7°C	2.88	2.24
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	5.58 kW	8.55 kW
COP Tj = +2°C	4.38	3.23
Cdh Tj = +2 °C	0.96	0.98
Pdh Tj = +7°C	3.8 kW	3.86 kW
COP Tj = +7°C	6.16	5.03
Cdh Tj = +7 °C	0.92	0.93
Pdh Tj = 12°C	4.31 kW	4.42 kW
COP Tj = 12°C	8.76	8.43
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	9.13 kW	9.04 kW

COP $T_j = T_{biv}$	2.88	2.24
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	8.4 kW	7.54 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.69	1.88
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.89	0.9
WTOL	65 °C	65 °C
P _{off}	11 W	11 W
PTO	52 W	52 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.6 kW	2.5 kW
Annual energy consumption Q _{he}	4677 kWh	6005 kWh

Model HP ODU AGILE 11T / HP IDU AGILE M6WM

Model name	HP ODU AGILE 11T / HP IDU AGILE M6WM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	138 %	138 %
Prated	10 kW	10 kW
SCOP	4.56	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.13 kW	9.04 kW
COP Tj = -7°C	2.88	2.24
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	5.58 kW	8.55 kW
COP Tj = +2°C	4.38	3.23
Cdh Tj = +2 °C	0.96	0.98
Pdh Tj = +7°C	3.8 kW	3.86 kW
COP Tj = +7°C	6.16	5.03
Cdh Tj = +7 °C	0.92	0.93
Pdh Tj = 12°C	4.31 kW	4.42 kW
COP Tj = 12°C	8.76	8.43
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	9.13 kW	9.04 kW

COP Tj = Tbiv	2.88	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.4 kW	7.54 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.69	1.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.89	0.9
WTOL	65 °C	65 °C
Poff	11 W	11 W
PTO	52 W	52 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.6 kW	2.5 kW
Annual energy consumption Qhe	4677 kWh	6005 kWh

Model HP ODU AGILE 11T / HP IDU AGILE T6WM

Model name	HP ODU AGILE 11T / HP IDU AGILE T6WM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	138 %	138 %
Prated	10 kW	10 kW
SCOP	4.56	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.13 kW	9.04 kW
COP Tj = -7°C	2.88	2.24
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	5.58 kW	8.55 kW
COP Tj = +2°C	4.38	3.23
Cdh Tj = +2 °C	0.96	0.98
Pdh Tj = +7°C	3.8 kW	3.86 kW
COP Tj = +7°C	6.16	5.03
Cdh Tj = +7 °C	0.92	0.93
Pdh Tj = 12°C	4.31 kW	4.42 kW
COP Tj = 12°C	8.76	8.43
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	9.13 kW	9.04 kW

COP $T_j = T_{biv}$	2.88	2.24
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	8.4 kW	7.54 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.69	1.88
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.89	0.9
WTOL	65 °C	65 °C
P _{off}	11 W	11 W
PTO	52 W	52 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.6 kW	2.5 kW
Annual energy consumption Q _{he}	4677 kWh	6005 kWh