

## Subtype Beretta TOWER GREEN T 4M/6M AIO

Certificate Holder	Riello S.p.A.
Address	Via Ing. Pilade Riello 7
ZIP	37045
City	Legnago (VR)
Country	IT
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Beretta TOWER GREEN T 4M/6M AIO
Registration number	011-1W0728
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	0.9 kg
Certification Date	24.10.2023
Testing basis	HP KEYMARK certification scheme rules V12

## Model HP ODU AGILE 4M / HP IDU TOWER M31AS

Model name	HP ODU AGILE 4M / HP IDU TOWER M31AS
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	133 %
COP	3.14
Heating up time	1:38 h:min
Standby power input	35 W
Reference hot water temperature	47.7 °C
Mixed water at 40°C	234 l

## Model HP ODU AGILE 4M / HP IDU TOWER M61AS

Model name	HP ODU AGILE 4M / HP IDU TOWER M61AS
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	133 %
COP	3.14
Heating up time	1:38 h:min
Standby power input	35 W
Reference hot water temperature	47.7 °C
Mixed water at 40°C	234 l

## Model HP ODU AGILE 4M / HP IDU TOWER M32AS

Model name	HP ODU AGILE 4M / HP IDU TOWER M32AS
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	133 %
COP	3.14
Heating up time	1:38 h:min
Standby power input	35 W
Reference hot water temperature	47.7 °C
Mixed water at 40°C	234 l

## Model HP ODU AGILE 4M / HP IDU TOWER M62AS

Model name	HP ODU AGILE 4M / HP IDU TOWER M62AS
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	133 %
COP	3.14
Heating up time	1:38 h:min
Standby power input	35 W
Reference hot water temperature	47.7 °C
Mixed water at 40°C	234 l

## Model HP ODU AGILE 6M / HP IDU TOWER M31AS

Model name	HP ODU AGILE 6M / HP IDU TOWER M31AS
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	133 %
COP	3.14
Heating up time	1:38 h:min
Standby power input	35 W
Reference hot water temperature	47.7 °C
Mixed water at 40°C	234 l

## Model HP ODU AGILE 6M / HP IDU TOWER M61AS

Model name	HP ODU AGILE 6M / HP IDU TOWER M61AS
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	133 %
COP	3.14
Heating up time	1:38 h:min
Standby power input	35 W
Reference hot water temperature	47.7 °C
Mixed water at 40°C	234 l

## Model HP ODU AGILE 6M / HP IDU TOWER M32AS

Model name	HP ODU AGILE 6M / HP IDU TOWER M32AS
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	133 %
COP	3.14
Heating up time	1:38 h:min
Standby power input	35 W
Reference hot water temperature	47.7 °C
Mixed water at 40°C	234 l



## Model HP ODU AGILE 6M / HP IDU TOWER M62AS

Model name	HP ODU AGILE 6M / HP IDU TOWER M62AS
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	133 %
COP	3.14
Heating up time	1:38 h:min
Standby power input	35 W
Reference hot water temperature	47.7 °C
Mixed water at 40°C	234 l