

Subtype Ferroli Omnia S 3.2 4-6 - Omnia ST 3.2 4-6

Certificate Holder	Ferroli S.p.A.
Address	Via Ritonda 78/A
ZIP	37047
City	San Bonifacio (VR)
Country	IT
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Ferroli Omnia S 3.2 4-6 - Omnia ST 3.2 4-6
Registration number	011-1W0597
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	03.05.2023
Testing basis	HP KEYMARK certification scheme rules V11

Model OMNIA S 3.2 4

Model name	OMNIA S 3.2 4
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	55 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	191 %	129 %
Prated	5.50 kW	4.40 kW
SCOP	4.81	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.88 kW	3.89 kW
COP Tj = -7°C	3.19	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.05 kW	2.38 kW
COP Tj = +2°C	4.78	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.93 kW	2.94 kW
COP Tj = +7°C	6.13	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.48 kW	1.32 kW
COP Tj = 12°C	8.05	5.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.88 kW	3.89 kW

COP Tj = Tbiv	3.19	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.41 kW	3.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.09 kW	0.98 kW
Annual energy consumption Qhe	2351 kWh	2744 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	55 dB(A)	56 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	160 %	102 %
Prated	4.60 kW	3.40 kW
SCOP	4.03	2.58
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	2.75 kW	2.13 kW
COP Tj = -7°C	3.49	2.32
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	1.77 kW	1.28 kW
COP Tj = +2°C	4.95	2.99
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.17 kW	1.01 kW
COP Tj = +7°C	5.53	3.86
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.43 kW	1.36 kW
COP Tj = 12°C	7.67	6.28
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.72 kW	2.74 kW
COP Tj = Tbiv	2.57	1.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.80 kW	1.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.02

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	51 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.80 kW	1.76 kW
Annual energy consumption Qhe	2769 kWh	3159 kWh
Pdh Tj = -15°C (if TOL	3.72	2.74
COP Tj = -15°C (if TOL	2.57	1.74
Cdh Tj = -15 °C	0.900	0.900

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	55 dB(A)	56 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	255 %	162 %
Prated	5.50 kW	5.00 kW
SCOP	6.41	4.08
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.34 kW	4.83 kW
COP Tj = +2°C	3.94	2.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.56 kW	3.22 kW
COP Tj = +7°C	5.92	3.68
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.63 kW	1.47 kW
COP Tj = 12°C	7.91	5.15
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.56 kW	3.22 kW
COP Tj = Tbiv	5.92	3.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.34 kW	4.83 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.94	2.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	62 °C
Poff	14 W	14 W
PTO	24 W	24 W

PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.16 kW	0.17 kW
Annual energy consumption Q _{he}	1146 kWh	1621 kWh

Model OMNIA S 3.2 6

Model name	OMNIA S 3.2 6
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	57 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	138 %
Prated	6.80 kW	5.70 kW
SCOP	4.91	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.03 kW	5.04 kW
COP Tj = -7°C	3.09	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.88 kW	3.12 kW
COP Tj = +2°C	4.85	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.39 kW	2.08 kW
COP Tj = +7°C	6.63	4.54
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.39 kW	1.28 kW
COP Tj = 12°C	7.93	5.59
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.03 kW	5.04 kW

COP Tj = Tbiv	3.09	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.36 kW	4.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.44 kW	1.18 kW
Annual energy consumption Qhe	2845 kWh	3345 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	57 dB(A)	58 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	165 %	111 %
Prated	5.60 kW	4.30 kW
SCOP	4.16	2.81
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.42 kW	2.70 kW
COP Tj = -7°C	3.59	2.46
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	2.06 kW	1.60 kW
COP Tj = +2°C	5.21	3.36
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.46 kW	1.02 kW
COP Tj = +7°C	6.24	3.94
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.44 kW	1.37 kW
COP Tj = 12°C	7.66	6.35
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.59 kW	3.47 kW
COP Tj = Tbiv	2.53	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.48 kW	2.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.96	1.13

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	51 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.12 kW	2.21 kW
Annual energy consumption Qhe	3300 kWh	3681 kWh
Pdh Tj = -15°C (if TOL	4.59	3.47
COP Tj = -15°C (if TOL	2.53	1.86
Cdh Tj = -15 °C	0.900	0.900

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	57 dB(A)	58 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	260 %	165 %
Prated	6.10 kW	5.10 kW
SCOP	6.53	4.16
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.93 kW	5.02 kW
COP Tj = +2°C	3.91	2.48
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.93 kW	3.31 kW
COP Tj = +7°C	5.89	3.67
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.79 kW	1.60 kW
COP Tj = 12°C	8.20	5.29
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.93 kW	3.31 kW
COP Tj = Tbiv	5.89	3.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.93 kW	5.02 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.91	2.48
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	62 °C
Poff	14 W	14 W
PTO	24 W	24 W

PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.17 kW	0.08 kW
Annual energy consumption Q _{he}	1244 kWh	1640 kWh

Model OMNIA ST 3.2 4

Model name	OMNIA ST 3.2 4
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	123 %
COP	2.91
Heating up time	4:34 h:min
Standby power input	40.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	215 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	102 %
COP	2.40
Heating up time	5:32 h:min
Standby power input	49.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	215 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	145 %
COP	3.43
Heating up time	3:52 h:min
Standby power input	34.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	215 l

Model OMNIA ST 3.2 6

Model name	OMNIA ST 3.2 6
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	126 %
COP	2.97
Heating up time	4:16 h:min
Standby power input	42.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	215 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.45
Heating up time	5:10 h:min
Standby power input	51.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	215 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	150 %
COP	3.52
Heating up time	3:35 h:min
Standby power input	35.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	215 l