

Subtype Áurea+ HP60 16/18 / AHP60 16/18

Certificate Holder	Group Atlantic España - Soluciones Confort Térmico S.A.
Address	Calle Antonio Machado, 65 - Edificio Sócrates
ZIP	08840
City	Viladecans, Barcelona
Country	ES
Certification Body	ICIM S.p.A.
Subtype title	Áurea+ HP60 16/18 / AHP60 16/18
Registration number	ICIM-PDC-000125-00
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	4 kg
Certification Date	18.10.2021
Testing basis	HP KEYMARK certification scheme rules rev. no. 7

Model HP60-16 / AHP60-16

Model name	HP60-16 / AHP60-16
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	177 %	126 %
Prated	14.00 kW	13.00 kW
SCOP	4.49	3.22
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	12.00 kW	11.50 kW
COP Tj = -7°C	2.88	2.09
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	7.30 kW	6.90 kW
COP Tj = +2°C	4.33	3.06
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.70 kW	5.50 kW
COP Tj = +7°C	5.83	4.11
Cdh Tj = +7 °C	0.981	0.986
Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.12	6.30
Cdh Tj = +12 °C	0.977	0.982
Pdh Tj = Tbiv	12.00 kW	11.50 kW

COP $T_j = T_{biv}$	2.88	2.09
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	11.50 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.60	1.94
WTOL	60 °C	60 °C
P _{off}	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	6209 kWh	8357 kWh

Model HP60-18TR / AHP60-18TR

Model name	HP60-18TR / AHP60-18TR
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	175 %	131 %
Prated	15.00 kW	14.00 kW
SCOP	4.46	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	12.80 kW	12.50 kW
COP Tj = -7°C	2.83	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	7.80 kW	7.60 kW
COP Tj = +2°C	4.34	3.34
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.80 kW	5.70 kW
COP Tj = +7°C	5.67	4.14
Cdh Tj = +7 °C	0.981	0.990
Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	7.94	6.15
Cdh Tj = +12 °C	0.977	0.980
Pdh Tj = Tbiv	12.80 kW	12.50 kW
COP Tj = Tbiv	2.83	2.03

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.80 kW	12.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.93
WTOL	60 °C	60 °C
Poff	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6720 kWh	8659 kWh

Model HP60-16TR / AHP60-16TR

Model name	HP60-16TR / AHP60-16TR
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	177 %	126 %
Prated	14.00 kW	13.00 kW
SCOP	4.49	3.22
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	12.00 kW	11.50 kW
COP Tj = -7°C	2.88	2.09
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	7.30 kW	6.90 kW
COP Tj = +2°C	4.33	3.06
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.70 kW	5.50 kW
COP Tj = +7°C	5.83	4.11
Cdh Tj = +7 °C	0.981	0.986
Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.12	6.30
Cdh Tj = +12 °C	0.977	0.982
Pdh Tj = Tbiv	12.00 kW	11.50 kW

COP $T_j = T_{biv}$	2.88	2.09
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	11.50 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.60	1.94
WTOL	60 °C	60 °C
P _{off}	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	6209 kWh	8357 kWh

Model HPS60-16 / AHP60-16

Model name	HPS60-16 / AHP60-16
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	186 %	133 %
Prated	13.00 kW	13.00 kW
SCOP	4.72	3.39
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	11.90 kW	11.50 kW
COP Tj = -7°C	2.98	2.16
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	7.30 kW	6.90 kW
COP Tj = +2°C	4.56	3.23
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.80 kW	5.70 kW
COP Tj = +7°C	6.17	4.34
Cdh Tj = +7 °C	0.980	0.985
Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.70	6.75
Cdh Tj = +12 °C	0.975	0.981
Pdh Tj = Tbiv	11.90 kW	11.50 kW

COP $T_j = T_{biv}$	2.98	2.16
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.40 kW	11.50 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.65	1.98
WTOL	60 °C	60 °C
P _{off}	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	5882 kWh	7914 kWh

Model HPS60-16TR / AHPS60-16TR

Model name	HPS60-16TR / AHPS60-16TR
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	186 %	133 %
Prated	13.00 kW	13.00 kW
SCOP	4.72	3.39
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	11.90 kW	11.50 kW
COP Tj = -7°C	2.98	2.16
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	7.30 kW	6.90 kW
COP Tj = +2°C	4.56	3.23
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.80 kW	5.70 kW
COP Tj = +7°C	6.17	4.34
Cdh Tj = +7 °C	0.980	0.985
Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.70	6.75
Cdh Tj = +12 °C	0.975	0.981
Pdh Tj = Tbiv	11.90 kW	11.50 kW

COP $T_j = T_{biv}$	2.98	2.16
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.40 kW	11.50 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.65	1.98
WTOL	60 °C	60 °C
P _{off}	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	5882 kWh	7914 kWh