

Subtype Acond PRO-N	
Certificate Holder	Acond a.s.
Address	Štěrboholská 1434/102a
ZIP	102 00
City	Hostivař, Praha
Country	CZ
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
Subtype title	Acond PRO-N
Registration number	037-0075-22
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.35 kg
Certification Date	17.03.2022
Testing basis	HP Keymark scheme rules rev. no. 9

Model Acond PRO-N		
Model name	Acond PRO-N	
Application	Heating (medium temp)	
Units	Indoor, Outdoor	
Climate zone (for heating)	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	3x400V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	3.04 kW	3.54 kW
El input	0.62 kW	1.17 kW
COP	4.90	3.03
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	0 dB(A)
Sound power level outdoor	dB(A)	48 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	164 %	135 %
Prated	5.29 kW	5.14 kW
SCOP	4.18	3.45
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.68 kW	4.54 kW
COP Tj = -7°C	2.98	2.20
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	2.88 kW	2.77 kW
COP Tj = +2°C	4.18	3.42
Cdh Tj = +2 °C	0.900	0.900

Pdh Tj = +7°C	1.83 kW	1.86 kW
COP Tj = +7°C	5.11	4.46
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.81 kW	1.76 kW
COP Tj = 12°C	5.18	4.86
Cdh Tj = +12 °C	0.954	0.959
Pdh Tj = Tbiv	5.29 kW	5.14 kW
COP Tj = Tbiv	2.21	1.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.29 kW	5.14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.21	1.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2615 kWh	3078 kWh