

## Subtype ECL-PAC-14

Certificate Holder	ECL Nexus
Address	13, Boulevard Pereire
ZIP	75017
City	Paris
Country	FR
Certification Body	ICIM S.p.A.
Subtype title	ECL-PAC-14
Registration number	ICIM-PDC-000144
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	3.6 kg
Certification Date	20.05.2022
Testing basis	HP KEYMARK certification scheme rules rev. no. 7

## Model ECLPAC14X.ST ; ECLPAC14X.KA

Model name	ECLPAC14X.ST ; ECLPAC14X.KA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	176 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.48	3.31
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	10.70 kW	10.30 kW
COP Tj = -7°C	2.98	2.10
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.50 kW	6.20 kW
COP Tj = +2°C	4.20	3.21
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.80 kW	5.70 kW
COP Tj = +7°C	5.98	4.19
Cdh Tj = +7 °C	0.980	0.986
Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.16	6.17
Cdh Tj = +12 °C	0.977	0.982
Pdh Tj = Tbiv	10.70 kW	10.30 kW

COP $T_j = T_{biv}$	2.98	2.10
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.50 kW	10.20 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.69	1.96
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$		
WTOL	60 °C	60 °C
P <sub>off</sub>	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.50 kW	1.80 kW
Annual energy consumption Q <sub>he</sub>	5583 kWh	7259 kWh

## Model ECLPAC14TX.ST ; ECLPAC14T.KA

Model name	ECLPAC14TX.ST ; ECLPAC14T.KA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	176 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.48	3.31
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	10.70 kW	10.30 kW
COP Tj = -7°C	2.98	2.10
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.50 kW	6.20 kW
COP Tj = +2°C	4.20	3.21
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.80 kW	5.70 kW
COP Tj = +7°C	5.98	4.19
Cdh Tj = +7 °C	0.980	0.986
Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.16	6.17
Cdh Tj = +12 °C	0.977	0.982
Pdh Tj = Tbiv	10.70 kW	10.30 kW

COP $T_j = T_{biv}$	2.98	2.10
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.50 kW	10.20 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.69	1.96
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$		
WTOL	60 °C	60 °C
P <sub>off</sub>	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.50 kW	1.80 kW
Annual energy consumption $Q_{he}$	5583 kWh	7259 kWh