

Subtype ECL-PAC-04

Certificate Holder	ECL Nexus
Address	13, Boulevard Pereire
ZIP	75017
City	Paris
Country	FR
Certification Body	ICIM S.p.A.
Subtype title	ECL-PAC-04
Registration number	ICIM-PDC-000141
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	20.05.2022
Testing basis	V9

Model ECLPAC04X.ST / ECLPAC04X.KA

Model name	ECLPAC04X.ST / ECLPAC04X.KA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	179 %	135 %
Prated	4.00 kW	4.00 kW
SCOP	4.56	3.45
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	3.90 kW	3.90 kW
COP Tj = -7°C	3.01	2.26
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	2.40 kW	2.40 kW
COP Tj = +2°C	4.53	3.32
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	2.80 kW	2.80 kW
COP Tj = +7°C	5.57	4.35
Cdh Tj = +7 °C	0.969	0.976
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.01	6.01
Cdh Tj = +12 °C	0.963	0.969
Pdh Tj = Tbiv	3.90 kW	3.90 kW

COP $T_j = T_{biv}$	3.01	2.26
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.80 kW	3.90 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.77	2.06
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$		
WTOL	60 °C	60 °C
P _{off}	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.20 kW	0.10 kW
Annual energy consumption Q _{he}	1988 kWh	2624 kWh