

Subtype ECL-PAC-06-08

Certificate Holder	ECL Nexus
Address	13, Boulevard Pereire
ZIP	75017
City	Paris
Country	FR
Certification Body	ICIM S.p.A.
Subtype title	ECL-PAC-06-08
Registration number	ICIM-PDC-000142
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	20.05.2022
Testing basis	HP KEYMARK certification scheme rules rev. no. 7

Model ECLPAC06X.XT ; ECLPAC06X.KA

Model name	ECLPAC06X.XT ; ECLPAC06X.KA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	175 %	126 %
Prated	7.00 kW	7.00 kW
SCOP	4.46	3.22
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	6.10 kW	5.80 kW
COP Tj = -7°C	2.96	2.08
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	3.70 kW	3.60 kW
COP Tj = +2°C	4.36	3.30
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	5.56	3.49
Cdh Tj = +7 °C	0.967	0.978
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.88	6.49
Cdh Tj = +12 °C	0.959	0.966
Pdh Tj = Tbiv	6.10 kW	5.80 kW

COP $T_j = T_{biv}$	2.96	2.08
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.10 kW	6.00 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.73	1.95
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$		
WTOL	60 °C	60 °C
P _{off}	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.90 kW	1.00 kW
Annual energy consumption Q _{he}	3178 kWh	4190 kWh

Model ECLPAC08X.XT ; ECLPAC08X.KA

Model name	ECLPAC08X.XT ; ECLPAC08X.KA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	128 %
Prated	7.00 kW	7.00 kW
SCOP	4.46	3.27
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	6.50 kW	6.30 kW
COP Tj = -7°C	2.95	1.91
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.00 kW	3.80 kW
COP Tj = +2°C	4.37	3.33
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	3.10 kW	3.10 kW
COP Tj = +7°C	5.55	3.90
Cdh Tj = +7 °C	0.966	0.976
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.86	6.30
Cdh Tj = +12 °C	0.959	0.967
Pdh Tj = Tbiv	6.50 kW	6.30 kW

COP $T_j = T_{biv}$	2.95	1.91
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.50 kW	6.40 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.70	1.95
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$		
WTOL	60 °C	60 °C
P _{off}	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.50 kW	0.60 kW
Annual energy consumption Q _{he}	3411 kWh	4494 kWh