

## Subtype EVI DC Inverter Heat Pump 30

Certificate Holder	Power World Machinery Equipment Co. Ltd
Address	No.24, The Fourth Industrial Zone, HouTing Street
ZIP	
City	Shenzhen
Country	CN
Certification Body	BRE Global Limited
Subtype title	EVI DC Inverter Heat Pump 30
Registration number	041-K032-04
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.3 kg
Certification Date	19.01.2023
Testing basis	Heat Pump Keymark Scheme Rules Rev 11

## Model PW030-DKZLRS-B/S

Model name	PW030-DKZLRS-B/S
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	63 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	175 %	129 %
Prated	4.38 kW	5.09 kW
SCOP	4.46	3.30
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	3.88 kW	4.50 kW
COP Tj = -7°C	2.91	2.21
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	2.55 kW	2.94 kW
COP Tj = +2°C	4.51	3.35
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.54 kW	2.45 kW
COP Tj = +7°C	5.99	4.19
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.00 kW	3.01 kW
COP Tj = 12°C	7.83	5.61
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.88 kW	4.50 kW
COP Tj = Tbiv	2.91	2.21

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.19 kW	4.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.42	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	13 W	16 W
PSB	10 W	10 W
PCK	42 W	42 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.78 kW
Annual energy consumption Qhe	2030 kWh	3183 kWh