

Subtype KENSOL KTM6kW

Certificate Holder	KENSOL Sp z.o.o.
Address	ul. Daszyńskiego 609a
ZIP	44-151
City	Gliwice
Country	PL
Certification Body	BRE Global Limited
Subtype title	KENSOL KTM6kW
Registration number	041-K049-01
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.3 kg
Certification Date	26.04.2023
Testing basis	Heat Pump Keymark Scheme Rules Rev 11

Model KTM6kW

Model name	KTM6kW
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	136 %
Prated	6.37 kW	6.68 kW
SCOP	4.59	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.64 kW	5.91 kW
COP Tj = -7°C	3.40	2.27
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.45 kW	3.53 kW
COP Tj = +2°C	4.40	3.51
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	3.00 kW	2.84 kW
COP Tj = +7°C	5.61	4.16
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.09 kW	3.38 kW
COP Tj = 12°C	6.85	5.96
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	5.64 kW	5.91 kW
COP Tj = Tbiv	3.40	2.27

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.85 kW	5.85 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.02	2.13
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	50 °C	50 °C
Poff	5 W	5 W
PTO	5 W	5 W
PSB	5 W	5 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.52 kW	0.83 kW
Annual energy consumption Qhe	2867 kWh	3983 kWh