

Subtype Air Source Heat Pump R32- 08

| | |
|---------------------|--|
| Certificate Holder | Jiangsu Micoe Solar Energy Co., Ltd |
| Address | No.199, Yingzhou Road, |
| ZIP | 222000 |
| City | LianyungangCity, Jiangsu Province |
| Country | CN |
| Certification Body | BRE Global Limited |
| Subtype title | Air Source Heat Pump R32- 08 |
| Registration number | 041-K061-01 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R32 |
| Mass of Refrigerant | 1.25 kg |
| Certification Date | 08.08.2023 |
| Testing basis | Heat Pump KEYMARK certification Scheme rules v12 |

Model MMHP-008C1

| | |
|-------------------------------------|-----------------------|
| Model name | MMHP-008C1 |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water

EN 14511-4 | Heating

| | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 63 dB(A) | 63 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|-----------------|-----------------|--------------------|
| η_s | 180 % | 126 % |
| Prated | 5.22 kW | 5.03 kW |
| SCOP | 4.58 | 3.23 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 4.62 kW | 4.45 kW |
| COP Tj = -7°C | 3.03 | 2.14 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 2.92 kW | 2.80 kW |
| COP Tj = +2°C | 4.51 | 3.22 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = +7°C | 2.04 kW | 1.75 kW |
| COP Tj = +7°C | 6.03 | 3.90 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 2.06 kW | 2.19 kW |
| COP Tj = 12°C | 7.58 | 6.08 |
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 4.62 kW | 4.45 kW |
| COP Tj = Tbiv | 3.03 | 2.14 |

| | | |
|---|-------------|-------------|
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 4.18 kW | 4.08 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.75 | 1.89 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 50 °C | 50 °C |
| Poff | 8 W | 8 W |
| PTO | 16 W | 16 W |
| PSB | 8 W | 8 W |
| PCK | 63 W | 63 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.05 kW | 0.94 kW |
| Annual energy consumption Qhe | 2357 kWh | 3212 kWh |

Model MMHP-008B1

| | |
|-------------------------------------|-----------------------|
| Model name | MMHP-008B1 |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water

EN 14511-4 | Heating

| | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 63 dB(A) | 63 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|-----------------|-----------------|--------------------|
| η_s | 180 % | 126 % |
| Prated | 5.22 kW | 5.03 kW |
| SCOP | 4.58 | 3.23 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 4.62 kW | 4.45 kW |
| COP Tj = -7°C | 3.03 | 2.14 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 2.92 kW | 2.80 kW |
| COP Tj = +2°C | 4.51 | 3.22 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = +7°C | 2.04 kW | 1.75 kW |
| COP Tj = +7°C | 6.03 | 3.90 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 2.06 kW | 2.19 kW |
| COP Tj = 12°C | 7.58 | 6.08 |
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 4.62 kW | 4.45 kW |
| COP Tj = Tbiv | 3.03 | 2.14 |

| | | |
|---|-------------|-------------|
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 4.18 kW | 4.08 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.75 | 1.89 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 50 °C | 50 °C |
| Poff | 8 W | 8 W |
| PTO | 16 W | 16 W |
| PSB | 8 W | 8 W |
| PCK | 63 W | 63 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.05 kW | 0.94 kW |
| Annual energy consumption Qhe | 2357 kWh | 3212 kWh |