

## Subtype Inverter Air Source Heat Pump- R32- 10

Certificate Holder	Guangzhou Dentwiton Manufacture Co., Ltd.
Address	No.3, No. 9, Huasheng Beiroad, Xicheng industry zone, Renhe town, Baiyun district,
ZIP	
City	Guangzhou
Country	CN
Certification Body	BRE Global Limited
Subtype title	Inverter Air Source Heat Pump- R32- 10
Registration number	041-K077-02
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.8 kg
Certification Date	24.11.2023
Testing basis	Heat Pump KEYMARK certification Scheme rules v12

Model RS10V/L		
Model name	RS10V/L	
Application	Heating (medium temp)	
Units	Outdoor	
Climate zone (for heating)	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	3x400V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4   Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2   Heating		
	Low temperature	Medium temperature
Heat output	9.10 kW	9.95 kW
El input	2.04 kW	3.31 kW
COP	4.46	3.01
EN 12102-1   Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	64 dB(A)	64 dB(A)
EN 14825   Average Climate		
	Low temperature	Medium temperature
ηs	179 %	134 %
Prated	9.61 kW	10.06 kW
SCOP	4.54	3.44
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	8.50 kW	8.90 kW
COP Tj = -7°C	3.01	2.31
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.18 kW	5.49 kW
COP Tj = +2°C	4.42	3.35
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.20 kW	4.00 kW

COP Tj = +7°C	5.68	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.78 kW	4.61 kW
COP Tj = 12°C	7.64	5.69
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	8.50 kW	8.90 kW
COP Tj = Tbiv	3.01	2.31
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.17 kW	8.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	2.18
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.990
WTOL	55 °C	55 °C
Poff	16 W	14 W
PTO	16 W	15 W
PSB	16 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.44 kW	1.46 kW
Annual energy consumption Qhe	4367 kWh	6053 kWh