

Subtype WELLEA MONOBLOC 12/14/16 KW 1ph

Certificate Holder	Airwell Residential S.A.S.
Address	10, rue du Fort de Saint Cyr
ZIP	78180
City	Montigny le Bretonneux
Country	FR
Certification Body	ICIM S.p.A.
Subtype title	WELLEA MONOBLOC 12/14/16 KW 1ph
Registration number	ICIM-PDC-000055-00
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	2.8 kg
Certification Date	17.01.2020
Testing basis	EN 14511:2013, EN 14825:2016, EN 12102:2013

Model WELLEA MONOBLOC 12 KW 1PH

Model name	WELLEA MONOBLOC 12 KW 1PH
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	169 %	126 %
Prated	12.00 kW	13.00 kW
SCOP	4.29	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.52 kW	11.29 kW
COP Tj = -7°C	2.88	2.05
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.50 kW	7.31 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.12 kW	4.96 kW
COP Tj = +7°C	5.74	4.25
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.23 kW	2.37 kW
COP Tj = 12°C	5.40	4.94
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.52 kW	11.29 kW
COP Tj = Tbiv	2.88	2.05

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.01 kW	11.88 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.79
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	15 W	15 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5726 kWh	8164 kWh

Model WELLEA MONOBLOC 14 KW 1PH

Model name	WELLEA MONOBLOC 14 KW 1PH
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	168 %	128 %
Prated	14.00 kW	14.00 kW
SCOP	4.27	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.47 kW	12.18 kW
COP Tj = -7°C	2.84	2.05
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.48 kW	7.84 kW
COP Tj = +2°C	4.19	3.18
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.04 kW	5.21 kW
COP Tj = +7°C	5.99	4.29
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.23 kW	2.57 kW
COP Tj = 12°C	5.30	5.14
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.47 kW	12.18 kW
COP Tj = Tbiv	2.84	2.05

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.72 kW	11.68 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	1.74
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	26 W	26 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	2.10 kW
Annual energy consumption Qhe	6819 kWh	8724 kWh

Model WELLEA MONOBLOC 16 KW 1PH

Model name	WELLEA MONOBLOC 16 KW 1PH
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	169 %	128 %
Prated	16.00 kW	15.00 kW
SCOP	4.30	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.15 kW	12.90 kW
COP Tj = -7°C	2.72	2.04
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.92 kW	8.25 kW
COP Tj = +2°C	4.17	3.21
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.64 kW	5.45 kW
COP Tj = +7°C	5.86	4.32
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.47 kW	2.57 kW
COP Tj = 12°C	6.28	5.12
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.15 kW	12.90 kW
COP Tj = Tbiv	2.72	2.04

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.93 kW	11.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.65
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	41 W	41 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.10 kW	3.40 kW
Annual energy consumption Qhe	7687 kWh	9216 kWh