

## Subtype Aquarena Split 7 kW STD (J Series)

Certificate Holder	Panasonic Marketing Europe GmbH
Address	Hagenauer Strasse 43, Wiesbaden
ZIP	65203
City	Wiesbaden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Aquarena Split 7 kW STD (J Series)
Registration number	011-1W0208
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.27 kg
Certification Date	08.01.2020
Testing basis	HP KEYMARK certification scheme rules V7

## Model WH-ADC0309J3E5 / WH-UD07JE5

Model name	WH-ADC0309J3E5 / WH-UD07JE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	3.00
Heating up time	1:22 h:min
Standby power input	31.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	234 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.00 kW	7.00 kW
El input	1.47 kW	2.48 kW
COP	4.76	2.82

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	193 %	130 %
Prated	6.00 kW	7.00 kW

SCOP	4.90	3.32
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	6.30 kW
COP Tj = -7°C	3.04	1.86
Cdh Tj = -7 °C	0.970	0.990
Pdh Tj = +2°C	3.20 kW	3.80 kW
COP Tj = +2°C	4.96	3.33
Cdh Tj = +2 °C	0.930	0.960
Pdh Tj = +7°C	2.90 kW	2.70 kW
COP Tj = +7°C	6.50	4.52
Cdh Tj = +7 °C	0.900	0.920
Pdh Tj = 12°C	3.40 kW	3.30 kW
COP Tj = 12°C	8.42	6.26
Cdh Tj = +12 °C	0.890	0.910
Pdh Tj = Tbiv	6.00 kW	6.20 kW
COP Tj = Tbiv	2.95	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	6.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.95	1.70
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	44 W	44 W
PSB	10 W	10 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.80 kW
Annual energy consumption Qhe	2532 kWh	4354 kWh

## Model WH-ADC0309J3E5B / WH-UD07JE5

Model name	WH-ADC0309J3E5B / WH-UD07JE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	3.00
Heating up time	1:22 h:min
Standby power input	31.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	234 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.00 kW	7.00 kW
El input	1.47 kW	2.48 kW
COP	4.76	2.82

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	193 %	130 %
Prated	6.00 kW	7.00 kW

SCOP	4.90	3.32
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	6.30 kW
COP Tj = -7°C	3.04	1.86
Cdh Tj = -7 °C	0.970	0.990
Pdh Tj = +2°C	3.20 kW	3.80 kW
COP Tj = +2°C	4.96	3.33
Cdh Tj = +2 °C	0.930	0.960
Pdh Tj = +7°C	2.90 kW	2.70 kW
COP Tj = +7°C	6.50	4.52
Cdh Tj = +7 °C	0.900	0.920
Pdh Tj = 12°C	3.40 kW	3.30 kW
COP Tj = 12°C	8.42	6.26
Cdh Tj = +12 °C	0.890	0.910
Pdh Tj = Tbiv	6.00 kW	6.20 kW
COP Tj = Tbiv	2.95	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	6.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.95	1.70
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	44 W	44 W
PSB	10 W	10 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.80 kW
Annual energy consumption Qhe	2532 kWh	4354 kWh

## Model WH-ADC0309J3E5AN / WH-UD07JE5

Model name	WH-ADC0309J3E5AN / WH-UD07JE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	3.00
Heating up time	1:22 h:min
Standby power input	31.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	234 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.00 kW	7.00 kW
El input	1.47 kW	2.48 kW
COP	4.76	2.82

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	193 %	130 %
Prated	6.00 kW	7.00 kW

SCOP	4.90	3.32
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	6.30 kW
COP Tj = -7°C	3.04	1.86
Cdh Tj = -7 °C	0.970	0.990
Pdh Tj = +2°C	3.20 kW	3.80 kW
COP Tj = +2°C	4.96	3.33
Cdh Tj = +2 °C	0.930	0.960
Pdh Tj = +7°C	2.90 kW	2.70 kW
COP Tj = +7°C	6.50	4.52
Cdh Tj = +7 °C	0.900	0.920
Pdh Tj = 12°C	3.40 kW	3.30 kW
COP Tj = 12°C	8.42	6.26
Cdh Tj = +12 °C	0.890	0.910
Pdh Tj = Tbiv	6.00 kW	6.20 kW
COP Tj = Tbiv	2.95	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	6.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.95	1.70
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	44 W	44 W
PSB	10 W	10 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.80 kW
Annual energy consumption Qhe	2532 kWh	4354 kWh

**Model WH-ADC0309J3E5UK / WH-UD07JE5**

Model name	WH-ADC0309J3E5UK / WH-UD07JE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

**General data**

Power supply	1x230V 50Hz
Off-peak product	n/a

**Outdoor Air/Water****EN 16147 | Average Climate**

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	3.00
Heating up time	1:22 h:min
Standby power input	31.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	234 l

**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

**EN 14511-2 | Heating**

	Low temperature	Medium temperature
Heat output	7.00 kW	7.00 kW
El input	1.47 kW	2.48 kW
COP	4.76	2.82

**EN 12102-1 | Average Climate**

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

**EN 14825 | Average Climate**

	Low temperature	Medium temperature
$\eta_s$	193 %	130 %
Prated	6.00 kW	7.00 kW



SCOP	4.90	3.32
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	6.30 kW
COP Tj = -7°C	3.04	1.86
Cdh Tj = -7 °C	0.970	0.990
Pdh Tj = +2°C	3.20 kW	3.80 kW
COP Tj = +2°C	4.96	3.33
Cdh Tj = +2 °C	0.930	0.960
Pdh Tj = +7°C	2.90 kW	2.70 kW
COP Tj = +7°C	6.50	4.52
Cdh Tj = +7 °C	0.900	0.920
Pdh Tj = 12°C	3.40 kW	3.30 kW
COP Tj = 12°C	8.42	6.26
Cdh Tj = +12 °C	0.890	0.910
Pdh Tj = Tbiv	6.00 kW	6.20 kW
COP Tj = Tbiv	2.95	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	6.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.95	1.70
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	44 W	44 W
PSB	10 W	10 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.80 kW
Annual energy consumption Qhe	2532 kWh	4354 kWh

## Model WH-SDC0709J3E5 / WH-UD07JE5

Model name	WH-SDC0709J3E5 / WH-UD07JE5
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.00 kW	7.00 kW
El input	1.47 kW	2.48 kW
COP	4.76	2.82

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	193 %	130 %
Prated	6.00 kW	7.00 kW
SCOP	4.90	3.32
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	6.30 kW
COP Tj = -7°C	3.04	1.86
Cdh Tj = -7 °C	0.970	0.990
Pdh Tj = +2°C	3.20 kW	3.80 kW
COP Tj = +2°C	4.96	3.33
Cdh Tj = +2 °C	0.930	0.960

Pdh Tj = +7°C	2.90 kW	2.70 kW
COP Tj = +7°C	6.50	4.52
Cdh Tj = +7 °C	0.900	0.920
Pdh Tj = 12°C	3.40 kW	3.30 kW
COP Tj = 12°C	8.42	6.26
Cdh Tj = +12 °C	0.890	0.910
Pdh Tj = Tbiv	6.00 kW	6.20 kW
COP Tj = Tbiv	2.95	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	6.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.95	1.70
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	44 W	44 W
PSB	10 W	10 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.80 kW
Annual energy consumption Qhe	2532 kWh	4354 kWh

## EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	164 %	116 %
Prated	7.00 kW	6.00 kW
SCOP	4.18	2.98
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.20 kW	3.60 kW
COP Tj = -7°C	3.41	2.41
Cdh Tj = -7 °C	0.96	0.97
Pdh Tj = +2°C	2.50 kW	2.20 kW
COP Tj = +2°C	5.39	3.75
Cdh Tj = +2 °C	0.90	0.92
Pdh Tj = +7°C	3.00 kW	2.80 kW
COP Tj = +7°C	6.69	5.01
Cdh Tj = +7 °C	0.90	0.92
Pdh Tj = 12°C	3.40 kW	3.30 kW
COP Tj = 12°C	8.24	6.67
Cdh Tj = +12 °C	0.89	0.91
Pdh Tj = Tbiv	5.70 kW	4.90 kW
COP Tj = Tbiv	2.44	1.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.70 kW	3.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.82	1.08

WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	44 W	44 W
PSB	10 W	10 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.00 kW	3.00 kW
Annual energy consumption Qhe	4132 kWh	4967 kWh
Pdh Tj = -15°C (if TOL	5.70	4.90
COP Tj = -15°C (if TOL	2.44	1.72
Cdh Tj = -15 °C	0.98	0.98

## EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	227 %	160 %
Prated	7.00 kW	6.00 kW
SCOP	5.75	4.07
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.10 kW	6.10 kW
COP Tj = +2°C	2.80	2.14
Cdh Tj = +2 °C	0.98	0.98
Pdh Tj = +7°C	4.50 kW	3.80 kW
COP Tj = +7°C	5.37	3.51
Cdh Tj = +7 °C	0.95	0.96
Pdh Tj = 12°C	3.40 kW	3.30 kW
COP Tj = 12°C	7.77	5.80
Cdh Tj = +12 °C	0.90	0.92
Pdh Tj = Tbiv	7.00 kW	6.00 kW
COP Tj = Tbiv	2.80	2.14
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.10 kW	6.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.14
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	44 W	44 W
PSB	10 W	10 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.00 kW	3.00 kW
Annual energy consumption Qhe	1627 kWh	1971 kWh

## Model WH-ADC0309J3E5C / WH-UD07JE5

Model name	WH-ADC0309J3E5C / WH-UD07JE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	116 %
COP	2.90
Heating up time	1:01 h:min
Standby power input	39.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	232 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.00 kW	7.00 kW
El input	1.47 kW	2.48 kW
COP	4.76	2.82

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	193 %	130 %
Prated	6.00 kW	7.00 kW

SCOP	4.90	3.32
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	6.30 kW
COP Tj = -7°C	3.04	1.86
Cdh Tj = -7 °C	0.970	0.990
Pdh Tj = +2°C	3.20 kW	3.80 kW
COP Tj = +2°C	4.96	3.33
Cdh Tj = +2 °C	0.930	0.960
Pdh Tj = +7°C	2.90 kW	2.70 kW
COP Tj = +7°C	6.50	4.52
Cdh Tj = +7 °C	0.900	0.920
Pdh Tj = 12°C	3.40 kW	3.30 kW
COP Tj = 12°C	8.42	6.26
Cdh Tj = +12 °C	0.890	0.910
Pdh Tj = Tbiv	6.00 kW	6.20 kW
COP Tj = Tbiv	2.95	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	6.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.95	1.70
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	44 W	44 W
PSB	10 W	10 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.80 kW
Annual energy consumption Qhe	2532 kWh	4354 kWh

**Model WH-ADC0309J3E5ANC / WH-UD07JE5**

Model name	WH-ADC0309J3E5ANC / WH-UD07JE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

**General data**

Power supply	1x230V 50Hz
Off-peak product	n/a

**Outdoor Air/Water****EN 16147 | Average Climate**

Declared load profile	L
Efficiency $\eta_{DHW}$	116 %
COP	2.90
Heating up time	1:01 h:min
Standby power input	39.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	232 l

**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

**EN 14511-2 | Heating**

	Low temperature	Medium temperature
Heat output	7.00 kW	7.00 kW
El input	1.47 kW	2.48 kW
COP	4.76	2.82

**EN 12102-1 | Average Climate**

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

**EN 14825 | Average Climate**

	Low temperature	Medium temperature
$\eta_s$	193 %	130 %
Prated	6.00 kW	7.00 kW

SCOP	4.90	3.32
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	6.30 kW
COP Tj = -7°C	3.04	1.86
Cdh Tj = -7 °C	0.970	0.990
Pdh Tj = +2°C	3.20 kW	3.80 kW
COP Tj = +2°C	4.96	3.33
Cdh Tj = +2 °C	0.930	0.960
Pdh Tj = +7°C	2.90 kW	2.70 kW
COP Tj = +7°C	6.50	4.52
Cdh Tj = +7 °C	0.900	0.920
Pdh Tj = 12°C	3.40 kW	3.30 kW
COP Tj = 12°C	8.42	6.26
Cdh Tj = +12 °C	0.890	0.910
Pdh Tj = Tbiv	6.00 kW	6.20 kW
COP Tj = Tbiv	2.95	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	6.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.95	1.70
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	44 W	44 W
PSB	10 W	10 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.80 kW
Annual energy consumption Qhe	2532 kWh	4354 kWh