

Subtype F1355-43

| | |
|---------------------|-------------------------------|
| Certificate Holder | Nibe AB |
| Address | Box 14 |
| ZIP | S-28521 |
| City | Markaryd |
| Country | SE |
| Certification Body | RISE CERT |
| Subtype title | F1355-43 |
| Registration number | 012-C700002 |
| Heat Pump Type | Brine/Water and Water/Water |
| Refrigerant | Other |
| Mass of Refrigerant | 3.8 kg |
| Certification Date | 12.02.2020 |
| Testing basis | HP Keymark Scheme Rules rev 7 |

Model F1355-43

| | |
|-------------------------------------|-----------------------|
| Model name | F1355-43 |
| Application | Heating (medium temp) |
| Units | Indoor |
| Climate zone (for heating) | Colder Climate |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 3x400V 50Hz |
| Off-peak product | No |

Brine/Water

EN 14511-4 | Heating

| | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 47 dB(A) | 47 dB(A) |
| Sound power level outdoor | 0 dB(A) | 0 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|-----------------|-----------------|--------------------|
| η_s | 192 % | 152 % |
| Prated | 45.00 kW | 42.00 kW |
| SCOP | 5.00 | 4.00 |
| Tbiv | -10 °C | -10 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 39.50 kW | 36.50 kW |
| COP Tj = -7°C | 4.24 | 3.13 |
| Cdh Tj = -7 °C | 1.00 | 1.00 |
| Pdh Tj = +2°C | 26.43 kW | 26.59 kW |
| COP Tj = +2°C | 4.82 | 3.87 |
| Cdh Tj = +2 °C | 1.00 | 1.00 |
| Pdh Tj = +7°C | 15.39 kW | 13.32 kW |
| COP Tj = +7°C | 5.61 | 4.66 |
| Cdh Tj = +7 °C | 1.00 | 1.00 |
| Pdh Tj = 12°C | 7.81 kW | 7.78 kW |
| COP Tj = 12°C | 6.51 | 5.41 |
| Cdh Tj = +12 °C | 1.00 | 1.00 |
| Pdh Tj = Tbiv | 42.90 kW | 40.11 kW |
| COP Tj = Tbiv | 4.02 | 2.83 |

| | | |
|---|-----------|-----------|
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 42.90 kW | 40.11 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 4.02 | 2.83 |
| WTOL | 65 °C | 65 °C |
| Poff | 8 W | 8 W |
| PTO | 0 W | 0 W |
| PSB | 18 W | 18 W |
| PCK | 20 W | 20 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 18588 kWh | 21700 kWh |

EN 12102-1 | Colder Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 47 dB(A) | 47 dB(A) |
| Sound power level outdoor | 0 dB(A) | 0 dB(A) |

EN 14825 | Colder Climate

| | Low temperature | Medium temperature |
|---|-----------------|--------------------|
| ηs | 203 % | 158 % |
| Prated | 45.00 kW | 42.00 kW |
| SCOP | 5.30 | 4.10 |
| Tbiv | -22 °C | -22 °C |
| TOL | -22 °C | -22 °C |
| Pdh Tj = -7°C | 27.15 kW | 25.15 kW |
| COP Tj = -7°C | 4.93 | 3.68 |
| Cdh Tj = -7 °C | 1.00 | 1.00 |
| Pdh Tj = +2°C | 16.45 kW | 15.47 kW |
| COP Tj = +2°C | 5.54 | 4.50 |
| Cdh Tj = +2 °C | 1.00 | 1.00 |
| Pdh Tj = +7°C | 10.89 kW | 9.95 kW |
| COP Tj = +7°C | 6.28 | 5.36 |
| Cdh Tj = +7 °C | 1.00 | 1.00 |
| Pdh Tj = 12°C | 7.77 kW | 7.74 kW |
| COP Tj = 12°C | 6.22 | 5.40 |
| Cdh Tj = +12 °C | 1.00 | 1.00 |
| Pdh Tj = Tbiv | 42.87 kW | 40.11 kW |
| COP Tj = Tbiv | 4.02 | 2.83 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 42.87 kW | 40.11 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 4.02 | 2.83 |
| WTOL | 65 °C | 65 °C |
| Poff | 8 W | 8 W |
| PTO | 0 W | 0 W |

| | | |
|--|-----------|-----------|
| PSB | 18 W | 18 W |
| PCK | 20 W | 20 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Q _{he} | 21023 kWh | 24990 kWh |

Water/Water

EN 14511-4 | Heating

| | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 47 dB(A) | 47 dB(A) |
| Sound power level outdoor | 0 dB(A) | 0 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|---|-----------------|--------------------|
| η_s | 244 % | 194 % |
| Prated | 58.00 kW | 52.00 kW |
| SCOP | 6.30 | 5.05 |
| T _{biv} | -10 °C | -10 °C |
| TOL | -10 °C | -10 °C |
| P _{dh} T _j = -7°C | 51.30 kW | 46.00 kW |
| COP T _j = -7°C | 5.20 | 3.65 |
| C _{dh} T _j = -7 °C | 1.00 | 1.00 |
| P _{dh} T _j = +2°C | 33.97 kW | 27.75 kW |
| COP T _j = +2°C | 6.13 | 4.90 |
| C _{dh} T _j = +2 °C | 1.00 | 1.00 |
| P _{dh} T _j = +7°C | 20.10 kW | 18.00 kW |
| COP T _j = +7°C | 7.30 | 6.34 |
| C _{dh} T _j = +7 °C | 0.99 | 0.99 |
| P _{dh} T _j = 12°C | 9.00 kW | 8.00 kW |
| COP T _j = 12°C | 7.50 | 6.34 |
| C _{dh} T _j = +12 °C | 0.98 | 0.98 |
| P _{dh} T _j = T _{biv} | 57.80 kW | 51.93 kW |
| COP T _j = T _{biv} | 5.04 | 3.53 |
| P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh} | 57.80 kW | 51.93 kW |
| COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh} | 5.04 | 3.53 |
| WTOL | 65 °C | 65 °C |
| P _{off} | 8 W | 8 W |

| | | |
|--|-----------|-----------|
| PTO | 30 W | 20 W |
| PSB | 18 W | 18 W |
| PCK | 20 W | 20 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Q _{he} | 19008 kWh | 21282 kWh |

EN 12102-1 | Colder Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 47 dB(A) | 47 dB(A) |
| Sound power level outdoor | 0 dB(A) | 0 dB(A) |

EN 14825 | Colder Climate

| | Low temperature | Medium temperature |
|---|-----------------|--------------------|
| η_s | 252 % | 204 % |
| Prated | 58.00 kW | 52.00 kW |
| SCOP | 6.50 | 5.29 |
| T _{biv} | -22 °C | -22 °C |
| TOL | -22 °C | -22 °C |
| P _{dh} T _j = -7°C | 35.10 kW | 31.50 kW |
| COP T _j = -7°C | 6.13 | 4.50 |
| C _{dh} T _j = -7 °C | 1.00 | 1.00 |
| P _{dh} T _j = +2°C | 21.50 kW | 19.20 kW |
| COP T _j = +2°C | 7.00 | 6.20 |
| C _{dh} T _j = +2 °C | 0.99 | 0.99 |
| P _{dh} T _j = +7°C | 13.80 kW | 12.50 kW |
| COP T _j = +7°C | 7.00 | 6.20 |
| C _{dh} T _j = +7 °C | 0.99 | 0.99 |
| P _{dh} T _j = 12°C | 9.00 kW | 8.00 kW |
| COP T _j = 12°C | 7.00 | 6.20 |
| C _{dh} T _j = +12 °C | 0.98 | 0.99 |
| P _{dh} T _j = T _{biv} | 57.79 kW | 51.90 kW |
| COP T _j = T _{biv} | 5.04 | 3.53 |
| P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh} | 57.79 kW | 51.90 kW |
| COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh} | 5.04 | 3.53 |
| WTOL | 65 °C | 65 °C |
| P _{off} | 8 W | 8 W |
| PTO | 30 W | 20 W |
| PSB | 18 W | 18 W |
| PCK | 20 W | 20 W |
| Supplementary Heater: Type of energy input | n/a | n/a |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Q _{he} | 21986 kWh | 24241 kWh |