

This information was generated by the HP KEYMARK database on 31 Jul 2023

Summary of	F1x55-6	Reg. No.	012-047
Certificate Holder			
Name	Nibe AB		
Address	Box 14	ZIP	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	F1x55-6		
Heat Pump Type	Brine/Water and Water/Water		
Refrigerant	R407c		
Mass of Refrigerant	1.16 kg		
Certification Date	15.06.2017		

## Model: F1155-6 1x230

Configure model	
Model name	F1155-6 1x230
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Brine/Water Heat Pump

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.15 kW	2.78 kW
El input	0.67 kW	0.93 kW
COP	4.72	2.99

### Colder Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	211 %	157 %
Prated	5.50 kW	5.50 kW
SCOP	5.48	4.13
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.40 kW	3.40 kW
COP Tj = -7°C	5.17	3.77
Cdh Tj = -7 °C		
Pdh Tj = +2°C	2.10 kW	2.10 kW
COP Tj = +2°C	5.91	4.51
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.40 kW	1.40 kW
COP Tj = +7°C	6.36	5.12
Cdh Tj = +7 °C		
Pdh Tj = 12°C	1.30 kW	1.20 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP Tj = 12°C	4.15	4.81
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	5.40 kW	5.50 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2481 kWh	3287 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>
-----------------

This information was generated by the HP KEYMARK database on 31 Jul 2023

	Low temperature	Medium temperature
$\eta_s$	200 %	150 %
Prated	5.50 kW	5.50 kW
SCOP	5.20	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	5.00 kW
COP Tj = -7°C	4.37	3.06
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	5.24	3.97
Pdh Tj = +7°C	2.00 kW	2.00 kW
COP Tj = +7°C	5.92	4.63
Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	5.95	4.86
Pdh Tj = Tbiv	5.40 kW	5.40 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 31 Jul 2023

Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2188 kWh	2875 kWh

Water/Water Heat Pump

## Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	4.30 kW	3.82 kW
El input	0.66 kW	1.00 kW
COP	6.00	3.83

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	282 %	222 %
Prated	7.00 kW	7.00 kW
SCOP	7.25	5.75
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.30 kW	4.30 kW
COP Tj = -7°C	7.00	5.39
Pdh Tj = +2°C	2.70 kW	2.70 kW
COP Tj = +2°C	7.83	6.21
Pdh Tj = +7°C	1.80 kW	1.80 kW
COP Tj = +7°C	8.14	6.85
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.70	6.64
Pdh Tj = Tbiv	7.00 kW	7.00 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP Tj = Tbiv	5.79	4.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.79	4.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.95	0.96
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2378 kWh	3005 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	270 %	214 %



This information was generated by the HP KEYMARK database on 31 Jul 2023

Prated	7.00 kW	7.00 kW
SCOP	6.95	5.55
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.30 kW
COP Tj = -7°C	6.07	4.52
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	7.09	5.62
Pdh Tj = +7°C	2.50 kW	2.50 kW
COP Tj = +7°C	7.84	6.34
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.97	6.57
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.79	4.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W

This information was generated by the HP KEYMARK database on 31 Jul 2023

PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2078 kWh	2611 kWh

## Model: F1155-6 PC 1x230

Configure model	
Model name	F1155-6 PC 1x230
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Brine/Water Heat Pump

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.15 kW	2.78 kW
El input	0.67 kW	0.93 kW
COP	4.72	2.99

### Colder Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	211 %	157 %
Prated	5.50 kW	5.50 kW
SCOP	5.48	4.13
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.40 kW	3.40 kW
COP Tj = -7°C	5.17	3.77
Cdh Tj = -7 °C		
Pdh Tj = +2°C	2.10 kW	2.10 kW
COP Tj = +2°C	5.91	4.51
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.40 kW	1.40 kW
COP Tj = +7°C	6.36	5.12
Cdh Tj = +7 °C		
Pdh Tj = 12°C	1.30 kW	1.20 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP Tj = 12°C	4.15	4.81
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	5.40 kW	5.50 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2481 kWh	3287 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>
-----------------

This information was generated by the HP KEYMARK database on 31 Jul 2023

	Low temperature	Medium temperature
$\eta_s$	200 %	150 %
Prated	5.50 kW	5.50 kW
SCOP	5.20	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	5.00 kW
COP Tj = -7°C	4.37	3.06
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	5.24	3.97
Pdh Tj = +7°C	2.00 kW	2.00 kW
COP Tj = +7°C	5.92	4.63
Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	5.95	4.86
Pdh Tj = Tbiv	5.40 kW	5.40 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 31 Jul 2023

Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2188 kWh	2875 kWh

Water/Water Heat Pump

## Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	4.30 kW	3.82 kW
El input	0.66 kW	1.00 kW
COP	6.00	3.83

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	282 %	222 %
Prated	7.00 kW	7.00 kW
SCOP	7.25	5.75
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.30 kW	4.30 kW
COP Tj = -7°C	7.00	5.39
Pdh Tj = +2°C	2.70 kW	2.70 kW
COP Tj = +2°C	7.83	6.21
Pdh Tj = +7°C	1.80 kW	1.80 kW
COP Tj = +7°C	8.14	6.85
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.70	6.64
Pdh Tj = Tbiv	7.00 kW	7.00 kW



This information was generated by the HP KEYMARK database on 31 Jul 2023

COP $T_j = T_{biv}$	5.79	4.21
P <sub>dh</sub> $T_j = TOL$ or P <sub>dh</sub> $T_j = T_{designh}$ if $TOL < T_{designh}$	7.00 kW	7.00 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	5.79	4.21
C <sub>dh</sub> $T_j = TOL$ or P <sub>dh</sub> $T_j = T_{designh}$ if $TOL < T_{designh}$	0.95	0.96
WTOL	65 °C	65 °C
P <sub>off</sub>	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2378 kWh	3005 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	270 %	214 %

This information was generated by the HP KEYMARK database on 31 Jul 2023

Prated	7.00 kW	7.00 kW
SCOP	6.95	5.55
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.30 kW
COP Tj = -7°C	6.07	4.52
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	7.09	5.62
Pdh Tj = +7°C	2.50 kW	2.50 kW
COP Tj = +7°C	7.84	6.34
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.97	6.57
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.79	4.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W

This information was generated by the HP KEYMARK database on 31 Jul 2023

PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2078 kWh	2611 kWh

## Model: F1155-6 3x400

Configure model	
Model name	F1155-6 3x400
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Brine/Water Heat Pump

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.15 kW	2.78 kW
El input	0.67 kW	0.93 kW
COP	4.72	2.99

### Colder Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	211 %	157 %
Prated	5.50 kW	5.50 kW
SCOP	5.48	4.13
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.40 kW	3.40 kW
COP Tj = -7°C	5.17	3.77
Cdh Tj = -7 °C		
Pdh Tj = +2°C	2.10 kW	2.10 kW
COP Tj = +2°C	5.91	4.51
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.40 kW	1.40 kW
COP Tj = +7°C	6.36	5.12
Cdh Tj = +7 °C		
Pdh Tj = 12°C	1.30 kW	1.20 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP Tj = 12°C	4.15	4.81
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	5.40 kW	5.50 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2481 kWh	3287 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>
-----------------

This information was generated by the HP KEYMARK database on 31 Jul 2023

	Low temperature	Medium temperature
$\eta_s$	200 %	150 %
Prated	5.50 kW	5.50 kW
SCOP	5.20	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	5.00 kW
COP Tj = -7°C	4.37	3.06
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	5.24	3.97
Pdh Tj = +7°C	2.00 kW	2.00 kW
COP Tj = +7°C	5.92	4.63
Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	5.95	4.86
Pdh Tj = Tbiv	5.40 kW	5.40 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 31 Jul 2023

Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2188 kWh	2875 kWh

Water/Water Heat Pump

## Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	4.30 kW	3.82 kW
El input	0.66 kW	1.00 kW
COP	6.00	3.83



## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	282 %	222 %
Prated	7.00 kW	7.00 kW
SCOP	7.25	5.75
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.30 kW	4.30 kW
COP Tj = -7°C	7.00	5.39
Pdh Tj = +2°C	2.70 kW	2.70 kW
COP Tj = +2°C	7.83	6.21
Pdh Tj = +7°C	1.80 kW	1.80 kW
COP Tj = +7°C	8.14	6.85
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.70	6.64
Pdh Tj = Tbiv	7.00 kW	7.00 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP $T_j = T_{biv}$	5.79	4.21
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	7.00 kW	7.00 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	5.79	4.21
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.95	0.96
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption $Q_{he}$	2378 kWh	3005 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	270 %	214 %

This information was generated by the HP KEYMARK database on 31 Jul 2023

Prated	7.00 kW	7.00 kW
SCOP	6.95	5.55
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.30 kW
COP Tj = -7°C	6.07	4.52
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	7.09	5.62
Pdh Tj = +7°C	2.50 kW	2.50 kW
COP Tj = +7°C	7.84	6.34
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.97	6.57
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.79	4.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W

This information was generated by the HP KEYMARK database on 31 Jul 2023

PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2078 kWh	2611 kWh

## Model: F1155-6 PC3x400

Configure model	
Model name	F1155-6 PC3x400
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Brine/Water Heat Pump

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.15 kW	2.78 kW
El input	0.67 kW	0.93 kW
COP	4.72	2.99

### Colder Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	211 %	157 %
Prated	5.50 kW	5.50 kW
SCOP	5.48	4.13
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.40 kW	3.40 kW
COP Tj = -7°C	5.17	3.77
Cdh Tj = -7 °C		
Pdh Tj = +2°C	2.10 kW	2.10 kW
COP Tj = +2°C	5.91	4.51
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.40 kW	1.40 kW
COP Tj = +7°C	6.36	5.12
Cdh Tj = +7 °C		
Pdh Tj = 12°C	1.30 kW	1.20 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP Tj = 12°C	4.15	4.81
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	5.40 kW	5.50 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2481 kWh	3287 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>
-----------------

This information was generated by the HP KEYMARK database on 31 Jul 2023

	Low temperature	Medium temperature
$\eta_s$	200 %	150 %
Prated	5.50 kW	5.50 kW
SCOP	5.20	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	5.00 kW
COP Tj = -7°C	4.37	3.06
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	5.24	3.97
Pdh Tj = +7°C	2.00 kW	2.00 kW
COP Tj = +7°C	5.92	4.63
Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	5.95	4.86
Pdh Tj = Tbiv	5.40 kW	5.40 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C



This information was generated by the HP KEYMARK database on 31 Jul 2023

Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2188 kWh	2875 kWh

Water/Water Heat Pump

## Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	4.30 kW	3.82 kW
El input	0.66 kW	1.00 kW
COP	6.00	3.83

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	282 %	222 %
Prated	7.00 kW	7.00 kW
SCOP	7.25	5.75
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.30 kW	4.30 kW
COP Tj = -7°C	7.00	5.39
Pdh Tj = +2°C	2.70 kW	2.70 kW
COP Tj = +2°C	7.83	6.21
Pdh Tj = +7°C	1.80 kW	1.80 kW
COP Tj = +7°C	8.14	6.85
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.70	6.64
Pdh Tj = Tbiv	7.00 kW	7.00 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP $T_j = T_{biv}$	5.79	4.21
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	7.00 kW	7.00 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	5.79	4.21
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.95	0.96
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption $Q_{he}$	2378 kWh	3005 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	270 %	214 %

This information was generated by the HP KEYMARK database on 31 Jul 2023

Prated	7.00 kW	7.00 kW
SCOP	6.95	5.55
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.30 kW
COP Tj = -7°C	6.07	4.52
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	7.09	5.62
Pdh Tj = +7°C	2.50 kW	2.50 kW
COP Tj = +7°C	7.84	6.34
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.97	6.57
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.79	4.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W

This information was generated by the HP KEYMARK database on 31 Jul 2023

PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2078 kWh	2611 kWh

## Model: F1255-6 1x230

Configure model	
Model name	F1255-6 1x230
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Brine/Water Heat Pump

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.15 kW	2.78 kW
El input	0.67 kW	0.93 kW
COP	4.72	2.99

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	211 %	157 %
Prated	5.50 kW	5.50 kW
SCOP	5.48	4.13
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.40 kW	3.40 kW
COP Tj = -7°C	5.17	3.77
Cdh Tj = -7 °C		
Pdh Tj = +2°C	2.10 kW	2.10 kW
COP Tj = +2°C	5.91	4.51
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.40 kW	1.40 kW
COP Tj = +7°C	6.36	5.12
Cdh Tj = +7 °C		

This information was generated by the HP KEYMARK database on 31 Jul 2023

Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	4.15	4.81
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	5.40 kW	5.50 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2481 kWh	3287 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)



This information was generated by the HP KEYMARK database on 31 Jul 2023

**EN 14825**

	Low temperature	Medium temperature
$\eta_s$	200 %	150 %
Prated	5.50 kW	5.50 kW
SCOP	5.20	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	5.00 kW
COP Tj = -7°C	4.37	3.06
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	5.24	3.97
Pdh Tj = +7°C	2.00 kW	2.00 kW
COP Tj = +7°C	5.92	4.63
Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	5.95	4.86
Pdh Tj = Tbiv	5.40 kW	5.40 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 31 Jul 2023

Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2188 kWh	2875 kWh

## Domestic Hot Water (DHW)

### Colder Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	102 %
COP	2.55
Heating up time	02:23 h:min
Standby power input	50.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	245 l

### Average Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	102 %
COP	2.55
Heating up time	02:23 h:min
Standby power input	50.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	245 l

Water/Water Heat Pump

## Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	3.82 kW
El input	0.66 kW	1.00 kW
COP	6.00	3.83

## Colder Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	282 %	222 %
Prated	7.00 kW	7.00 kW
SCOP	7.25	5.75
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.30 kW	4.30 kW
COP Tj = -7°C	7.00	5.39
Pdh Tj = +2°C	2.70 kW	2.70 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP Tj = +2°C	7.83	6.21
Pdh Tj = +7°C	1.80 kW	1.80 kW
COP Tj = +7°C	8.14	6.85
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.70	6.64
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.79	4.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.95	0.96
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2378 kWh	3005 kWh

## Average Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	270 %	214 %
Prated	7.00 kW	7.00 kW
SCOP	6.95	5.55
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.30 kW
COP Tj = -7°C	6.07	4.52
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	7.09	5.62
Pdh Tj = +7°C	2.50 kW	2.50 kW
COP Tj = +7°C	7.84	6.34
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.97	6.57
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21

This information was generated by the HP KEYMARK database on 31 Jul 2023

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	7.00 kW	7.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	5.79	4.21
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.96	0.97
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption $Q_{he}$	2078 kWh	2611 kWh

## Domestic Hot Water (DHW)

### Colder Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	117 %
COP	2.93
Heating up time	02:09 h:min
Standby power input	45.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	240 l

## Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	117 %
COP	2.93
Heating up time	02:09 h:min
Standby power input	45.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	240 l



## Model: F1255-6 PC 1x230

Configure model	
Model name	F1255-6 PC 1x230
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Brine/Water Heat Pump

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.15 kW	2.78 kW
El input	0.67 kW	0.93 kW
COP	4.72	2.99

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	211 %	157 %
Prated	5.50 kW	5.50 kW
SCOP	5.48	4.13
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.40 kW	3.40 kW
COP Tj = -7°C	5.17	3.77
Cdh Tj = -7 °C		
Pdh Tj = +2°C	2.10 kW	2.10 kW
COP Tj = +2°C	5.91	4.51
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.40 kW	1.40 kW
COP Tj = +7°C	6.36	5.12
Cdh Tj = +7 °C		

This information was generated by the HP KEYMARK database on 31 Jul 2023

Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	4.15	4.81
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	5.40 kW	5.50 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2481 kWh	3287 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

This information was generated by the HP KEYMARK database on 31 Jul 2023

**EN 14825**

	Low temperature	Medium temperature
$\eta_s$	200 %	150 %
Prated	5.50 kW	5.50 kW
SCOP	5.20	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	5.00 kW
COP Tj = -7°C	4.37	3.06
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	5.24	3.97
Pdh Tj = +7°C	2.00 kW	2.00 kW
COP Tj = +7°C	5.92	4.63
Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	5.95	4.86
Pdh Tj = Tbiv	5.40 kW	5.40 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 31 Jul 2023

Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2188 kWh	2875 kWh

## Domestic Hot Water (DHW)

### Colder Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	102 %
COP	2.55
Heating up time	02:23 h:min
Standby power input	61.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	245 l

### Average Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	102 %
COP	2.55
Heating up time	02:23 h:min
Standby power input	61.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	245 l

Water/Water Heat Pump

## Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	3.82 kW
El input	0.66 kW	1.00 kW
COP	6.00	3.83

## Colder Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	282 %	222 %
Prated	7.00 kW	7.00 kW
SCOP	7.25	5.75
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.30 kW	4.30 kW
COP Tj = -7°C	7.00	5.39
Pdh Tj = +2°C	2.70 kW	2.70 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP Tj = +2°C	7.83	6.21
Pdh Tj = +7°C	1.80 kW	1.80 kW
COP Tj = +7°C	8.14	6.85
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.70	6.64
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.79	4.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.95	0.96
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2378 kWh	3005 kWh

## Average Climate



This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	270 %	214 %
Prated	7.00 kW	7.00 kW
SCOP	6.95	5.55
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.30 kW
COP Tj = -7°C	6.07	4.52
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	7.09	5.62
Pdh Tj = +7°C	2.50 kW	2.50 kW
COP Tj = +7°C	7.84	6.34
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.97	6.57
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21

This information was generated by the HP KEYMARK database on 31 Jul 2023

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	7.00 kW	7.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	5.79	4.21
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.96	0.97
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption $Q_{he}$	2078 kWh	2611 kWh

## Domestic Hot Water (DHW)

### Colder Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	117 %
COP	2.93
Heating up time	02:09 h:min
Standby power input	55.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	240 l

## Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	117 %
COP	2.93
Heating up time	02:09 h:min
Standby power input	55.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	240 l

## Model: F1255-6 3x400

Configure model	
Model name	F1255-6 3x400
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Brine/Water Heat Pump

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.15 kW	2.78 kW
El input	0.67 kW	0.93 kW
COP	4.72	2.99

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	211 %	157 %
Prated	5.50 kW	5.50 kW
SCOP	5.48	4.13
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.40 kW	3.40 kW
COP Tj = -7°C	5.17	3.77
Cdh Tj = -7 °C		
Pdh Tj = +2°C	2.10 kW	2.10 kW
COP Tj = +2°C	5.91	4.51
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.40 kW	1.40 kW
COP Tj = +7°C	6.36	5.12
Cdh Tj = +7 °C		

This information was generated by the HP KEYMARK database on 31 Jul 2023

Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	4.15	4.81
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	5.40 kW	5.50 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2481 kWh	3287 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

This information was generated by the HP KEYMARK database on 31 Jul 2023

**EN 14825**

	Low temperature	Medium temperature
$\eta_s$	200 %	150 %
Prated	5.50 kW	5.50 kW
SCOP	5.20	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	5.00 kW
COP Tj = -7°C	4.37	3.06
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	5.24	3.97
Pdh Tj = +7°C	2.00 kW	2.00 kW
COP Tj = +7°C	5.92	4.63
Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	5.95	4.86
Pdh Tj = Tbiv	5.40 kW	5.40 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 31 Jul 2023

Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2188 kWh	2875 kWh

## Domestic Hot Water (DHW)

### Colder Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	102 %
COP	2.55
Heating up time	02:23 h:min
Standby power input	50.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	245 l

### Average Climate



<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	102 %
COP	2.55
Heating up time	02:23 h:min
Standby power input	50.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	245 l

Water/Water Heat Pump

## Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	3.82 kW
El input	0.66 kW	1.00 kW
COP	6.00	3.83

## Colder Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	282 %	222 %
Prated	7.00 kW	7.00 kW
SCOP	7.25	5.75
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.30 kW	4.30 kW
COP Tj = -7°C	7.00	5.39
Pdh Tj = +2°C	2.70 kW	2.70 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP Tj = +2°C	7.83	6.21
Pdh Tj = +7°C	1.80 kW	1.80 kW
COP Tj = +7°C	8.14	6.85
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.70	6.64
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.79	4.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.95	0.96
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2378 kWh	3005 kWh

## Average Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	270 %	214 %
Prated	7.00 kW	7.00 kW
SCOP	6.95	5.55
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.30 kW
COP Tj = -7°C	6.07	4.52
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	7.09	5.62
Pdh Tj = +7°C	2.50 kW	2.50 kW
COP Tj = +7°C	7.84	6.34
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.97	6.57
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21

This information was generated by the HP KEYMARK database on 31 Jul 2023

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	7.00 kW	7.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	5.79	4.21
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.96	0.97
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption $Q_{he}$	2078 kWh	2611 kWh

## Domestic Hot Water (DHW)

### Colder Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	117 %
COP	2.93
Heating up time	02:09 h:min
Standby power input	45.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	240 l

## Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	117 %
COP	2.93
Heating up time	02:09 h:min
Standby power input	45.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	240 l

## Model: F1255-6 PC 3x400

Configure model	
Model name	F1255-6 PC 3x400
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Brine/Water Heat Pump

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.15 kW	2.78 kW
El input	0.67 kW	0.93 kW
COP	4.72	2.99

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	211 %	157 %
Prated	5.50 kW	5.50 kW
SCOP	5.48	4.13
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.40 kW	3.40 kW
COP Tj = -7°C	5.17	3.77
Cdh Tj = -7 °C		
Pdh Tj = +2°C	2.10 kW	2.10 kW
COP Tj = +2°C	5.91	4.51
Cdh Tj = +2 °C		
Pdh Tj = +7°C	1.40 kW	1.40 kW
COP Tj = +7°C	6.36	5.12
Cdh Tj = +7 °C		



This information was generated by the HP KEYMARK database on 31 Jul 2023

Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	4.15	4.81
Cdh Tj = +12 °C		
Pdh Tj = Tbiv	5.40 kW	5.50 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2481 kWh	3287 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)

This information was generated by the HP KEYMARK database on 31 Jul 2023

**EN 14825**

	Low temperature	Medium temperature
$\eta_s$	200 %	150 %
Prated	5.50 kW	5.50 kW
SCOP	5.20	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	5.00 kW
COP Tj = -7°C	4.37	3.06
Pdh Tj = +2°C	3.10 kW	3.00 kW
COP Tj = +2°C	5.24	3.97
Pdh Tj = +7°C	2.00 kW	2.00 kW
COP Tj = +7°C	5.92	4.63
Pdh Tj = 12°C	1.30 kW	1.20 kW
COP Tj = 12°C	5.95	4.86
Pdh Tj = Tbiv	5.40 kW	5.40 kW
COP Tj = Tbiv	4.15	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.40 kW	5.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.15	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 31 Jul 2023

Poff	2 W	2 W
PTO	10 W	7 W
PSB	7 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	2188 kWh	2875 kWh

## Domestic Hot Water (DHW)

### Colder Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	102 %
COP	2.55
Heating up time	02:23 h:min
Standby power input	61.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	245 l

### Average Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	102 %
COP	2.55
Heating up time	02:23 h:min
Standby power input	61.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	245 l

Water/Water Heat Pump

## Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	3.82 kW
El input	0.66 kW	1.00 kW
COP	6.00	3.83

## Colder Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	282 %	222 %
Prated	7.00 kW	7.00 kW
SCOP	7.25	5.75
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.30 kW	4.30 kW
COP Tj = -7°C	7.00	5.39
Pdh Tj = +2°C	2.70 kW	2.70 kW

This information was generated by the HP KEYMARK database on 31 Jul 2023

COP Tj = +2°C	7.83	6.21
Pdh Tj = +7°C	1.80 kW	1.80 kW
COP Tj = +7°C	8.14	6.85
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.70	6.64
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.00 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.79	4.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.95	0.96
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2378 kWh	3005 kWh

## Average Climate

This information was generated by the HP KEYMARK database on 31 Jul 2023

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	270 %	214 %
Prated	7.00 kW	7.00 kW
SCOP	6.95	5.55
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	6.30 kW
COP Tj = -7°C	6.07	4.52
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	7.09	5.62
Pdh Tj = +7°C	2.50 kW	2.50 kW
COP Tj = +7°C	7.84	6.34
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	7.97	6.57
Pdh Tj = Tbiv	7.00 kW	7.00 kW
COP Tj = Tbiv	5.79	4.21

This information was generated by the HP KEYMARK database on 31 Jul 2023

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	7.00 kW	7.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	5.79	4.21
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.96	0.97
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	18 W	15 W
PSB	10 W	7 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption $Q_{he}$	2078 kWh	2611 kWh

## Domestic Hot Water (DHW)

### Colder Climate



This information was generated by the HP KEYMARK database on 31 Jul 2023

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	117 %
COP	2.93
Heating up time	02:09 h:min
Standby power input	55.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	240 l

## Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	117 %
COP	2.93
Heating up time	02:09 h:min
Standby power input	55.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	240 l