

Subtype NIMBUS 90 S - ARIANEXT 90 S - AEROTOP SPLIT 09

Certificate Holder	Ariston Thermo Group
Address	Viale Aristide Merloni 45
ZIP	I-60044
City	Fabriano (AN)
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	NIMBUS 90 S - ARIANEXT 90 S - AEROTOP SPLIT 09
Registration number	ICIM-PDC-000001
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	4.3 kg
Certification Date	19.12.2017

Model AEROTOP SPLIT 09M-R

Model name	AEROTOP SPLIT 09M-R
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η _s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW

COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
Pdesignh	14.97 kW	13.72 kW
ηs	150 %	106 %
Prated	14.97 kW	13.72 kW
SCOP	3.84	2.73
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.06 kW	8.30 kW
COP Tj = -7°C	3.65	2.75
Pdh Tj = +2°C	5.53 kW	4.86 kW
COP Tj = +2°C	5.01	3.60
Pdh Tj = +7°C	3.71 kW	3.61 kW
COP Tj = +7°C	6.51	5.09
Pdh Tj = 12°C	4.44 kW	4.30 kW
COP Tj = 12°C	9.48	7.53
Pdh Tj = Tbiv	9.06 kW	8.30 kW
COP Tj = Tbiv	3.65	2.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.33 kW	2.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	0.54

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
Pdesignh	6.86 kW	6.27 kW
η_s	245 %	153 %
Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1477 kWh	2149 kWh
-------------------------------	----------	----------

Model ARIANEXT PLUS 90 S-T LINK

Model name	ARIANEXT PLUS 90 S-T LINK
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW

COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
Pdesignh	14.97 kW	13.72 kW
ηs	150 %	106 %
Prated	14.97 kW	13.72 kW
SCOP	3.84	2.73
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.06 kW	8.30 kW
COP Tj = -7°C	3.65	2.75
Pdh Tj = +2°C	5.53 kW	4.86 kW
COP Tj = +2°C	5.01	3.60
Pdh Tj = +7°C	3.71 kW	3.61 kW
COP Tj = +7°C	6.51	5.09
Pdh Tj = 12°C	4.44 kW	4.30 kW
COP Tj = 12°C	9.48	7.53
Pdh Tj = Tbiv	9.06 kW	8.30 kW
COP Tj = Tbiv	3.65	2.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.33 kW	2.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	0.54

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
Pdesignh	6.86 kW	6.27 kW
η_s	245 %	153 %
Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1477 kWh	2149 kWh
-------------------------------	----------	----------

Model ARIANEXT PLUS 90 S-T

Model name	ARIANEXT PLUS 90 S-T
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η _s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW

COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
Pdesignh	14.97 kW	13.72 kW
ηs	150 %	106 %
Prated	14.97 kW	13.72 kW
SCOP	3.84	2.73
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.06 kW	8.30 kW
COP Tj = -7°C	3.65	2.75
Pdh Tj = +2°C	5.53 kW	4.86 kW
COP Tj = +2°C	5.01	3.60
Pdh Tj = +7°C	3.71 kW	3.61 kW
COP Tj = +7°C	6.51	5.09
Pdh Tj = 12°C	4.44 kW	4.30 kW
COP Tj = 12°C	9.48	7.53
Pdh Tj = Tbiv	9.06 kW	8.30 kW
COP Tj = Tbiv	3.65	2.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.33 kW	2.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	0.54

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
Pdesignh	6.86 kW	6.27 kW
η_s	245 %	153 %
Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1477 kWh	2149 kWh
-------------------------------	----------	----------

Model NIMBUS PLUS 90 S-T NET

Model name	NIMBUS PLUS 90 S-T NET
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η _s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW

COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
Pdesignh	14.97 kW	13.72 kW
ηs	150 %	106 %
Prated	14.97 kW	13.72 kW
SCOP	3.84	2.73
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.06 kW	8.30 kW
COP Tj = -7°C	3.65	2.75
Pdh Tj = +2°C	5.53 kW	4.86 kW
COP Tj = +2°C	5.01	3.60
Pdh Tj = +7°C	3.71 kW	3.61 kW
COP Tj = +7°C	6.51	5.09
Pdh Tj = 12°C	4.44 kW	4.30 kW
COP Tj = 12°C	9.48	7.53
Pdh Tj = Tbiv	9.06 kW	8.30 kW
COP Tj = Tbiv	3.65	2.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.33 kW	2.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	0.54

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
Pdesignh	6.86 kW	6.27 kW
η_s	245 %	153 %
Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1477 kWh	2149 kWh
-------------------------------	----------	----------

Model AEROTOP SPLIT 09M-CR

Model name	AEROTOP SPLIT 09M-CR
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model ARIANEXT COMPACT 90 S-T LINK

Model name	ARIANEXT COMPACT 90 S-T LINK
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model ARIANEXT FLEX 90 S-T LINK

Model name	ARIANEXT FLEX 90 S-T LINK
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model ARIANEXT FLEX 90 S-T - 300 LINK

Model name	ARIANEXT FLEX 90 S-T - 300 LINK
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XXL
Efficiency η_{DHW}	122 %
COP	3.06
Heating up time	01:52 h:min
Standby power input	53.0 W
Reference hot water temperature	54.5 °C
Mixed water at 40°C	434 l

EN 16147 | Colder Climate

Declared load profile	XXL
Efficiency η_{DHW}	97 %
COP	2.43
Heating up time	02:15 h:min
Standby power input	63.0 W
Reference hot water temperature	53.4 °C
Mixed water at 40°C	422 l

EN 16147 | Warmer Climate

Declared load profile	XXL
Efficiency η_{DHW}	132 %
COP	3.30
Heating up time	01:34 h:min
Standby power input	48.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	430 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model NIMBUS COMPACT 90 S-T NET

Model name	NIMBUS COMPACT 90 S-T NET
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model NIMBUS FLEX 90 S-T NET

Model name	NIMBUS FLEX 90 S-T NET
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model NIMBUS FLEX 90 S-T - 300 NET

Model name	NIMBUS FLEX 90 S-T - 300 NET
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XXL
Efficiency η_{DHW}	122 %
COP	3.06
Heating up time	01:52 h:min
Standby power input	53.0 W
Reference hot water temperature	54.5 °C
Mixed water at 40°C	434 l

EN 16147 | Colder Climate

Declared load profile	XXL
Efficiency η_{DHW}	97 %
COP	2.43
Heating up time	02:15 h:min
Standby power input	63.0 W
Reference hot water temperature	53.4 °C
Mixed water at 40°C	422 l

EN 16147 | Warmer Climate

Declared load profile	XXL
Efficiency η_{DHW}	132 %
COP	3.30
Heating up time	01:34 h:min
Standby power input	48.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	430 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model ARIANEXT COMPACT 90 S-T

Model name	ARIANEXT COMPACT 90 S-T
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.01
Heating up time	00:47 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	247 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
Prated	10.38 kW	9.38 kW
SCOP	4.80	3.40

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.18 kW	8.30 kW
COP Tj = -7°C	3.32	2.32
Pdh Tj = +2°C	5.60 kW	5.31 kW
COP Tj = +2°C	4.59	3.22
Pdh Tj = +7°C	3.64 kW	3.47 kW
COP Tj = +7°C	5.98	4.38
Pdh Tj = 12°C	4.44 kW	4.22 kW
COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

Model ARIANEXT FLEX 90 S-T

Model name	ARIANEXT FLEX 90 S-T
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.01
Heating up time	00:47 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	247 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
Prated	10.38 kW	9.38 kW
SCOP	4.80	3.40

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.18 kW	8.30 kW
COP Tj = -7°C	3.32	2.32
Pdh Tj = +2°C	5.60 kW	5.31 kW
COP Tj = +2°C	4.59	3.22
Pdh Tj = +7°C	3.64 kW	3.47 kW
COP Tj = +7°C	5.98	4.38
Pdh Tj = 12°C	4.44 kW	4.22 kW
COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

Model ARIANEXT FLEX 90 S-T - 300

Model name	ARIANEXT FLEX 90 S-T - 300
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:52 h:min
Standby power input	61.0 W
Reference hot water temperature	54.4 °C
Mixed water at 40°C	434 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
Prated	10.38 kW	9.38 kW
SCOP	4.80	3.40

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.18 kW	8.30 kW
COP Tj = -7°C	3.32	2.32
Pdh Tj = +2°C	5.60 kW	5.31 kW
COP Tj = +2°C	4.59	3.22
Pdh Tj = +7°C	3.64 kW	3.47 kW
COP Tj = +7°C	5.98	4.38
Pdh Tj = 12°C	4.44 kW	4.22 kW
COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

Model AEROTOP SPLIT 09M-RX

Model name	AEROTOP SPLIT 09M-RX
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η _s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW

COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
Pdesignh	14.97 kW	13.72 kW
ηs	150 %	106 %
Prated	14.97 kW	13.72 kW
SCOP	3.84	2.73
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.06 kW	8.30 kW
COP Tj = -7°C	3.65	2.75
Pdh Tj = +2°C	5.53 kW	4.86 kW
COP Tj = +2°C	5.01	3.60
Pdh Tj = +7°C	3.71 kW	3.61 kW
COP Tj = +7°C	6.51	5.09
Pdh Tj = 12°C	4.44 kW	4.30 kW
COP Tj = 12°C	9.48	7.53
Pdh Tj = Tbiv	9.06 kW	8.30 kW
COP Tj = Tbiv	3.65	2.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.33 kW	2.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	0.54

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
Pdesignh	6.86 kW	6.27 kW
η_s	245 %	153 %
Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1477 kWh	2149 kWh
-------------------------------	----------	----------

Model ARIANEXT PLUS 90 S LINK

Model name	ARIANEXT PLUS 90 S LINK
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η _s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW

COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
Pdesignh	14.97 kW	13.72 kW
ηs	150 %	106 %
Prated	14.97 kW	13.72 kW
SCOP	3.84	2.73
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.06 kW	8.30 kW
COP Tj = -7°C	3.65	2.75
Pdh Tj = +2°C	5.53 kW	4.86 kW
COP Tj = +2°C	5.01	3.60
Pdh Tj = +7°C	3.71 kW	3.61 kW
COP Tj = +7°C	6.51	5.09
Pdh Tj = 12°C	4.44 kW	4.30 kW
COP Tj = 12°C	9.48	7.53
Pdh Tj = Tbiv	9.06 kW	8.30 kW
COP Tj = Tbiv	3.65	2.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.33 kW	2.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	0.54

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
Pdesignh	6.86 kW	6.27 kW
η_s	245 %	153 %
Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1477 kWh	2149 kWh
-------------------------------	----------	----------

Model ARIANEXT PLUS 90 S

Model name	ARIANEXT PLUS 90 S
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW

COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
Pdesignh	14.97 kW	13.72 kW
ηs	150 %	106 %
Prated	14.97 kW	13.72 kW
SCOP	3.84	2.73
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.06 kW	8.30 kW
COP Tj = -7°C	3.65	2.75
Pdh Tj = +2°C	5.53 kW	4.86 kW
COP Tj = +2°C	5.01	3.60
Pdh Tj = +7°C	3.71 kW	3.61 kW
COP Tj = +7°C	6.51	5.09
Pdh Tj = 12°C	4.44 kW	4.30 kW
COP Tj = 12°C	9.48	7.53
Pdh Tj = Tbiv	9.06 kW	8.30 kW
COP Tj = Tbiv	3.65	2.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.33 kW	2.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	0.54

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
Pdesignh	6.86 kW	6.27 kW
η_s	245 %	153 %
Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1477 kWh	2149 kWh
-------------------------------	----------	----------

Model NIMBUS PLUS 90 S NET

Model name	NIMBUS PLUS 90 S NET
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η _s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW

COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
Pdesignh	14.97 kW	13.72 kW
ηs	150 %	106 %
Prated	14.97 kW	13.72 kW
SCOP	3.84	2.73
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.06 kW	8.30 kW
COP Tj = -7°C	3.65	2.75
Pdh Tj = +2°C	5.53 kW	4.86 kW
COP Tj = +2°C	5.01	3.60
Pdh Tj = +7°C	3.71 kW	3.61 kW
COP Tj = +7°C	6.51	5.09
Pdh Tj = 12°C	4.44 kW	4.30 kW
COP Tj = 12°C	9.48	7.53
Pdh Tj = Tbiv	9.06 kW	8.30 kW
COP Tj = Tbiv	3.65	2.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.33 kW	2.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	0.54

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
Pdesignh	6.86 kW	6.27 kW
η_s	245 %	153 %
Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1477 kWh	2149 kWh
-------------------------------	----------	----------

Model AEROTOP SPLIT 09M-CRX

Model name	AEROTOP SPLIT 09M-CRX
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model ARIANEXT COMPACT 90 S LINK

Model name	ARIANEXT COMPACT 90 S LINK
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model ARIANEXT FLEX 90 S - 300 LINK

Model name	ARIANEXT FLEX 90 S - 300 LINK
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XXL
Efficiency η_{DHW}	122 %
COP	3.06
Heating up time	01:52 h:min
Standby power input	53.0 W
Reference hot water temperature	54.5 °C
Mixed water at 40°C	434 l

EN 16147 | Colder Climate

Declared load profile	XXL
Efficiency η_{DHW}	97 %
COP	2.43
Heating up time	02:15 h:min
Standby power input	63.0 W
Reference hot water temperature	53.4 °C
Mixed water at 40°C	422 l

EN 16147 | Warmer Climate

Declared load profile	XXL
Efficiency η_{DHW}	132 %
COP	3.30
Heating up time	01:34 h:min
Standby power input	48.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	430 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model ARIANEXT FLEX 90 S LINK

Model name	ARIANEXT FLEX 90 S LINK
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model NIMBUS COMPACT 90 S NET

Model name	NIMBUS COMPACT 90 S NET
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model NIMBUS FLEX 90 S NET

Model name	NIMBUS FLEX 90 S NET
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.56
Heating up time	01:28 h:min
Standby power input	52.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	251 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	89 %
COP	2.15
Heating up time	01:49 h:min
Standby power input	57.0 W
Reference hot water temperature	53.6 °C
Mixed water at 40°C	250 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	111 %
COP	2.70
Heating up time	01:16 h:min
Standby power input	39.0 W
Reference hot water temperature	53.2 °C
Mixed water at 40°C	248 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model NIMBUS FLEX 90 S - 300 NET

Model name	NIMBUS FLEX 90 S - 300 NET
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XXL
Efficiency η_{DHW}	122 %
COP	3.06
Heating up time	01:52 h:min
Standby power input	53.0 W
Reference hot water temperature	54.5 °C
Mixed water at 40°C	434 l

EN 16147 | Colder Climate

Declared load profile	XXL
Efficiency η_{DHW}	97 %
COP	2.43
Heating up time	02:15 h:min
Standby power input	63.0 W
Reference hot water temperature	53.4 °C
Mixed water at 40°C	422 l

EN 16147 | Warmer Climate

Declared load profile	XXL
Efficiency η_{DHW}	132 %
COP	3.30
Heating up time	01:34 h:min
Standby power input	48.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	430 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
P _{rated}	10.38 kW	9.38 kW
SCOP	4.80	3.40
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C
P _{dh} T _j = -7°C	9.18 kW	8.30 kW
COP T _j = -7°C	3.32	2.32
P _{dh} T _j = +2°C	5.60 kW	5.31 kW
COP T _j = +2°C	4.59	3.22
P _{dh} T _j = +7°C	3.64 kW	3.47 kW
COP T _j = +7°C	5.98	4.38
P _{dh} T _j = 12°C	4.44 kW	4.22 kW
COP T _j = 12°C	9.48	6.80
P _{dh} T _j = T _{biv}	9.18 kW	8.30 kW
COP T _j = T _{biv}	3.32	2.32
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.16 kW	9.73 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.78	1.73
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Q _{he}	4468 kWh	5700 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
P _{designh}	14.97 kW	13.72 kW
η _s	150 %	106 %
P _{rated}	14.97 kW	13.72 kW
SCOP	3.84	2.73
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.06 kW	8.30 kW
COP T _j = -7°C	3.65	2.75
P _{dh} T _j = +2°C	5.53 kW	4.86 kW
COP T _j = +2°C	5.01	3.60
P _{dh} T _j = +7°C	3.71 kW	3.61 kW
COP T _j = +7°C	6.51	5.09
P _{dh} T _j = 12°C	4.44 kW	4.30 kW
COP T _j = 12°C	9.48	7.53
P _{dh} T _j = T _{biv}	9.06 kW	8.30 kW
COP T _j = T _{biv}	3.65	2.75
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.33 kW	2.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.17	0.54
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Q _{he}	9620 kWh	12389 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
P _{designh}	6.86 kW	6.27 kW
η _s	245 %	153 %

Prated	6.86 kW	6.27 kW
SCOP	6.20	3.90
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.86 kW	6.27 kW
COP Tj = +2°C	4.10	2.45
Pdh Tj = +7°C	4.46 kW	4.05 kW
COP Tj = +7°C	5.44	3.19
Pdh Tj = 12°C	4.36 kW	4.11 kW
COP Tj = 12°C	8.44	5.72
Pdh Tj = Tbiv	6.86 kW	6.27 kW
COP Tj = Tbiv	4.10	2.45
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.86 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1477 kWh	2149 kWh

Model ARIANEXT COMPACT 90 S

Model name	ARIANEXT COMPACT 90 S
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.01
Heating up time	00:47 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	247 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
Prated	10.38 kW	9.38 kW
SCOP	4.80	3.40

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.18 kW	8.30 kW
COP Tj = -7°C	3.32	2.32
Pdh Tj = +2°C	5.60 kW	5.31 kW
COP Tj = +2°C	4.59	3.22
Pdh Tj = +7°C	3.64 kW	3.47 kW
COP Tj = +7°C	5.98	4.38
Pdh Tj = 12°C	4.44 kW	4.22 kW
COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

Model ARIANEXT FLEX 90 S

Model name	ARIANEXT FLEX 90 S
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.01
Heating up time	00:47 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	247 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
Prated	10.38 kW	9.38 kW
SCOP	4.80	3.40

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.18 kW	8.30 kW
COP Tj = -7°C	3.32	2.32
Pdh Tj = +2°C	5.60 kW	5.31 kW
COP Tj = +2°C	4.59	3.22
Pdh Tj = +7°C	3.64 kW	3.47 kW
COP Tj = +7°C	5.98	4.38
Pdh Tj = 12°C	4.44 kW	4.22 kW
COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh

Model ARIANEXT FLEX 90 S - 300

Model name	ARIANEXT FLEX 90 S - 300
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:52 h:min
Standby power input	61.0 W
Reference hot water temperature	54.4 °C
Mixed water at 40°C	434 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.65 kW	7.67 kW
El input	1.65 kW	2.39 kW
COP	5.25	3.21

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
P _{designh}	10.38 kW	9.38 kW
η_s	189 %	133 %
Prated	10.38 kW	9.38 kW
SCOP	4.80	3.40

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.18 kW	8.30 kW
COP Tj = -7°C	3.32	2.32
Pdh Tj = +2°C	5.60 kW	5.31 kW
COP Tj = +2°C	4.59	3.22
Pdh Tj = +7°C	3.64 kW	3.47 kW
COP Tj = +7°C	5.98	4.38
Pdh Tj = 12°C	4.44 kW	4.22 kW
COP Tj = 12°C	9.48	6.80
Pdh Tj = Tbiv	9.18 kW	8.30 kW
COP Tj = Tbiv	3.32	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.16 kW	9.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	1.73
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	19 W	19 W
PSB	18 W	18 W
PCK	18 W	18 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	0.00 kW
Annual energy consumption Qhe	4468 kWh	5700 kWh