

## Certificate

[Search](#)

[Certificate holders](#)

English ▼ go

## Select search focus

[Search](#)

[Search for certificate holder](#)

## 02. Yutaki S Combi 200L 2.0HP R32

Certificate Holder Johnson Controls-Hitachi AirConditioning Spain  
Ronda Shimizu, 1. Pol. Ind. Can Torrella  
08233 Vacarisses, Barcelona  
Spain  
Reg. No. 041-K002-30/ Rev. 1  
Certification body BRE Energy & Communications Division  
Name of testing CEIS  
laboratory  
Subtype title 02. Yutaki S Combi 200L 2.0HP R32  
Heat Pump Type Outdoor Air/Water  
Refrigerant HFC-32  
Mass of refrigerant 1,200kg  
Certification Date 08.08.2019

01. RAS-2WHVRP RWD-2.0NRWE-200S - Heating Only

### General Data

Power supply 1x230V 50Hz  
Off-peak product Yes

### Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30kW	4.30kW
El input	0.82kW	1.43kW
COP	5.25	3.00
Indoor water flow rate	0.77m <sup>3</sup> /h	0.46m <sup>3</sup> /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

### Average Climate

#### EN 12102-1

Sound power level indoor	37dB(A)	37dB(A)
Sound power level outdoor	61dB(A)	61dB(A)

#### EN 14825

#### Low temperature

#### Medium temperature

$\eta_s$	181%	133%
$P_{rated}$	4.00kW	4.00kW
SCOP	4.60	3.40
$T_{biv}$	-7°C	-7°C
TOL	-10°C	-10°C
Pdh $T_j = -7^\circ\text{C}$	3.54kW	3.50kW
COPd $T_j = -7^\circ\text{C}$	3.20	2.13
Cdh	1.00	1.00
Pdh $T_j = +2^\circ\text{C}$	2.35kW	2.10kW
COPd $T_j = +2^\circ\text{C}$	4.80	3.35
Cdh	1.00	1.00
Pdh $T_j = +7^\circ\text{C}$	3.00kW	2.43kW
COPd $T_j = +7^\circ\text{C}$	6.20	5.15
Cdh	0.90	0.90
Pdh $T_j = +12^\circ\text{C}$	3.05kW	2.80kW
COPd $T_j = +12^\circ\text{C}$	8.30	6.80
Cdh	0.90	0.90
Pdh $T_j = \text{bivalent temperature}$	3.54kW	3.50kW
COPd $T_j = \text{bivalent temperature}$	3.20	2.13
Pdh $T_j = \text{TOL}$	4.00kW	3.10kW
COPd $T_j = \text{TOL}$	2.75	1.90
WTOL	55°C	55°C
$P_{OFF}$	12W	12W
$P_{TO}$	0W	0W
$P_{SB}$	12W	12W
$P_{CK}$	0W	0W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: $P_{SUP}$	0.00kW	0.90kW
Annual energy consumption $Q_{HE}$	1798kWh	2401kWh

### Domestic Hot Water (DHW)

### Average Climate

#### EN 16147

Declared load profile	L
Efficiency $\eta_{dhw}$	132%
COP	3.30
Heating up time	1:43
Standby power input	37.0W

Reference hot water temperature 54.0°C  
 Mixed water at 40°C 263l

02. RAS-2WHVRP RWD-2.0NWE-200S - with cooling kit

General Data

Power supply 1x230V 50Hz  
 Off-peak product Yes

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30kW	4.30kW
EI input	0.82kW	1.43kW
COP	5.25	3.00
Indoor water flow rate	0.77m <sup>3</sup> /h	0.46m <sup>3</sup> /h

EN 14511-4

Shutting off the heat transfer medium flow passed  
 Complete power supply failure passed  
 Starting and operating test passed

Average Climate

EN 12102-1

Sound power level indoor 37dB(A) 37dB(A)  
 Sound power level outdoor 61dB(A) 61dB(A)

EN 14825

	Low temperature	Medium temperature
$\eta_s$	186%	136%
$P_{rated}$	4.00kW	4.00kW
SCOP	4.73	3.48
$T_{biv}$	-7°C	-7°C
TOL	-10°C	-10°C
Pdh $T_j = -7°C$	3.54kW	3.50kW
COPd $T_j = -7°C$	3.20	2.13
Cdh	1.00	1.00
Pdh $T_j = +2°C$	2.35kW	2.10kW
COPd $T_j = +2°C$	4.80	3.35
Cdh	1.00	1.00
Pdh $T_j = +7°C$	3.00kW	2.43kW
COPd $T_j = +7°C$	6.20	5.15
Cdh	0.90	0.90
Pdh $T_j = +12°C$	3.05kW	2.80kW
COPd $T_j = +12°C$	8.30	6.80
Cdh	0.90	0.90
Pdh $T_j =$ bivalent temperature	3.54kW	3.50kW
COPd $T_j =$ bivalent temperature	3.20	2.13
Pdh $T_j =$ TOL	4.00kW	3.10kW
COPd $T_j =$ TOL	2.75	1.90
WTOL	55°C	55°C
$P_{OFF}$	12W	12W
$P_{TO}$	0W	0W

$P_{SB}$	12W	12W
$P_{CK}$	0W	0W
Supplementary Heater:	electricity	electricity
Type of energy input		
Supplementary Heater:	0.00kW	0.90kW
$P_{SUP}$		
Annual energy consumption $Q_{HE}$	1754kWh	2357kWh

## Domestic Hot Water (DHW)

### Average Climate

#### EN 16147

Declared load profile	L
Efficiency $\eta_{dhw}$	132%
COP	3.30
Heating up time	1:43
Standby power input	37.0W
Reference hot water temperature	54.0°C
Mixed water at 40°C	263l

## Cooling

#### EN 14511-2

	<b>+7°C/+12°C</b>	<b>+18°C/+23°C</b>
Cooling capacity	4kW	5.5kW
EI input	1kW	1.02kW
EER	4	5.4

#### EN 14825

	<b>+7°C/+12°C</b>	<b>+18°C/+23°C</b>
SEER	5.57	8.04
P designc	4 kW	5.5 kW
Pdc Tj = 35°C	4 kW	5.5 kW
EER Tj = 35°C	4 kW	5.4
Pdc Tj = 30°C	2.95 kW	4.05 kW
EER Tj = 30°C	5	7.2
Cdc	1	1
Pdc Tj = 25°C	2.05 kW	2.61 kW
EER Tj = 25°C	6.45	9.6
Cdc	0.9	0.9
Pdc Tj = 20°C	2.88 kW	2.51 kW
EER Tj = 20°C	8	10.3
Cdc	0.9	0.9
Poff	12 W	12 W
Pto	0 W	0 W
Psb	12 W	12 W
Pck	0 W	0 W
Annual energy consumption $Q_{ce}$	431 kWh	410 kWh

03. RAS-2WHVRP RWD-2.0NRWE-200S-K - UK Version - Heating Only

### General Data

Power supply	1x230V 50Hz
Off-peak product	Yes

## Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30kW	4.30kW
EI input	0.82kW	1.43kW
COP	5.25	3.00
Indoor water flow rate	0.77m <sup>3</sup> /h	0.46m <sup>3</sup> /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

**Average Climate**

EN 12102-1

Sound power level indoor	37dB(A)	37dB(A)
Sound power level outdoor	61dB(A)	61dB(A)

EN 14825

	Low temperature	Medium temperature
$\eta_s$	181%	133%
$P_{rated}$	4.00kW	4.00kW
SCOP	4.60	3.40
$T_{biv}$	-7°C	-7°C
TOL	-10°C	-10°C
Pdh $T_j = -7°C$	3.54kW	3.50kW
COPd $T_j = -7°C$	3.20	2.13
Cdh	1.00	1.00
Pdh $T_j = +2°C$	2.35kW	2.10kW
COPd $T_j = +2°C$	4.80	3.35
Cdh	1.00	1.00
Pdh $T_j = +7°C$	3.00kW	2.43kW
COPd $T_j = +7°C$	6.20	5.15
Cdh	0.90	0.90
Pdh $T_j = +12°C$	3.05kW	2.80kW
COPd $T_j = +12°C$	8.30	6.80
Cdh	0.90	0.90
Pdh $T_j =$ bivalent temperature	3.54kW	3.50kW
COPd $T_j =$ bivalent temperature	3.20	2.13
Pdh $T_j =$ TOL	4.00kW	3.10kW
COPd $T_j =$ TOL	2.75	1.90
WTOL	55°C	55°C
$P_{OFF}$	12W	12W
$P_{TO}$	0W	0W
$P_{SB}$	12W	12W
$P_{CK}$	0W	0W
Supplementary Heater:	electricity	electricity
Type of energy input		
Supplementary Heater:	0.00kW	0.90kW
$P_{SUP}$		
Annual energy consumption $Q_{HE}$	1798kWh	2401kWh

Domestic Hot Water (DHW)

## Average Climate

EN 16147

Declared load profile	L
Efficiency $\eta_{dhw}$	132%
COP	3.30
Heating up time	1:43
Standby power input	37.0W
Reference hot water temperature	54.0°C
Mixed water at 40°C	263l

04. RAS-2WHVRP RWD-2.0NWE-200S-K - UK Version- with cooling kit

## General Data

Power supply	1x230V 50Hz
Off-peak product	Yes

## Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30kW	4.30kW
EI input	0.82kW	1.43kW
COP	5.25	3.00
Indoor water flow rate	0.77m <sup>3</sup> /h	0.46m <sup>3</sup> /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

## Average Climate

EN 12102-1

Sound power level indoor	37dB(A)	37dB(A)
Sound power level outdoor	61dB(A)	61dB(A)

EN 14825

	Low temperature	Medium temperature
$\eta_s$	186%	136%
$P_{rated}$	4.00kW	4.00kW
SCOP	4.73	3.48
$T_{biv}$	-7°C	-7°C
TOL	-10°C	-10°C
$P_{dh} T_j = -7°C$	3.54kW	3.50kW
$COP_d T_j = -7°C$	3.20	2.13
$C_{dh}$	1.00	1.00
$P_{dh} T_j = +2°C$	2.35kW	2.10kW
$COP_d T_j = +2°C$	4.80	3.35
$C_{dh}$	1.00	1.00
$P_{dh} T_j = +7°C$	3.00kW	2.43kW
$COP_d T_j = +7°C$	6.20	5.15
$C_{dh}$	0.90	0.90
$P_{dh} T_j = +12°C$	3.05kW	2.80kW

COPd Tj = +12°C	8.30	6.80
Cdh	0.90	0.90
Pdh Tj = bivalent temperature	3.54kW	3.50kW
COPd Tj = bivalent temperature	3.20	2.13
Pdh Tj = TOL	4.00kW	3.10kW
COPd Tj = TOL	2.75	1.90
WTOL	55°C	55°C
P <sub>OFF</sub>	12W	12W
P <sub>TO</sub>	0W	0W
P <sub>SB</sub>	12W	12W
P <sub>CK</sub>	0W	0W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: P <sub>SUP</sub>	0.00kW	0.90kW
Annual energy consumption Q <sub>HE</sub>	1754kWh	2357kWh

## Domestic Hot Water (DHW)

### Average Climate

#### EN 16147

Declared load profile	L
Efficiency $\eta_{dhw}$	132%
COP	3.31
Heating up time	1:43
Standby power input	37.0W
Reference hot water temperature	54.0°C
Mixed water at 40°C	263l

## Cooling

#### EN 14511-2

	+7°C/+12°C	+18°C/+23°C
Cooling capacity	4kW	5.5kW
EI input	1kW	1.02kW
EER	4	5.4

#### EN 14825

	+7°C/+12°C	+18°C/+23°C
SEER	5.57	8.04
P designc	4 kW	5.5 kW
Pdc Tj = 35°C	4 kW	5.5 kW
EER Tj = 35°C	4 kW	5.4
Pdc Tj = 30°C	2.95 kW	4.05 kW
EER Tj = 30°C	5	7.2
Cdc	1	1
Pdc Tj = 25°C	2.05 kW	2.61 kW
EER Tj = 25°C	6.45	9.6
Cdc	0.9	0.9
Pdc Tj = 20°C	2.88 kW	2.51 kW
EER Tj = 20°C	8	10.3
Cdc	0.9	0.9
Poff	12 W	12 W
Pto	0 W	0 W
Psb	12 W	12 W
Pck	0 W	0 W
Annual energy consumption Q <sub>ce</sub>	431 kWh	410 kWh

