

Subtype IDEAL HEATING Alféa Excellia A.I. 14

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	IDEAL HEATING Alféa Excellia A.I. 14
Registration number	012-SC0135-19
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.5 kg
Certification Date	04.04.2020

Model IDEAL HEATING Alféa Excellia A.I. 14

Model name	IDEAL HEATING Alféa Excellia A.I. 14
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	148 %	113 %
Prated	12.50 kW	11.30 kW
SCOP	3.77	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	1.90
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.60	2.80
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	3.90
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.90	5.10
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.10 kW	10.00 kW
COP Tj = Tbiv	2.50	1.90

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	9.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	72 W	25 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Qhe	6824 kWh	8041 kWh