

Subtype Samsung EHS TDM Plus R410A 9 kW 1Phase (wall-mounted hydro unit)

Certificate Holder	Samsung Electronics Air Conditioner Europe B.V.
Address	Evert van de Beekstraat 310
ZIP	1118 CX
City	Schiphol
Country	NL
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Samsung EHS TDM Plus R410A 9 kW 1Phase (wall-mounted hydro unit)
Registration number	011-1W0374
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.4 kg
Certification Date	29.07.2020
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 7

Model AE090MXTPEH/EU & AE090MNYDEH/EU

Model name	AE090MXTPEH/EU & AE090MNYDEH/EU
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	174 %	117 %
Prated	5.60 kW	5.50 kW
SCOP	4.42	3.01
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	4.90 kW
COP Tj = -7°C	2.67	1.77
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.00 kW	3.00 kW
COP Tj = +2°C	4.47	3.02
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.20 kW	2.30 kW
COP Tj = +7°C	5.74	3.90
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.00 kW	2.20 kW
COP Tj = 12°C	8.27	4.90
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.60 kW	5.50 kW

COP Tj = Tbiv	2.31	1.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.31	1.59
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2660 kWh	3885 kWh