

This information was generated by the HP KEYMARK database on 25 Feb 2023

	Samsung EHS LNHT 8kW (260L)	Reg. No.	011-1W0548
Certificate Holder			
	Samsung Electronics Air Conditioner Europe B.V.		
	Evert van de Beekstraat 310		1118 CX
	Schiphol		Netherlands
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Samsung EHS LNHT 8kW (260L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2.7 kg		
Certification Date	27.09.2022		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 10 (as of 2022-06)		

Model: AE080BXYDEG/EU & AE260RNWMEG/EU

Configure model	
Model name	AE080BXYDEG/EU & AE260RNWMEG/EU
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.60 kW	2.50 kW
COP	5.00	3.20

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	183 %	132 %
Prated	9.50 kW	9.50 kW
SCOP	4.65	3.37
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.40 kW	8.40 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.12 kW	5.12 kW
COP Tj = +2°C	4.55	3.20
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.00 kW	4.00 kW
COP Tj = +7°C	5.70	4.39
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 25 Feb 2023

Pdh Tj = 12°C	4.00 kW	4.00 kW
COP Tj = 12°C	7.70	5.45
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.40 kW	8.40 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.40 kW	9.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	2.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.10 kW	0.10 kW
Annual energy consumption Qhe	4219 kWh	5825 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.55
Heating up time	1:24 h:min
Standby power input	75.0 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	290 l

Model: AE080BXYDGG/EU & AE260RNWMGG/EU

Configure model	
Model name	AE080BXYDGG/EU & AE260RNWMGG/EU
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.60 kW	2.50 kW
COP	5.00	3.20

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	183 %	132 %
Prated	9.50 kW	9.50 kW
SCOP	4.65	3.37
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.40 kW	8.40 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.12 kW	5.12 kW
COP Tj = +2°C	4.55	3.20
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.00 kW	4.00 kW
COP Tj = +7°C	5.70	4.39
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 25 Feb 2023

Pdh Tj = 12°C	4.00 kW	4.00 kW
COP Tj = 12°C	7.70	5.45
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.40 kW	8.40 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.40 kW	9.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	2.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.10 kW	0.10 kW
Annual energy consumption Qhe	4219 kWh	5825 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.55
Heating up time	1:24 h:min
Standby power input	75.0 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	290 l