

Subtype Hi-Therma Split 4 6kW with 260L tank

Certificate Holder	Qingdao Hisense Hitachi Air-conditioning Systems Co.,Ltd.
Address	Qianwangang Road
ZIP	266555
City	Qingdao, Shandong
Country	CN
Certification Body	BRE Global Limited
Subtype title	Hi-Therma Split 4 6kW with 260L tank
Registration number	041-k021-07
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	0.98 kg
Certification Date	20.03.2023
Testing basis	Heat-pump Keymark Scheme rules v11

Model AHW-044HCDS1+AHM-044HCDSAA/HDHWT-300L30H**

Model name	AHW-044HCDS1+AHM-044HCDSAA/HDHWT-300L30H**
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	137 %
COP	3.33
Heating up time	2:24 h:min
Standby power input	28.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	280 l

Model AHW-060HCDS1+AHM-060HCDSAA/HDHWT-300L30H**

Model name	AHW-060HCDS1+AHM-060HCDSAA/HDHWT-300L30H**
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	137 %
COP	3.33
Heating up time	2:24 h:min
Standby power input	28.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	280 l