

## Subtype Beretta AGILE T 8M/11M WH

Certificate Holder	Riello S.p.A.
Address	Via Ing. Pilade Riello 7
ZIP	37045
City	Legnago (VR)
Country	IT
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Beretta AGILE T 8M/11M WH
Registration number	011-1W0724
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.25 kg
Certification Date	24.10.2023
Testing basis	HP KEYMARK certification scheme rules V12

## Model HP ODU AGILE 8M / HP IDU AGILE M3WM

Model name	HP ODU AGILE 8M / HP IDU AGILE M3WM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	182 %	142 %
Prated	8.18 kW	8.12 kW
SCOP	4.63	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.2 kW	7.3 kW

COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.9
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.38 kW	1.42 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

## Model HP ODU AGILE 8M / HP IDU AGILE T6WM

Model name	HP ODU AGILE 8M / HP IDU AGILE T6WM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	182 %	142 %
Prated	8.18 kW	8.12 kW
SCOP	4.63	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.2 kW	7.3 kW

COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.9
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.38 kW	1.42 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

## Model HP ODU AGILE 11M / HP IDU AGILE M3WM

Model name	HP ODU AGILE 11M / HP IDU AGILE M3WM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	179 %	142 %
Prated	8.93 kW	8.27 kW
SCOP	4.55	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.9 kW	7.3 kW
COP Tj = -7°C	2.59	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.9 kW	4.5 kW
COP Tj = +2°C	4.5	3.58
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3.1 kW	3 kW
COP Tj = +7°C	6.23	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.9 kW	7.3 kW

COP Tj = Tbiv	2.59	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.7 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.42	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.23 kW	1.57 kW
Annual energy consumption Qhe	4054 kWh	4728 kWh

## Model HP ODU AGILE 11M / HP IDU AGILE T6WM

Model name	HP ODU AGILE 11M / HP IDU AGILE T6WM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	179 %	142 %
Prated	8.93 kW	8.27 kW
SCOP	4.55	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.9 kW	7.3 kW
COP Tj = -7°C	2.59	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.9 kW	4.5 kW
COP Tj = +2°C	4.5	3.58
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3.1 kW	3 kW
COP Tj = +7°C	6.23	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.9 kW	7.3 kW



COP Tj = Tbiv	2.59	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.7 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.42	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.23 kW	1.57 kW
Annual energy consumption Qhe	4054 kWh	4728 kWh

## Model HP ODU AGILE 8M / HP IDU AGILE M6WM

Model name	HP ODU AGILE 8M / HP IDU AGILE M6WM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	182 %	142 %
Prated	8.18 kW	8.12 kW
SCOP	4.63	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.2 kW	7.3 kW

COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.9
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.38 kW	1.42 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

## Model HP ODU AGILE 11M / HP IDU AGILE M6WM

Model name	HP ODU AGILE 11M / HP IDU AGILE M6WM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	179 %	142 %
Prated	8.93 kW	8.27 kW
SCOP	4.55	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.9 kW	7.3 kW
COP Tj = -7°C	2.59	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.9 kW	4.5 kW
COP Tj = +2°C	4.5	3.58
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3.1 kW	3 kW
COP Tj = +7°C	6.23	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.9 kW	7.3 kW

COP Tj = Tbiv	2.59	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.7 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.42	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.23 kW	1.57 kW
Annual energy consumption Qhe	4054 kWh	4728 kWh