

This information was generated by the HP KEYMARK database on 25 Feb 2023

	Volan 9	Reg. No.	011-1W0531
Certificate Holder			
	THERMAGEN sp. z o.o.		
	Ul. Warszawska 50		82-100
	Nowy Dwór Gdański		Poland
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Volan 9		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	0.85 kg		
Certification Date	01.06.2022		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 9 (as of 2021-03)		

Model: Volan 9

Configure model	
Model name	Volan 9
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.20 kW	4.10 kW
El input	0.84 kW	1.30 kW
COP	4.98	3.15

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	218 %	171 %
Prated	6.50 kW	6.00 kW
SCOP	5.53	4.35
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.47 kW	5.96 kW
COP Tj = +2°C	3.39	2.49
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	4.12 kW	3.92 kW
COP Tj = +7°C	5.38	3.88
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.92 kW	4.59 kW
COP Tj = 12°C	6.66	5.67
Cdh Tj = +12 °C	0.990	0.990

This information was generated by the HP KEYMARK database on 25 Feb 2023

Pdh Tj = Tbiv	6.47 kW	5.96 kW
COP Tj = Tbiv	3.39	2.49
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.47 kW	5.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.39	2.49
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1570 kWh	1844 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	Low temperature	Medium temperature
η_s	148 %	125 %
Prated	4.50 kW	4.50 kW
SCOP	3.78	3.20
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	2.75 kW	2.48 kW
COP Tj = -7°C	3.80	2.88
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.12 kW	3.42 kW
COP Tj = +2°C	4.80	4.07
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	4.18 kW	4.06 kW
COP Tj = +7°C	6.13	5.26
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	2.26 kW	4.81 kW
COP Tj = 12°C	5.29	6.38
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	3.64 kW	3.71 kW
COP Tj = Tbiv	2.92	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.64 kW	3.71 kW

This information was generated by the HP KEYMARK database on 25 Feb 2023

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.92	2.24
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.50 kW	4.50 kW
Annual energy consumption Qhe	2936 kWh	3472 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.64	3.71
COP Tj = -15°C (if TOL<-20°C)	2.92	2.24
Cdh Tj = -15 °C	0.990	0.990

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	Low temperature	Medium temperature
η_s	180 %	142 %
Prated	5.00 kW	5.00 kW
SCOP	4.57	3.63
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.32 kW	4.40 kW
COP Tj = -7°C	3.27	2.35
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.18 kW	3.41 kW
COP Tj = +2°C	4.49	3.58
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	4.07 kW	3.85 kW
COP Tj = +7°C	5.87	4.81
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	5.11 kW	4.79 kW
COP Tj = 12°C	6.96	6.11
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	5.03 kW	4.40 kW
COP Tj = Tbiv	3.01	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.03 kW	4.52 kW

This information was generated by the HP KEYMARK database on 25 Feb 2023

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.01	2.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.48 kW
Annual energy consumption Qhe	2258 kWh	2844 kWh