

## Subtype DC Inverter Type Air to Water Unit- R410A- 45kW

Certificate Holder	Zhongshan Amitime Electric Co., Ltd
Address	5th Yandong Rd
ZIP	
City	Zhongshan City - Guangdong
Country	CN
Certification Body	BRE Global Limited
Subtype title	DC Inverter Type Air to Water Unit- R410A- 45kW
Registration number	041-K027-22
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	8 kg
Certification Date	31.10.2023
Testing basis	Heat Pump KEYMARK certification Scheme rules v12

Model Indoor unit: PEVH-45V4DEA/IA, Outdoor unit: PEVH-45V4DEA

Model name	Indoor unit: PEVH-45V4DEA/IA, Outdoor unit: PEVH-45V4DEA
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

#### General data

Power supply	3x400V 50Hz
Off-peak product	n/a

#### Outdoor Air/Water

##### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

##### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	32 dB(A)	32 dB(A)
Sound power level outdoor	71 dB(A)	72 dB(A)

##### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	156 %	134 %
Prated	32.41 kW	37.01 kW
SCOP	3.98	3.44
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	28.67 kW	32.74 kW
COP Tj = -7°C	2.82	2.04
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	18.20 kW	19.98 kW
COP Tj = +2°C	4.04	3.50
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	15.76 kW	16.23 kW
COP Tj = +7°C	5.01	4.51
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	17.48 kW	18.95 kW
COP Tj = 12°C	5.69	5.93
Cdh Tj = +12 °C	0.900	0.900

Pdh Tj = Tbiv	28.67 kW	32.74 kW
COP Tj = Tbiv	2.82	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	26.09 kW	31.31 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.58	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	36 W	36 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.32 kW	5.71 kW
Annual energy consumption Qhe	16825 kWh	22261 kWh