

Subtype CTC EcoPart 408

Certificate Holder	Enertech CTC AB
Address	Box 309, Näsvägen
ZIP	SE-341 26
City	Ljungby
Country	SE
Certification Body	RISE CERT
Subtype title	CTC EcoPart 408
Registration number	012-063
Heat Pump Type	Brine/Water
Refrigerant	R407c
Mass of Refrigerant	1.9 kg

Model CTC EcoPart 408 1x230V

Model name	CTC EcoPart 408 1x230V
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	180 %	136 %
Prated	6.45 kW	8.72 kW
SCOP	4.70	3.60
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.20 kW	7.70 kW
COP Tj = -7°C	4.76	3.28
Pdh Tj = +2°C	8.30 kW	7.90 kW
COP Tj = +2°C	4.86	3.62
Pdh Tj = +7°C	8.30 kW	8.00 kW
COP Tj = +7°C	5.04	4.00
Pdh Tj = 12°C	8.40 kW	8.10 kW
COP Tj = 12°C	5.21	4.38
Pdh Tj = Tbiv	8.20 kW	7.70 kW
COP Tj = Tbiv	4.67	3.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.19 kW	7.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.58	3.13
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

Poff	18 W	18 W
PTO	13 W	4 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	1.10 kW
Annual energy consumption Qhe	4092 kWh	4995 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	183 %	139 %
Prated	8.92 kW	8.62 kW
SCOP	4.80	7.70
Tbiv	-19 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.30 kW	7.80 kW
COP Tj = -7°C	4.88	3.55
Pdh Tj = +2°C	8.30 kW	8.00 kW
COP Tj = +2°C	5.04	3.92
Pdh Tj = +7°C	8.40 kW	8.10 kW
COP Tj = +7°C	5.16	4.27
Pdh Tj = 12°C	8.40 kW	8.20 kW
COP Tj = 12°C	5.19	4.52
Pdh Tj = Tbiv	8.20 kW	7.70 kW
COP Tj = Tbiv	4.67	3.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.19 kW	7.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.58	3.13
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	13 W	4 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.70 kW	0.70 kW
Annual energy consumption Qhe	4612 kWh	4612 kWh

Model CTC EcoPart 408 3x400V

Model name	CTC EcoPart 408 3x400V
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	180 %	136 %
Prated	6.45 kW	8.72 kW
SCOP	4.70	3.60
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.20 kW	7.70 kW
COP Tj = -7°C	4.76	3.28
Pdh Tj = +2°C	8.30 kW	7.90 kW
COP Tj = +2°C	4.86	3.62
Pdh Tj = +7°C	8.30 kW	8.00 kW
COP Tj = +7°C	5.04	4.00
Pdh Tj = 12°C	8.40 kW	8.10 kW
COP Tj = 12°C	5.21	4.38
Pdh Tj = Tbiv	8.20 kW	7.70 kW
COP Tj = Tbiv	4.67	3.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.19 kW	7.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.58	3.13
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

Poff	18 W	18 W
PTO	13 W	4 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	1.10 kW
Annual energy consumption Qhe	4092 kWh	4995 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	183 %	139 %
Prated	8.92 kW	8.62 kW
SCOP	4.80	7.70
Tbiv	-19 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.30 kW	7.80 kW
COP Tj = -7°C	4.88	3.55
Pdh Tj = +2°C	8.30 kW	8.00 kW
COP Tj = +2°C	5.04	3.92
Pdh Tj = +7°C	8.40 kW	8.10 kW
COP Tj = +7°C	5.16	4.27
Pdh Tj = 12°C	8.40 kW	8.20 kW
COP Tj = 12°C	5.19	4.52
Pdh Tj = Tbiv	8.20 kW	7.70 kW
COP Tj = Tbiv	4.67	3.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.19 kW	7.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.58	3.13
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	13 W	4 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.70 kW	0.70 kW
Annual energy consumption Qhe	4612 kWh	4612 kWh