

## Subtype CTC CombiAir 6MR

Certificate Holder	Enertech CTC AB
Address	Box 309, Näsvägen
ZIP	SE-341 26
City	Ljungby
Country	SE
Certification Body	RISE CERT
Subtype title	CTC CombiAir 6MR
Registration number	012-C700184
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.3 kg
Certification Date	30.05.2023
Testing basis	EN 14511:2018, EN 14825:2018, EN 12102:2017.

## Model CTC CombiAir 6MR

Model name	CTC CombiAir 6MR
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	200 %	139 %
Prated	5.20 kW	5.60 kW
SCOP	5.08	3.56
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.54 kW	5.04 kW
COP Tj = -7°C	3.04	1.95
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	2.70 kW	2.89 kW
COP Tj = +2°C	5.00	3.51
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	1.78 kW	1.89 kW
COP Tj = +7°C	6.67	4.99
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	1.83 kW	1.74 kW
COP Tj = 12°C	8.54	6.33
Cdh Tj = +12 °C	0.950	0.960
Pdh Tj = Tbiv	5.23 kW	5.04 kW
COP Tj = Tbiv	2.61	1.95

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.23 kW	4.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.61	1.75
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	58 °C	58 °C
Poff	7 W	7 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	1.00 kW
Annual energy consumption Qhe	2116 kWh	3250 kWh