

Subtype M thermal A series 18 22 26 30 kW

Certificate Holder	GD Midea Heating & Ventilating Equipment Co., Ltd.
Address	Penglai Industry Road
ZIP	528311
City	Beijiao, Shunde, Foshan
Country	CN
Certification Body	BRE Global Limited
Subtype title	M thermal A series 18 22 26 30 kW
Registration number	041-K007-11
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	5 kg
Certification Date	02.12.2020
Testing basis	HP Keymark Scheme Rules Rev 08

Model MHC-V18W/D2RN8

Model name	MHC-V18W/D2RN8
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	125 %
Prated	17.99 kW	17.67 kW
SCOP	4.60	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	15.90 kW	15.61 kW
COP Tj = -7°C	2.85	1.72
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	9.66 kW	9.59 kW
COP Tj = +2°C	4.59	3.32
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.56 kW	6.37 kW
COP Tj = +7°C	5.99	4.48
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.76 kW	3.57 kW
COP Tj = 12°C	7.08	5.27
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	15.90 kW	15.61 kW
COP Tj = Tbiv	2.85	1.72

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.99 kW	15.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.17
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	2.64 kW
Annual energy consumption Qhe	8086 kWh	11375 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	146 %	97 %
Prated	17.76 kW	18.38 kW
SCOP	3.73	2.50
Tbiv	-15 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	11.21 kW	11.13 kW
COP Tj = -7°C	3.09	1.98
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.64 kW	6.65 kW
COP Tj = +2°C	4.50	3.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.77 kW	4.66 kW
COP Tj = +7°C	5.85	4.35
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.95 kW	3.74 kW
COP Tj = 12°C	7.18	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.49 kW	11.13 kW
COP Tj = Tbiv	2.42	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.14 kW	13.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.21
WTOL	60 °C	60 °C
Poff	20 W	20 W

PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.62 kW	18.38 kW
Annual energy consumption Q _{he}	11740 kWh	18156 kWh
P _{dh} T _j = -15°C (if TOL	14.49	13.56
COP T _j = -15°C (if TOL	2.42	1.21
C _{dh} T _j = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	226 %	157 %
Prated	17.67 kW	18.07 kW
SCOP	5.74	4.00
T _{biv}	7 °C	7 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	17.67 kW	18.07 kW
COP T _j = +2°C	3.53	2.12
C _{dh} T _j = +2 °C	0.900	0.900
P _{dh} T _j = +7°C	11.36 kW	11.62 kW
COP T _j = +7°C	5.16	3.49
C _{dh} T _j = +7 °C	0.900	0.900
P _{dh} T _j = 12°C	5.45 kW	5.35 kW
COP T _j = 12°C	7.01	5.09
C _{dh} T _j = +12 °C	0.900	0.900
P _{dh} T _j = T _{biv}	11.36 kW	11.62 kW
COP T _j = T _{biv}	5.16	3.49
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	17.67 kW	18.07 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.53	2.12
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}		
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q_{he}

4116 kWh

6041 kWh

Model MHC-V22W/D2RN8

Model name	MHC-V22W/D2RN8
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	178 %	126 %
Prated	22.31 kW	22.43 kW
SCOP	4.53	3.22
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	19.72 kW	19.82 kW
COP Tj = -7°C	2.74	1.74
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	12.03 kW	11.89 kW
COP Tj = +2°C	4.41	3.32
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.97 kW
COP Tj = +7°C	6.29	4.66
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.79 kW	3.60 kW
COP Tj = 12°C	7.14	5.32
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	19.72 kW	19.82 kW
COP Tj = Tbiv	2.74	1.74

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.33 kW	13.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.08
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.97 kW	8.60 kW
Annual energy consumption Qhe	10180 kWh	14390 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	146 %	102 %
Prated	21.40 kW	22.36 kW
SCOP	3.72	2.62
Tbiv	-15 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	13.30 kW	13.53 kW
COP Tj = -7°C	3.12	2.07
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.25 kW	8.61 kW
COP Tj = +2°C	4.42	3.70
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.45 kW	5.21 kW
COP Tj = +7°C	5.87	4.49
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.98 kW	3.74 kW
COP Tj = 12°C	7.19	5.76
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	17.46 kW	13.53 kW
COP Tj = Tbiv	2.36	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.27 kW	13.78 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.69	1.24
WTOL	60 °C	60 °C
Poff	20 W	20 W
PTO	96 W	96 W
PSB	18 W	18 W

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	8.13 kW	22.36 kW
Annual energy consumption Q _{he}	14179 kWh	21067 kWh
P _{dh} T _j = -15°C (if TOL	17.46	13.78
COP T _j = -15°C (if TOL	2.36	1.24
C _{dh} T _j = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	234 %	161 %
Prated	21.90 kW	22.01 kW
SCOP	5.85	4.09
T _{biv}	7 °C	7 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	21.81 kW	22.01 kW
COP T _j = +2°C	3.31	2.12
C _{dh} T _j = +2 °C	0.900	0.900
P _{dh} T _j = +7°C	14.08 kW	14.15 kW
COP T _j = +7°C	5.20	3.50
C _{dh} T _j = +7 °C	0.900	0.900
P _{dh} T _j = 12°C	6.44 kW	6.38 kW
COP T _j = 12°C	7.50	5.34
C _{dh} T _j = +12 °C	0.900	0.900
P _{dh} T _j = T _{biv}	14.08 kW	14.15 kW
COP T _j = T _{biv}	5.20	3.50
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	21.81 kW	22.01 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.31	2.12
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}		
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.09 kW	0.00 kW
Annual energy consumption Q _{he}	4945 kWh	7180 kWh

Model MHC-V26W/D2RN8

Model name	MHC-V26W/D2RN8
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	75 dB(A)	75 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	177 %	123 %
Prated	25.04 kW	26.15 kW
SCOP	4.50	3.14
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	22.12 kW	20.64 kW
COP Tj = -7°C	2.57	1.69
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	13.76 kW	14.26 kW
COP Tj = +2°C	4.44	3.12
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	9.36 kW	9.29 kW
COP Tj = +7°C	6.52	4.74
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.09 kW	3.89 kW
COP Tj = 12°C	7.35	5.48
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	22.12 kW	22.11 kW
COP Tj = Tbiv	2.57	1.88

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.33 kW	13.86 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.08
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.68 kW	12.28 kW
Annual energy consumption Qhe	11489 kWh	17204 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	75 dB(A)	75 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	143 %	101 %
Prated	25.75 kW	26.27 kW
SCOP	3.64	2.59
Tbiv	-12 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	15.91 kW	15.90 kW
COP Tj = -7°C	3.10	2.10
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	10.10 kW	10.17 kW
COP Tj = +2°C	4.45	3.58
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	6.30 kW	6.52 kW
COP Tj = +7°C	6.06	4.99
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.03 kW	3.63 kW
COP Tj = 12°C	7.13	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	18.97 kW	15.90 kW
COP Tj = Tbiv	2.36	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.07 kW	13.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.20
WTOL	60 °C	60 °C
Poff	20 W	20 W
PTO	96 W	96 W
PSB	18 W	18 W

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	12.68 kW	26.27 kW
Annual energy consumption Q _{he}	17421 kWh	24967 kWh
P _{dh} T _j = -15°C (if TOL	18.95	13.37
COP T _j = -15°C (if TOL	2.27	1.20
C _{dh} T _j = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	75 dB(A)	75 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	231 %	168 %
Prated	26.08 kW	26.22 kW
SCOP	5.85	4.26
T _{biv}	7 °C	7 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	25.50 kW	26.22 kW
COP T _j = +2°C	3.00	1.99
C _{dh} T _j = +2 °C	0.900	0.900
P _{dh} T _j = +7°C	16.77 kW	16.86 kW
COP T _j = +7°C	5.02	3.47
C _{dh} T _j = +7 °C	0.900	0.900
P _{dh} T _j = 12°C	7.65 kW	7.58 kW
COP T _j = 12°C	7.78	5.94
C _{dh} T _j = +12 °C	0.900	0.900
P _{dh} T _j = T _{biv}	16.77 kW	16.86 kW
COP T _j = T _{biv}	5.02	3.47
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	25.50 kW	26.22 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.00	1.99
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}		
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	0.00 kW
Annual energy consumption Q _{he}	5959 kWh	8218 kWh

Model MHC-V30W/D2RN8

Model name	MHC-V30W/D2RN8
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	77 dB(A)	77 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	123 %
Prated	29.18 kW	29.69 kW
SCOP	4.19	3.14
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	21.90 kW	20.11 kW
COP Tj = -7°C	2.54	1.63
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	16.16 kW	16.49 kW
COP Tj = +2°C	4.16	3.09
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	10.64 kW	10.50 kW
COP Tj = +7°C	6.38	4.75
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.54 kW	4.64 kW
COP Tj = 12°C	7.72	5.91
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	23.51 kW	23.97 kW
COP Tj = Tbiv	2.71	2.02

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.37 kW	13.82 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.07
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	8.75 kW	15.86 kW
Annual energy consumption Qhe	14165 kWh	19316.17 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	77 dB(A)	77 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	138 %	100 %
Prated	29.13 kW	30.41 kW
SCOP	3.52	2.56
Tbiv	-10 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	18.49 kW	18.40 kW
COP Tj = -7°C	3.07	2.10
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	11.88 kW	11.22 kW
COP Tj = +2°C	4.42	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.53 kW	7.42 kW
COP Tj = +7°C	6.15	5.18
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.11 kW	3.64 kW
COP Tj = 12°C	6.87	5.73
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	19.93 kW	18.40 kW
COP Tj = Tbiv	2.44	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.17 kW	13.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.18
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	15.96 kW	30.41 kW
Annual energy consumption Q _{he}	20390 kWh	29238 kWh
P _{dh} T _j = -15°C (if TOL	18.61	13.06
COP T _j = -15°C (if TOL	2.24	1.18
C _{dh} T _j = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	77 dB(A)	77 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	213 %	163 %
Prated	30.44 kW	29.73 kW
SCOP	5.39	4.15
T _{biv}	7 °C	7 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	26.29 kW	26.41 kW
COP T _j = +2°C	2.94	1.99
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	19.57 kW	19.11 kW
COP T _j = +7°C	4.75	3.37
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	8.90 kW	8.92 kW
COP T _j = 12°C	7.53	6.09
C _{dh} T _j = +12 °C	0.90	0.90
P _{dh} T _j = T _{biv}	19.57 kW	19.11 kW
COP T _j = T _{biv}	4.75	3.37
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	26.29 kW	26.41 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.94	1.99
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.15 kW	3.32 kW
Annual energy consumption Q _{he}	7540 kWh	9580 kWh