

## Subtype DC Inverter Heat Pump R290-60

Certificate Holder	Power World Machinery Equipment Co. Ltd
Address	No.24, The Fourth Industrial Zone, HouTing Street
ZIP	
City	Shenzhen
Country	CN
Certification Body	BRE Global Limited
Subtype title	DC Inverter Heat Pump R290-60
Registration number	041-K032-10
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.4 kg
Certification Date	30.06.2023
Testing basis	Heat Pump Keymark Scheme Rules Rev 12

## Model PW060-DKZLRS-E

Model name	PW060-DKZLRS-E
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	62 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	185 %	139 %
Prated	14.05 kW	13.47 kW
SCOP	4.69	3.55
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.43 kW	11.91 kW
COP Tj = -7°C	3.34	2.38
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	7.57 kW	7.29 kW
COP Tj = +2°C	4.52	3.49
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.14 kW	7.66 kW
COP Tj = +7°C	6.38	4.73
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	8.98 kW	8.89 kW
COP Tj = 12°C	8.11	6.50
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	12.43 kW	11.91 kW
COP Tj = Tbiv	3.34	2.38

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.01 kW	13.29 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	2.08
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	39 W	39 W
PSB	13 W	13 W
PCK	54 W	54 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.04 kW	0.18 kW
Annual energy consumption Qhe	6189 kWh	7844 kWh